

Support for setting up a Smart Readiness Indicator for buildings and related impact assessment

Second progress report

VITO: Stijn Verbeke, Yixiao Ma, Paul Van Tichelen, Sarah Bogaert

Waide Strategic Efficiency: Paul Waide

OFFIS: Mathias Uslar, Judith Schulte

ECOFYS: Kjell Bettgenhäuser, Ashok John, Andreas Hermelink, Markus Offermann, Jan Groezinger

Study accomplished under the authority of the European Commission DG Energy

2017/SEB/R/1610684

Date: 12 June 2018



VITO NV

Boeretang 200 - 2400 MOL - BELGIE
Tel. + 32 14 33 55 11 - Fax + 32 14 33 55 99
vito@vito.be - www.vito.be

BTW BE-0244.195.916 RPR (Turnhout)
Bank 375-1117354-90 ING
BE34 3751 1173 5490 - BBRUBEBB

All rights, amongst which the copyright, on the materials described in this document rest with the Flemish Institute for Technological Research NV ("VITO"), Boeretang 200, BE-2400 Mol, Register of Legal Entities VAT BE 0244.195.916.

The information provided in this document is confidential information of VITO. This document may not be reproduced or brought into circulation without the prior written consent of VITO. Without prior permission in writing from VITO this document may not be used, in whole or in part, for the lodging of claims, for conducting proceedings, for publicity and/or for the benefit or acquisition in a more general sense.

This study was ordered and paid for by the European Commission, Directorate-General for Energy, Contract no. ENER/C3/2016-554/SI2.749248. The information and views set out in this study are those of the authors and do not necessarily reflect the official opinion of the Commission. The Commission does not guarantee the accuracy of the data included in this study. Neither the Commission nor any person acting on the Commission's behalf may be held responsible for the use which may be made of the information contained therein.

TABLE OF CONTENTS

Table of Contents	1
List of Acronyms	5
CHAPTER 1 Executive Summary	1
CHAPTER 2 Scope and objectives of study and second progress Report	1
2.1. Background	1
2.2. Objectives of the study	2
2.3. This Second Progress Report	3
CHAPTER 3 Task 1 – SRT characterization, market analysis and industrial capacities evolution in EU	4
3.1. Terminology and glossary	4
3.2. Compiling the Smart Ready Services catalogue	6
3.2.1. Scope and selection criteria	6
3.2.2. Structure of the Smart Ready Services catalogue	7
3.2.3. Format of the Smart Ready Services catalogue	10
3.3. Selection and assessment of the services	11
3.3.1. Smart ready services domains	11
3.3.2. Provisional impact of the various services	15
3.3.3. Updating the smart service catalogue	15
3.4. Data protection, cybersecurity, interoperability and standardisation	16
3.4.1. Data protection	16
3.4.2. Cyber security in the context of the SRI indicator	17
3.4.3. Interoperability in the context of the SRI Indicator	18
3.4.4. Standards identified and covered for the service catalogue	19
CHAPTER 4 Task 2 - Robust methodology for the harmonised calculation at EU level of the SRI for buildings	21
4.1. Factors to consider in deriving an SRI	22
4.2. Development of a generic SRI methodology	30
4.2.1. Multi-criteria decision-making methods	30
4.2.2. Derivation of a generic SRI methodology	32
4.2.3. Theoretical application of Task 1 elements within the generic methodology	35
4.2.4. Viability analysis	41
4.3. Practical Considerations	51
4.3.1. Practical elements that affect the ability to implement an SRI	51
4.3.2. Review of the maturity of the Task 1 elements	52
4.4. Streamlining the smart ready service catalogue	53
4.4.1. Streamlining the SRI elements	53
4.4.2. Case study 1 – A Single Family House	67
4.4.3. Case study 2 – An office	72

4.5.	<i>Tailoring the SRI</i>	80
4.5.1.	Tailoring to take account of the buildings needs and context _____	80
4.5.2.	Examples of how the methodology can be tailored to needs and context _____	81
4.6.	<i>Evolutionary methodological approaches</i>	83
4.6.1.	Incorporating cardinal data assessment of impacts _____	84
4.6.2.	Using calculation software _____	85
4.6.3.	Using measured outcome based approaches _____	86
4.6.4.	Checklist based approaches _____	87
4.6.5.	Evolutionary hybrid approach _____	87
4.7.	<i>Organising and reporting the SRI</i>	88
4.8.	<i>Linkages with other schemes</i>	89
4.8.1.	Linkage with EPCs _____	90
4.8.2.	Linkage with Building renovation passports _____	91
4.8.3.	Linkage with LEVELS _____	91
4.9.	<i>Options for implementation</i>	94
4.9.1.	accounting for services that are not present _____	94
4.9.2.	smart services present in different parts of the building _____	95
4.9.3.	Complex (multi-mode) buildings _____	95
4.9.4.	Climatic zones _____	96
4.9.5.	Should different categories of buildings be targeted? _____	97
4.9.6.	Building Information Modelling _____	97
4.9.7.	Interoperability, broadband and smart meters _____	98
4.9.8.	Industry and sector specific indicators _____	98
4.9.9.	Differentiation and commons aspects of SRI implementation _____	99
4.10.	<i>Application of the streamlined methodology to actual buildings</i>	99
4.10.1.	Field case study – a traditional single family house _____	100
4.10.2.	Field case study – a contemporary office building _____	109
4.11.	<i>Provisional conclusions of Task 2</i>	117
CHAPTER 5	Task 3: Stakeholder consultation _____	119
CHAPTER 6	Task 4: Impact Assessment _____	121
6.1.	<i>Summary</i>	121
6.2.	<i>Scope and Goal of the Impact Assessment</i>	123
6.3.	<i>First Results</i>	124
6.3.1.	Underlying Building sector pathways _____	124
6.3.2.	SRT scenarios _____	126
6.3.3.	Sensitivity analysis _____	128
6.3.4.	Life-cycle aspects _____	129
6.3.5.	Policy Measures _____	129
6.4.	<i>Methodology and Approach</i>	129
6.4.1.	Building Sector Scenarios Methodology _____	129
6.4.2.	SRT Scenarios Methodology _____	131
6.5.	<i>Provisional conclusions of the impact assessment</i>	135
CHAPTER 7	Conclusions and next steps _____	137

CHAPTER 8 Annexes	139
ANNEX A - The Smart Ready Services Catalogue	140
ANNEX B – Glossary	144
ANNEX C – Interoperability of smart ready technologies	146
ANNEX D – Standardisation related to smart buildings	148
D.1. The Energy Performance of Buildings Directive (EPBD), the Construction Products Regulation (CPR) and its relationship to standardisation and Mandate (M/480)	148
D.2. Interaction with the electrical grid and the Smart Grid Standardization Mandate (M/490)	148
D.3. Interaction with Ecodesign product regulation and standardisation mandate (M/495)	149
D.4. Background information on European and international standardization bodies	149
D.5. A selection of the most relevant standards for SRI	150
ANNEX E – Hype Cycles to assess maturity of services	161
ANNEX F – Review of applicability of services for inclusion in Sri	167
F.1. Services within the heating domain	167
F.2. Services within the DHW domain	168
F.3. Services within the cooling domain	168
F.4. Services within the ventilation domain	169
F.5. Services within the lighting domain	170
F.6. Services within the dynamic building envelope domain	170
F.7. Services within the energy generation domain	171
F.8. Services within the demand side management domain	171
F.9. Services within the Electric vehicle charging domain	172
F.10. Services within the monitoring and control domain	173
ANNEX G - An Actionable Subset of Smart Readiness Elements	174
ANNEX H - The Built-Environment-Analysis-Model BEAM²	176
H.1. Terms and Definitions	176
H.2. Scope	176
H.3. Structure and Methodology	178
H.4. Scenario Results	180
H.5. Input Data	180
ANNEX I – Building sector Scenarios – Assumptions and detailed results	181
<i>I.1. Pathway definitions and parameters</i>	<i>181</i>
<i>I.1.1. Building sector scenario parameters - Agreed Amendments pathway</i>	<i>181</i>
<i>I.1.2. I.1.2 Building sector scenario parameters – Agreed Amendments + Ambitious Implementation pathway</i>	<i>182</i>
<i>I.2. Detailed Model inputs</i>	<i>182</i>
<i>I.2.1. Agreed Amendments to the EPBD</i>	<i>182</i>
<i>I.2.2. Adjustments to the EPBD IA parameters</i>	<i>183</i>

<i>I.3. Building stock disaggregation</i>	189
<i>I.3.1. Reference zones and climates</i>	189
<i>I.3.2. Reference Buildings</i>	190
<i>I.3.3. Age groups</i>	196
<i>I.3.4. Retrofit Levels</i>	197
<i>I.3.5. Building stock characteristics</i>	198
<i>I.3.6. Floor Areas</i>	198
<i>I.4. Detailed building sector Pathways</i>	202
<i>I.4.1. AGREED AMENDMENTS PATHWAY</i>	202
<i>I.4.2. Agreed Amendments + Ambitious Implementation Pathway</i>	235
ANNEX J – SRT Scenarios – Detailed Assumptions (To be completed)	237
ANNEX K – Current and additional accompanying policies	238
<i>K.1. Current policies</i>	238
<i>K.1.1. Regulatory law</i>	238
<i>K.1.2. Information measures member states</i>	243
<i>K.1.3. Incentives</i>	243
<i>K.2. Additional accompanying policy measures</i>	245
<i>K.2.1. Measures for increasing the reliability of EPC</i>	245
<i>K.2.2. Measures for eliminating financial risks attributed to energy efficiency and renewable energy investments</i>	246
<i>K.2.3. Information and evaluation</i>	246
ANNEX L Multi criteria decision making METHODS	247
ANNEX M - Calculation process details for the in-field Single Family Home case study	248
ANNEX N - Reference list	255

LIST OF ACRONYMS

BACS	Building Automation and Control Systems
BEMS	Building Energy Management System
DPC	Data Protection Class
DER	Distributed Energy Resource
DHW	Domestic Hot Water
DBE	Dynamic Building Envelope
EV	Electric Vehicle
EVSE	Electric Vehicle Supply Equipment
EED	Energy Efficiency Directive
EPC	Energy Performance Certificate
EPBD	Energy Performance of Buildings Directive
EC	European Commission
HEMS	Home Energy Management System
ICT	Information and Communication Technologies
MV	Mechanical Ventilation
MS	Member States
M&C	Monitoring & Control
MCD	Multi-criteria decision analysis
MCDM	Multi-criteria decision making
MFH	Multi-Family Home
RES	Renewable Energy Systems
SFH	Single Family Home
SRI	Smart Readiness Indicator
SR	Smart Ready
SRT	Smart Ready Technologies
TBS	Technical Building Systems
TES	Thermal Energy Storage

CHAPTER 1 EXECUTIVE SUMMARY

Executive summary of the second progress report of the technical study “Support for setting up a Smart Readiness Indicator for buildings and related impact assessment”¹

This document summarizes the intermediate conclusions of the technical study commissioned and supervised by the European Commission services (DG ENERGY) towards the development of a smart readiness indicator for buildings². The smart readiness indicator is part of the revised Energy Performance of Buildings Directive³. A Smart Readiness Indicator (SRI) for buildings shall provide information on the technological readiness of buildings to interact with their occupants and the energy grids, and their capabilities for more efficient operation and better performance through ICT technologies. This technical study explores the potential characteristics of the indicator via a transparent, open and interactive process, with the objective to support and inform the policy making process.

MOTIVATION - SMART BUILDINGS

Smart Building




Figure 1: Illustration of a smart building

There is a clear need to accelerate building renovation investments and leverage smart, energy-efficient technologies in the building sector. Smart buildings integrate cutting edge ICT-based solutions for energy efficiency and energy flexibility as part of their daily operation. Such smart

¹ Technical study carried out by VITO, Waide Strategic Efficiency, Ecofys and OFFIS for European Commission DG Energy. Reference: Verbeke S., Waide P., Bettenhäuser K., Usslar M.; Bogaert S.; “Support for setting up a Smart Readiness Indicator for buildings and related impact assessment - second progress report executive summary”; June 2018; Brussels

² See <https://smartreadinessindicator.eu> for further information on the study.

³ See press release of May 14th 2018: https://ec.europa.eu/info/news/commission-welcomes-council-adoption-new-energy-performance-buildings-directive-2018-may-14_en. The Energy Performance of Building Directive is part of the Clean Energy for All Europeans Package

capabilities can effectively assist in creating healthier and more comfortable buildings with lower energy consumption and carbon impact. Smart buildings have also been identified and acknowledged as the key enablers of future energy systems for which there will be a larger share of renewables, distributed supply and energy flexibility on the demand side.

CONCEPT - SMART READINESS INDICATOR - SRI

Measure the technological readiness of your building



The ‘Smart Readiness Indicator’ (SRI) aims at making the added value of building smartness more tangible for building users, owners and tenants. The indicator should be an informative tool, whose objective is to raise awareness about the benefits of smart technologies and ICT in buildings, in particular from an energy perspective. The indicator can also improve policy linkages between energy, buildings and other policy segments, in particular in the ICT area, and thereby contribute to the integration of the buildings sector into future energy systems and markets.

Smartness of a building refers to the ability of that building or its systems to sense, interpret, communicate and actively respond in an efficient manner to changing conditions in the operation of technical building systems or the external environment (including energy grids) and to demands from building occupants.

A Smart Readiness Indicator (SRI) for buildings shall provide information on the technological readiness of buildings to interact with their occupants and the energy grids, and their capabilities for more efficient operation and better performance through ICT technologies.

THIS STUDY AND ITS PROGRESS

This study commissioned and supervised by the European Commission services (DG ENERGY) is intended to provide technical support to feed the discussions on the definition and provision of a smart readiness indicator for buildings. In particular, this study proposes a methodological framework for the SRI and the definition of smart services such an indicator can build upon. It also provides a preliminary evaluation of potential impacts of the proposed indicator at EU scale. This work is being carried out iteratively in close consultation with stakeholders. As part of the consultation process, a first stakeholder meeting has been organised in June 2017, a second meeting in December 2017 and a last one in May 2018. After each meeting, stakeholders were invited to provide written feedback to the reports and accompanying annexes. This feedback has led to important updates in the second progress report compared to the interim report distributed in December 2017, as described in the following paragraphs.

The **catalogue** of smart ready services has been significantly amended in light of stakeholder comments. In total 13 new services have been introduced and 21 of the services listed have been updated (modification of properties such as functionality levels or impact scores). Furthermore, the need for a well-established process to review and regularly update the catalogue has been advocated.

The **methodology** has been adapted and further streamlined to reflect the changes in the smart services catalogue. Based on growing insights and feedback received, a streamlined SRI methodology is proposed that uses a consolidated set of services which are relevant in the scope of the EPBD, have significant impacts, are actionable now and can be assessed in practice. Further consideration has been given to how the SRI methodology can be tailored to address specific contexts and how it can link to other assessment procedures and initiatives. Significant attention has been given as to how a flexible structure can be set up that allows the SRI (methodology) to be adapted over time and to make use of data available at that time (e.g. to make it possible to use quantified impact scores or actual measured data for specific impacts).

METHODOLOGY UNDERPINNING THE SRI

The study has developed a prospective SRI methodology and scoring system, in accordance with the following **guiding principles**:

- The methodology aims to create a technology-neutral level playing field for market actors through the definition of functional capability rather than the prescription of certain technological solutions.
- An initial assessment of building user expectations has orientated the approach towards a simple, expressive and easy to grasp indicator which conveys transparent and tangible information.
- The methodology balances the desire for a sufficiently detailed assessment with the desire to limit the time and cost requirements of assessing the smartness of a building.
- A multi-criteria assessment method allows for the incorporation of multiple distinct domains (e.g. both heating services as well as electric vehicle charging capabilities) and multiple distinct impact categories (e.g. energy efficiency, energy flexibility and provision of information to occupants).
- The SRI methodology can adapt to relevant contextual factors, which include variations by building type, climate, culture and the collective impact these have on the demand for certain services.


The resulting approach, as set out in the streamlined methodology and demonstrated via two in-field case studies, follows a simple checklist process that is straightforward and ready to implement currently.

Based on a site visit, an assessor inspects which smart ready services are present in a building, and to what functionality level they are implemented. This is assessed based on a simple **check-list approach** in which each smart service is defined in a technology-neutral way, e.g. “*control the power of artificial lighting*”. Each of the services can be implemented with various degrees of smartness (referred to as ‘functionality levels’), e.g. “*manual on/off control of lighting*”, “*automatic on/off switching of lighting based on daylight availability*”, or even “*automatic dimming of lighting based on daylight availability*”. A higher functionality level is expected to provide more beneficial impacts to the users of the building or the connected grid compared to a lower level.

In the proposed SRI methodology, the impacts of the smart services have been evaluated for eight domains: Energy savings, Flexibility for the grid, Self-generation, Comfort, Convenience, Health & Wellbeing, Maintenance & fault prediction and Information to occupants.

The SRI assessor follows a check-list approach to define which services are relevant for a building and to which functionality level they are implemented. These data are fed into an assessment interface and a simple analytical tool can be used to calculate the resulting scores. These may be aggregated by ‘domain’ (e.g. ‘heating’, ‘controlled ventilation’, etc.) and/or by impact criterion. In

this multi-criteria assessment, weightings can be attributed to domains and impact criteria to reflect their relative contributions or importance.



CATALOGUE OF SMART SERVICES

The proposed SRI methodology builds on the inspection of smart ready services in a building. Services are enabled by (a combination of) smart ready technologies, but are defined in a technology neutral way, e.g. *'provide temperature control in a room'*. Within the project and strengthened by stakeholder feedback, a catalogue of smart ready services has been developed. Many of these services are based on international technical standards.

In accordance with the revised EPBD, three key functionalities of smartness in buildings have been taken into account when defining the smart ready services in the SRI catalogue:

The ability to maintain energy efficiency performance and operation of the building through the adaptation of energy consumption for example through use of energy from renewable sources

And/or

The ability to adapt its operation mode in response to the needs of the occupant paying due attention to the availability of user-friendliness, maintaining healthy indoor climate conditions and ability to report on energy use

And/or

The flexibility of a building's overall electricity demand, including its ability to enable participation in active and passive as well as implicit and explicit demand-response, in relation to the grid, for example through flexibility and load shifting capacities.

In total, the catalogue currently contains 112 smart services. Not all of these services are equally viable to be included in a practical SRI assessment. For some of the services listed, relevant standards and methodological frameworks are currently lacking. For others, it is technically difficult to conduct an assessment on site, e.g. because the impacts are sensitive to the nature of the control algorithms applied. Finally, for some services the impacts are perceived low and not in balance with the assessment efforts needed. In consideration of these issues, the catalogue has been streamlined in order to focus on the most impacting and actionable services (see next section).

A STREAMLINED SET OF SERVICES FOR A PRACTICAL SRI ASSESSMENT

The **time and resources** needed for an SRI assessment will depend on multiple variables, such as the number of services to be inspected, the detail of the assessment of each of the services, the size and accessibility of the building and the expertise and experience of the assessor. The costs for deriving a SRI will also be affected by the requested qualifications of the assessor and the additional efforts needed for operating any accompanying calculation software, administrative tasks, travel time to the inspection site, etc. An important consideration in deriving the SRI methodology is thus to balance the desire of a sufficiently detailed assessment with the desire to keep the time and cost requirements limited.

The long-list of 112 smart ready services has been streamlined to ensure prioritisation of services with the highest expected benefits, maximum accordance with the EPBD scope and the highest potential for a viable practical assessment on-site. In the current proposal for a **streamlined methodology**, a reduced set of 52 actionable smart ready services has been selected. Even in the case of this proposed restricted set of services, further developments are needed to be unambiguously define services and functionality levels during a practical site visit, e.g. through the creation of inspection protocols.

In theory, a maximum of 52 smart services can be inspected in the streamlined methodology. In practice, this will be further reduced in a **triage process**, since some of the services will not be relevant for a particular building. If the building does not feature some of the technical systems such as a heat pump, a storage vessel for domestic hot water or heat recovery ventilation, the respective services controlling these systems obviously do not have to be assessed.

FIELD TEST ON CASE STUDY BUILDINGS

The streamlined methodology was tested in two field case studies: a traditional single family house located in Manchester (UK) and a contemporary office building located in Genk (Belgium). In each assessment, the following steps are undertaken:

Step 1: Triage process to assess which services are relevant for a particular building. For the residential building this resulted in 23 relevant services. For the more intricate office building 44 services were to be assessed, also including services with respect to cooling, electric vehicle charging and shading control

Step 2: For each of the applicable services it was assessed to what functionality level they are implemented in the building. This was done based on information gathered from a visual inspection during a walk-through of the building, an interview with the building occupant or facility manager and the review of documentation of the technical building systems.

Step 3: For each of the relevant services, the functionality level is filled out in a calculation tool (currently a simple spreadsheet). This tool retrieves the impacts on each of the 8 impact categories from a predefined dataset.

Step 4: The calculation tool aggregates all scores and weighs them by domain and impact scores. In the case study examples the domain weightings are different for the residential building and the office building to reflect a different importance of for example cooling and lighting in the distinct building types.

Step 5: The maximum obtainable weighted impact score is calculated by the calculation tool. This solely depends on services selected after the triage process.

Step 6: The overall SRI score is calculated as the ratio of the actual impact score (step 4) and the maximum attainable score (step 5).

The **result of the SRI assessment** could be presented as a an overall single score, as a relative score (e.g. indicating that a building achieves 65% of its potential smartness impacts) or as a label classification (e.g. SRI label class 'B'). Sub-scores could also be presented (e.g. 72% on energy savings and 63% on comfort). Additionally, recommendations could be presented to the building occupant/owner/manager on the options to increase the smartness of their building (e.g. to improve the score by reaching higher functionality levels on well targeted services).

With the streamlined list of services and the triage process in place, the time taken to conduct assessments is found to be similar to the time it takes to conduct EPC assessments in many countries.



(a) Single family house case study



(b) Office and laboratory case study building

A MODULAR, FLEXIBLE AND EVOLUTIONARY SRI

The SRI assessment procedure can evolve over time. The current working assumption is that of a competent assessor making a site visit to the premises to conduct the SRI assessment and compute its score. This may evolve over time into more sophisticated and less intrusive - thus less costly - assessment processes as the scheme becomes established. Examples include the use of Building Information Models (BIM) to facilitate the assessment process and the emergence of some form of standardised labelling present on packages of smart-ready products.

The proposed SRI calculation methodology itself can also evolve over time. It provides a **modular framework**, allowing flexibility to further specify and update the method over time:

- It can be tailored depending on which services are pertinent or practicable in specific contexts (e.g. type of buildings or climate).
- It may be adapted to include additional domains, services, functionality levels or impact categories. Therefore, a process will need to be implemented to allow introducing new services and service levels, update weightings and impact scores, based on the evolution of smart ready technologies available on the market.
- The current methodology is based on ordinal scores ascribed to each service functionality level. The method is however flexible to be expanded to allow more differentiation in impact scores (e.g. differentiating by building type) or also use cardinal impact scores derived from calculations, or even a blend of scoring mechanisms. It could also evolve to allow measured performance outcomes for some specific services and impact categories. In the event that

outcome-based assessments using dynamic metering become viable then it may no longer be necessary for the specific service to be assessed manually but rather it could be done via a display interface to the user and/or assessor.

- The SRI assessment can be linked to other assessment schemes and voluntary labels, and for example also inform the user on the EC *broadband ready* label of a building. This approach could also potentially allow engagement of voluntary schemes introduced by some industry and service sectors that go into greater depth for specific smart services.

SRI - CALCULATION METHODOLOGY

ONE SINGLE SCORE CLASSIFIES THE BUILDING'S SMART READINESS



total score is based on average of total scores on 8 impact criteria

8 IMPACT CRITERIA

energy 80%	flexibility 60%	self-generation 40%	comfort 90%	convenience 90%	health 70%	tech. follow-up 60%	info to occupant 80%
--------------------------	-------------------------------	-----------------------------------	---------------------------	-------------------------------	--------------------------	-----------------------------------	------------------------------------

energy **a/b %**

theoretical maximum
a= score b= max. building

an impact criterion score is expressed as a % of the maximum score that is achievable for the building type that is evaluated

not every domain is considered to be relevant for each impact criterion

an impact criterion is the weighted average of 10 domain scores

10 DOMAINS

heating **66%** — the impact criterion

this % is the weight the domain contributes to

the qualitative scores for the different heating services are aggregated into a quantitative measure

domestic hot water **18%**

a domain score is based on the qualitative evaluation of the implemented services on the impact criterion considered

EACH DOMAIN COVERS A SET OF SERVICES

heating serv. A	heating serv. B	heating serv. C	heating serv. D	heating serv. E	heating serv. F
heating serv. G	heating serv. H	heating serv. I	heating serv. J	heating serv. K	heating serv. L

the qualitative evaluation depends on the service's functionality level

QUALITATIVE IMPACT OF A SERVICE ON ALL IMPACT CRITERIA

heating serv. G

functionality level 1						
functionality level 2						
functionality level 3						
functionality level 4						

for each service several functionality levels are defined

the higher the functionality level, the higher it's expected contribution to an impact criterion

BENEFITS AND COSTS OF A SRI

As part of the technical study, an **impact assessment** is performed to analyse benefits and costs of implementing a SRI in buildings to support an increased uptake of smart ready technologies in buildings in the EU. It also aims to understand the impact of accompanying policies to enhance the impact of the SRI. The methodology for assessing the potential impacts of the SRI is split into two steps.

The first focuses on the modelling of the evolution of the **EU building stock** within the framework of the revised EPBD. The building sector pathways used in this analysis describe the general development of the building sector calculated in five geographic zones across the EU. They take into account new buildings, demolition of buildings and retrofits regarding energy efficiency measures to the building shell and the HVAC systems.

In the second part of the impact assessment, the effects of an **uptake of smart ready technologies** and the SRI are modelled. The analysis is done in three different packages, dependent on whether a building has heating systems, cooling systems or both in place. This assessment has given only preliminary results and will be completed in the final stage of the study.

In the impact assessment a sensitivity analysis will be performed to (i) understand the influence of different relevant parameters, which is necessary to detect the most critical ones and (ii) get an impression of the uncertainties of the results of the previously determined scenarios. This work is ongoing and not yet covered by the second progress report.

First conclusions of the impact assessment suggest that the impacts of the uptake of smart ready technologies can be significant. Total effects of thermal energy savings by 2050 can be found in the range of 153 TWh per year, which is approximately 10% of the final energy demand for heating in 2050. Demand-side management in buildings (commercial and residential) could also be significantly enhanced, with a load-shifting potential of about 150 GW by 2030 and eventually even more by 2050. Heat pumps in buildings alone could account for 60 GW by 2050. If the 60 GW load shifting capacity would be used for an average of 1h per day, this would produce approx. 22 TWh of energy shifted in 2050.

NEXT STEPS

The second progress report is made available to stakeholders mid-June with the possibility to provide written comments to the study team by the end of June. This will lead to the final report of this technical study, to be delivered end of August 2018.

The policy making process towards the establishment of the SRI will be undertaken by the European Commission and will formally start when the revised EPBD enters into force. The revised EPBD requires the establishment of two legal acts: a delegated act for the definition and calculation methodology of the SRI and an implementing act for detailing the technical modalities for the effective implementation of the SRI scheme. Both legal acts shall be adopted by 31 December 2019.

CHAPTER 2 SCOPE AND OBJECTIVES OF STUDY AND SECOND PROGRESS REPORT

2.1. BACKGROUND

At the end of November 2016, the European Commission (EC) presented the “Clean Energy for All Europeans” package of proposals (EC, 2016) to amend and adapt several key directives in the field of energy efficiency, renewable energy, electricity market design, security of electricity supply and energy governance. In the scope of this package, buildings are treated as an essential driver of the energy transition. Buildings consume 40% of European Union (EU)’s final energy. Around 75% of the current EU housing stock is considered to be energy inefficient; annual renovation rates are low (0,4-1,2%) and the renovation depth is generally considered too shallow. There is a clear need to accelerate and finance building renovation investments and leverage smart, energy-efficient technologies.

One of the focus points of the proposal for amending the Energy Performance of Buildings Directive (EPBD) is to better tap the potential of Smart Ready Technologies (SRT). A greater uptake of smart technologies is expected to lead to significant energy savings in a cost-effective way, meanwhile it improves the comfort in the buildings and has the building adjusted to the needs of the user. Additionally, smart buildings have been identified and acknowledged as the key enablers of the future energy systems, in which there will be larger share of renewables, distributed supply and energy flexibility which is also managed on the demand side (e-mobility infrastructure, on-site electricity generation, energy storage). (EC, 2016)

The revised EPBD was approved by the European Parliament on 17 April 2018 and by the Council on 14 May 2018. While the current EPBD already considers Information and Communication Technologies (ICT) and smart systems to some extent⁴, the revised EPBD aims to provide additional support by:

- introducing Building Automation and Control Systems (BACS) as an alternative to physical inspections;
- reinforcing building automation by introducing additional requirements on room temperature level controls, building automation and controls and enhanced consideration of typical operating conditions;
- using building codes to support the roll-out of the recharging infrastructure for e-mobility;
- introducing a ‘Smart Readiness Indicator (SRI) for Buildings’ to assess the technological readiness of buildings to interact with their occupants and the energy environment and, to operate more efficiently.

Introducing such a SRI would raise awareness on the benefits of smarter building technologies and functionalities and their added value for building users, energy consumers and energy grids. It can support technology innovation in the building sector and become an incentive for the integration of cutting edge smart technologies into buildings. The SRI is expected to become a cost-effective

⁴ (1) the support to the introduction of intelligent metering systems and active control systems that aim to save energy, in line with Article 8; and (2) the possibility to use electronic monitoring and control systems as a partial replacement to inspections of heating and air conditioning systems, in line with Articles 14 and 15.

41 measure which can effectively assist in creating more healthy and comfortable buildings with a lower
 42 energy use and carbon impact, and can facilitate the integration of Renewable Energy Sources (RES).


43 **2.2. OBJECTIVES OF THE STUDY**

44 This study is intended to provide technical support to the Directorate-General for Energy of the
 45 European Commission services in order to feed the discussions on the definition and provision of a
 46 smart readiness indicator for buildings. Such indicator was originally proposed in the Clean Energy
 47 for All Europeans package of proposals (EC, 2016). Parallel to this technical study a policy process has
 48 taken place, which led to the approval of the revised EPBD. The new provisions of the amended EPBD
 49 indeed require the establishment of an optional European Smart Readiness Indicator (SRI) scheme
 50 for buildings.

51
 52 This study provides technical support, and in particular focusses on proposing methods to define a
 53 smart readiness indicator and the definition of smart services such indicator can build upon. This
 54 work is carried out in close consultation with stakeholders. It is supplemented by an impact analysis
 55 to evaluate the expected impact of the proposed indicator at EU scale. This technical support study
 56 will finalise in August 2018.

57
 58 The main objective of this study is thus to provides technical support to prepare the ground for the
 59 further establishment of the SRI. The revised EPBD stipulates that legal establishment will be done
 60 through two distinct legal acts. A delegated act will focus on the definition and calculation
 61 methodology of the SRI. An implementing act will specify the technical modalities of implementation.
 62 Both legal acts are due by December 31st, 2019.

63



64

65

Figure 2- Overview of the project structure

66

67 2.3. THIS SECOND PROGRESS REPORT

68 This document covers the progress of the study 'Support for setting up a Smart Readiness Indicator
69 for buildings and related impact assessment'.

70 The intermediate results of the four main tasks of the project are described in this second progress
71 report. This report is supplemented by a short summary which also lists the most important changes
72 compared to the interim report delivered in December 2017.

73

74 The objective of **Task 1** is to identify and characterise the Smart Ready Technologies together with
75 the smart ready services and functionalities that these technologies can provide to a building and its
76 occupants. Under this task, suitable technologies are listed which fit the definition of smart-ready
77 technologies that can be integrated into buildings and technical building systems to improve their
78 operations and enhance energy efficiency.

79

80 A spreadsheet (Annex A), which is integral part of the Task 1 deliverables, presents the catalogue of
81 smart ready services. It is structured in various tab sheets reflecting the distinct domains, and lists
82 the smart ready services, their functionality levels and their impacts. This catalogue was updated to
83 reflect feedback from the first two stakeholder workshops and subsequent stakeholder
84 consultations.

85

86 **Task 2** has taken the input from Task 1 deliverables and proposes methodological approaches to the
87 calculation of the SRI. A streamlined SRI methodology is proposed that uses a consolidated set of
88 services which are actionable now and are have reasonable confidence in their ability to be assessed
89 and their attribution of impacts to functional levels. This report describes the development of such
90 methodology and contains many updates based on growing insights and stakeholder feedback.

91

92 A stakeholder consultation process is ongoing as part of the dedicated **Task 3**. As part of these efforts
93 a public website has been launched, and three stakeholder meetings have been organised. A first
94 stakeholder meeting has been organised in June 2017, a second meeting in December 2017 and a
95 third on May 28th 2018. After each stakeholder meeting, stakeholders were invited to give feedback
96 to the reports and accompanying annexes⁵. This second progress report is distributed for public
97 consultation in follow-up of the third stakeholder meeting. The progress in task 3 is reported in
98 CHAPTER 5 of this document.

99

100 **Task 4** presents an **EU impact assessment of the SRI**. It is based on the description of smart ready
101 services from task 1 and the methodology to calculate the SRI in task 2. The core objective is the
102 calculation of benefits from and costs for the uptake of smart ready services (direct effect) and the
103 implementation of the SRI (indirect effect). This analysis relies on a baseline projected evolution of
104 the building stock (building sector pathway) in order to determine the additional saving potential
105 from smart ready technologies on top of that baseline.

106

⁵ Consultation documents are available on <https://smartreadinessindicator.eu/milestones-and-documents>

107 **CHAPTER 3 TASK 1 – SRT CHARACTERIZATION, MARKET ANALYSIS AND**
108 **INDUSTRIAL CAPACITIES EVOLUTION IN EU**

109 In this chapter, definitions are presented which provide both the scope and terminology for the
110 project. Next, the structure of the services catalogue is presented. The concepts of domains, impacts
111 and functionality levels of services are elaborated. Then the assumptions taken for the estimation
112 of the impacts of smart ready services, in particular in relation to standards, are discussed.

113 **3.1. TERMINOLOGY AND GLOSSARY**

114 The full glossary defined in Task 1 can be found in Annex B of this document. The most important
115 definitions are :

116 **Definition of ‘Smartness’**

117 In relation to buildings, no universally accepted definition of ‘smartness’ or ‘intelligence’ is currently
118 available. Many authors and organisations have proposed their - sometimes conflicting - definitions
119 of smart buildings (Amirhosein et al., 2016). While it could be argued that the outcome of this project
120 could lead to a definition stating *‘a smart (ready) building is a building with a high SRI score’*, this
121 does not evade the need for defining smartness in the first place.
122
123

124 In this work, the following definition will be proposed:

125
126
127 *“Smartness of a building refers to the ability of a building or its systems to sense, interpret,*
128 *communicate and actively respond in an efficient manner to changing conditions in relation the*
129 *operation of technical building systems or the external environment (including energy grids) and to*
130 *demands from building occupants,”*
131

132 On top of this definition, it is useful to refer to the three key ‘smartness’ functionalities given in the
133 Annex 1a of the revised EPBD (see discussion on scope, section 3.2.1).
134

135
136 **Definition of ‘Smart Ready Service’**

137
138 ‘Smart ready services’ satisfy a need from the user (occupant/owner) of a building or the energy grid
139 it is connected to.

140

141 Services are enabled by (a combination of) smart ready technologies, but are defined in a technology
142 neutral way, e.g. *'provide temperature control in a room'*. Many of the services listed in the catalogue
143 are based on international technical standards, for example BACS control functions (EN 15232-
144 1:2017), lighting control systems (EN 15193-1:2017) and Smart Grid Use cases (IEC 62559-2:2015).

145

146 The term "ready" indicates that the option to take action exists, but is not necessarily realized, e.g.
147 due to cost constraints, legal or market restrictions, or occupant preferences. However, the
148 equipment needed to implement the service has to be present in the building.

149

150

151 **Definition of 'Smart Ready Technologies'**

152

153 Smart Ready Services are delivered to the building user or the energy grid through the use of Smart
154 Ready Technologies. These smart ready technologies can either be digital ICT technology (e.g.
155 communication protocols or optimization algorithms) or physical products (e.g. ventilation system
156 with CO₂ sensor, cabling for bus systems) or combinations thereof (e.g. smart thermostats).

157

158 The smart ready technologies referenced in this study are considered to be active components which
159 could potentially:

160

- 161 • raise energy efficiency and comfort by increasing the level of controllability of the technical
162 building systems – either by the occupant or a building manager or via a fully automated
163 building control system;

163

- 164 • facilitate the energy management and maintenance of the building including via automated
165 fault detection;

165

- 166 • automate the reporting of the energy performance of buildings and their TBS (automated
167 and real time inspections);

167

- 168 • use advanced methods such as data analytics, self-learning control systems and model
169 predictive control to optimise building operations;

169

- 170 • enable buildings including their TBS, appliances, storage systems and energy generators, to
171 become active operators in a demand response setting.

171

172

173 **Definition of 'Technical Building System'**

174

175 In the EPBD under Article 2(3), a 'technical building system' is defined as a technical equipment for
176 the heating, cooling, ventilation, hot water, and lighting or for a combination thereof, of a building
177 or building unit. In the amended EPBD, this definition is extended to building automation and control
178 and on-site electricity generation. In the context of this study, this broader definition will be used.

179

180 **Definition of 'Interoperability'**

181

182 According to ISO/IEC 2382-01 on Information Technology Vocabulary, Fundamental Terms,
183 interoperability is defined as follows: "The capability to communicate, execute programs, or transfer
184 data among various functional units in a manner that requires the user to have little or no knowledge
185 of the unique characteristics of those units".

186 **Definition of ‘Cybersecurity’**

187 ‘Cyberspace security’ is defined as preservation of confidentiality, integrity and availability of
 188 information in the Cyberspace wherein Cyberspace means the Cyberspace the complex environment
 189 resulting from the interaction of people, software and services on the Internet by means of
 190 technology devices and networks connected to it, which does not exist in any physical form. The
 191 relevant standard is ISO/IEC 27032 - Information technology -- Security techniques -- Guidelines for
 192 cybersecurity.

193 **3.2. COMPILING THE SMART READY SERVICES CATALOGUE**

194 One of the main objectives of Task 1 was to compile the full list (or catalogue) of smart ready services
 195 that can be found in buildings and that could be considered in the calculation of the SRI. This section
 196 presents the scope and structure of this catalogue.

197 **3.2.1. SCOPE AND SELECTION CRITERIA**

198 Three key functionalities of smartness in buildings have been taken into account when selecting the
 199 smart services for the catalogue:

200
 201 **The ability to maintain energy efficiency performance and operation of the building**
 202 **through the adaptation of energy consumption for example through use of energy from**
 203 **renewable sources**

204 And/or

205 **The ability to adapt its operation mode in response to the needs of the occupant paying**
 206 **due attention to the availability of user-friendliness, maintaining healthy indoor climate**
 207 **conditions and ability to report on energy use**

208 And/or

209 **The flexibility of a building's overall electricity demand, including its ability to enable**
 210 **participation in active and passive as well as implicit and explicit demand-response, in**
 211 **relation to the grid, for example through flexibility and load shifting capacities.**

212
 213 These three functionalities are in line with the Annex Ia of the revised EPBD.


214
 215 In the process of compiling the catalogue, the following considerations have been taken into
 216 account:

- 217 • Services must be in the scope set by the terms of reference for this study and Annex Ia of the
 218 revised EPBD;
- 219 • Services must be described in a technology-neutral way;
- 220 • Services can have multiple impacts, e.g. on comfort, energy efficiency and user information;
- 221 • Services can be offered in multiple ways, with different levels of smartness;
- 222 • Some services might be mutually exclusive or conversely be mutually dependent (e.g. a
 223 service that requires smart metering to operate properly);
- 224 • The definition of a service must be unambiguous;
- 225 • The on-site assessment of services shall not require in-depth expertise or excessive inspection
 226 time;
- 227 • If services are already partially or completely defined in international technical standards, the
 228 catalogue shall align with these standards when possible;
- 229 • The service catalogue shall consider established and broadly marketed technologies and,
 230 where possible, emergent technologies;

- 231 • In order to limit the time spent on the assessment of services on-site, focus must be given to
232 smart ready services with the highest expected impacts.

233 3.2.2. STRUCTURE OF THE SMART READY SERVICES CATALOGUE

234
235



236

237 *Figure 3 – Illustration of the structure of the SRI smart ready services catalogue*

238 The SRI service catalogue is structured as shown in Figure 3. Each service belongs to a given domain
239 (e.g. ‘heating’) and can be provided with different functionality levels (the higher the level, the better
240 the smartness). Services and functionality levels are then mapped to impact scores, which express
241 their impact along the the areas of interest (e.g. impact on comfort). More details are given in the
242 following paragraphs.

243 Domains

244 In the SRI service catalogue, services are structured along 11 domains⁶: Heating, Cooling, Domestic
245 Hot Water, Controlled Ventilation, Lighting, Dynamic Building Envelope, On-site Renewable Energy
246 Generation, Demand Side Management, Electric Vehicle Charging, Monitoring and Control, and
247 Various.

248 Smart Ready Services

249 The full catalogue currently lists 112 Smart Ready Services.
250 The reader is referred to Annex A of this document and the accompanying Excel spreadsheet for the
251 full catalogue of services⁷. Figure 2 provides an excerpt of this catalogue, which illustrates the
252 structure of the catalogue.

⁶ Occupant comfort and health are currently not treated as service domains in the context of this study, but are considered in the impacts services can have.

⁷ In comparison to previous versions of the catalogue (such as presented in the interim report of December 2017), the concept of “sub-services” is no longer being used. The numbering of the services has not been altered, and thus still reflects that some of the smart ready services are closely related. For example: smart

253
254

255 **Functionality level**

256 For each of the services several functionality levels are defined. A higher functionality level generally
257 reflects a “smarter” service. The number of functionality levels varies from service to service, the
258 maximum level can be as low as 2 or as high as 5. The functionality levels are ordinal numbers,
259 implying that ranks cannot be compared in between distinct services.

260 **Impact criteria**

261 The services translate into different impacts for buildings, building users and the energy grid: for
262 example, enhancement of energy efficiency resulting from better control of TBS. One objective of
263 the study was to select the most relevant impact categories to consider, taking into account the
264 feedback from stakeholders. At this stage, the following eight impact categories are considered:

- 265 • **Energy savings on site:** refers to the impacts of services on energy saving capabilities. It is
266 not the energy performance of buildings that is considered, but only the contributions from
267 smart ready technologies, e.g. energy savings resulting from better control of room
268 temperature settings. Potential overlaps with some national implementations of the energy
269 performance certificates that reward BACS functionalities are discussed in section 4.8.1.
- 270 • **Flexibility for grid and storage:** refers to the impacts of services on the energy flexibility
271 potential of the building.
- 272 • **Self-generation:** refers to the impacts of services on the amount and share of renewable
273 energy generation by on-site assets and the control of self-consumption or storage of the
274 generated energy in order to provide more autonomy in terms of security-of-supply to the
275 building.
- 276 • **Comfort:** refers to the impacts of services on occupants comfort. Comfort refers to conscious
277 and unconscious perception of the physical environment, including thermal comfort,
278 acoustic comfort and visual performance (e.g. sufficient lighting levels without glare).
- 279 • **Convenience:** refers to the impacts of services on convenience for occupants, i.e. the extent
280 to which services “make the life easier” for the occupant, e.g. by requiring less manual
281 interactions to control the technical building system.
- 282 • **Well-being and health:** refers to the impacts of services on well-being and health of
283 occupants. It is identified as an important boundary condition for all services. On top of the
284 strict basic requirements, some services could also provide for a better indoor air quality,
285 thus improving occupants’ well-being, with possible impact on their health.
- 286 • **Maintenance and fault prediction, detection and diagnosis:** Automated fault detection and
287 diagnosis has the potential to significantly improve maintenance and operation of the TBS.
288 It also has potential impacts on the energy performance of TBS by detecting and diagnosing
289 inefficient operation.
- 290 • **Information to occupants:** this refers to the impacts of services on provision of information
291 on building operation to occupants.

292
293 These impact categories are important as services which have the highest impacts will also be those
294 considered as most priority in the calculation methodology.

ready services focusing on the demand side of heat control are numbered 1-a to 1-g, whereas those concerned with heat production are numbered 2-a to 2-e.

295

296 These categories are provisional and only reflect the assessment of the consortium at this stage of
297 the study. They can evolve (e.g. be simplified) in a later stage.

298

299 Some of the impact categories of smart-ready services can also be relevant to other policy
300 instruments and rating schemes. This is for example the case with energy savings and self-
301 generation, in relation to the EPBD. This is also true for wellbeing, health and comfort in relation to
302 building environmental assessment schemes such as Level(s)⁸, BREEAM⁹, HQE¹⁰, or DGNB¹¹. Section
303 4.8 of this report discusses linkages and potential overlaps between the SRI and other schemes in
304 more detail.

305

306

Boundary conditions and supporting technologies and services

307 Some smart ready services may depend on pre-conditions and / or boundary conditions and
308 supplementary services and technologies to be fully functional. Many of the smart services listed
309 require supporting technologies and services to reach a desired functionality level, e.g. higher
310 functionality levels of the services on heat generation or storage depend on other services (e.g. price
311 signal information) delivered by other technologies (e.g. smart meters). The prevalence of supporting
312 technologies such as the availability of broadband access or a smart metering device is not treated
313 as separate smart service. Nevertheless, these technologies can be essential assets for some of the
314 smart ready services. The supporting technologies are thus valued indirectly in the SRI when
315 evaluating the smart ready services which depend on them.

316

317 Apart from technical boundary condition for specific services, other boundary conditions might have
318 to be taken into account to prevent unintended side-effects of a greater uptake of smart
319 technologies. This is specifically true for services with a potential impact on health and wellbeing of
320 occupants, as well as thermal comfort. Recognising their important role, these potential impacts have
321 been taken into account in the development of the catalogue of services in two ways. Firstly, services
322 have been defined in such a way that higher functionality levels do not impede comfort, health and
323 well-being, but rather enhance these. Furthermore, both physical comfort and well-being and health
324 have been explicitly taken into account as impact factors in the proposed SRI method developed in
325 Task 2 of the project.

326

327 Other boundary conditions include aspects such as interoperability or data protection and cyber-
328 security. Interoperability is a prominent technical issue, translating into requirements for interfaces
329 between systems. Dataprotection (in terms of privacy and technical robustness) is of highest
330 importance for the occupant using the services. As regards cyber-security, the concept of security-
331 by-design is nowadays a widely-accepted approach. Noting that the scope of this study is limited to
332 the service level, and does not address the level of devices from individual vendors,, the issue of
333 security is dealt with from a general security standards perspective. Section 3.4 of this report
334 provides further information on these issues.

335

⁸ Level(s) is a voluntary reporting framework to improve the sustainability of buildings. Using existing standards, Level(s) provides a common EU approach to the assessment of environmental performance in the built environment.

<http://ec.europa.eu/environment/eussd/buildings.htm>

⁹ <https://www.breeam.com>

¹⁰ <http://www.behqe.com>

¹¹ <http://www.dgnb.de>

336

3.2.3. FORMAT OF THE SMART READY SERVICES CATALOGUE

337 The previous sections have given the theoretical and methodological foundations for Task 1
338 deliverables.

339

340 These deliverables (structured catalogue of smart ready services) are made available in the form of
341 an Excel spreadsheet (Annex A), which is the key output form Task 1. It includes the following
342 contents:

343

344 • In the spreadsheet file, the initial tab sheet covers the overall list of smart ready services as
345 given in the Annex C of this document. For the purpose of easy reading the domains have
346 been color-coded in the document. The structure of the tab sheet is in line with the structure
347 presented in section 2.2. The columns show:

348

- The domain of the service

349

- The service code (that uniquely identifies the service)

350

- The service group (e.g. controlling cooling demand)

351

- The smart ready service name

352

- Up to five functionality levels , which correspond to the different levels of smartness
of a service

353

354

- The standards from which the service was derived or to which the service is related
– if applicable

355

356

- An indication on whether the service is currently actionable

357

- An indication on whether the service is considered in the proposed SRI methodology
presented in CHAPTER 4

358

359

- Preconditions to the assessment of a service, e.g. dependency on other services or
building types (see more information on the triage process are in CHAPTER 4)

360

361

- In the additional tab sheets of the spreadsheet file, one tab sheet for each of the
362 classifications domains from section 2.2 is given. For each of the services, the following
363 information is displayed¹²:

364

- The functionality levels of the service, ranging from level 0 up to level 4, depending
on the service

365

366

- The impacts of each of the functionality levels of the service, on a scale ranging from
---,--, -, 0, +, ++ to +++ for each the impact category.

367

368

- The market uptake for both residential as well as commercial buildings

369

370

- An estimation of the on-site inspection time needed to assess the service for each
functionality level

371

372

- Preconditions on other services (i.e. which other services are needed for the service
to be made available)

373

374

- Information sources / references used for the estimation of the impacts of the
service, market uptake and inspection time

375

376

- Relevant standards (e.g. for the assessment or the service)

377

378

379

380 The version of the catalogue provided with this report includes eleven domains, which cover 112
381 smart ready services. For each of those services, up to 5 functionality levels were assessed, with an
average of 3 levels. For each level, 8 different impacts were assessed, two estimates of market
uptake as well as the inspection time.

¹² The impacts, inspection time and market uptake were estimated by the project team based on expert assessment, relevant standards and stakeholder feedback. These estimations are provisional and should be considered as a discussion basis that will have to be further substantiated or better quantified in later phases.

382 The reader should be aware that this catalogue is the result of a thorough assessment of smart
 383 services but does not reflect the actual number of services used to calculate the indicator. The later
 384 is much lower (see CHAPTER 4).

385
 386 The next section gives more details on each domain of the catalogue.
 387

388 **3.3. SELECTION AND ASSESSMENT OF THE SERVICES**

389 **3.3.1. SMART READY SERVICES DOMAINS**

390 The study team identified the smart ready services based on a number of sources, including technical
 391 standards, policy and industry roadmaps and market analysis studies. The catalogue was further
 392 consolidated based on the feedback received from stakeholders.

393 This section summarizes the scope and contents of the smart ready services domains and related
 394 references. The reader is invited to refer to Annex A for a complete list and detailed description of
 395 smart ready services .

396

397

398

399 **Heating**

400 About 40% of EU's final energy is consumed in buildings, and space heating takes the largest
 401 share herein. Across EU 28, the total residential and service sector building heat market
 402 constitute an energy volume of approximately 13.1 EJ (STRATEGO, 2014-2016).

403

404 The reduction of the heating energy consumption and transition to renewable energy sources
 405 are important policy targets. Better design of buildings (increased insulation, optimal choice of
 406 glazing characteristics, proper use of the thermal capacity of the building structure, etc.) can
 407 reduce the heating need, while more efficient HVAC installations and renewable heat sources
 408 will reduce the environmental impact and primary energy demand for fulfilling this heat demand.
 409

410

411 In the SRI Service catalogue, the "heating" domain lists smart services which enhance the
 412 operation of the heating systems (storage, generation, distribution and emission of heat).

413 These services are mainly related to the automation of the control of technical building systems
 414 for space heating, in accordance with technical standard EN 15232 and with some adaptations:

414 • Where relevant, simplification and aggregation of some services in order to ensure
 415 practical applicability and cost-effectiveness of the SRI.

416 • Where relevant, inclusion of additional services or functionality levels. For example
 417 service "Heating 2-b, Heat generator control for heat pumps", features an additional
 418 functionality level 3¹³ which is not present in the EN 15232 standard. .
 419

420

421 As standard EN 15232 does not quantify the energy efficiency gains resulting from heating
 422 system automation and control, and as these gains can depend on many factors such as building
 423 use, location, characteristics of the envelope, etc., the impacts given for this domain are only
 424 first order estimates which may need to be elaborated in follow-up work, e.g. by the inclusion of
 425 quantified scoring (see discussion in 4.6.1).

¹³ controlling the heat generator capacity based on external signals from a smart electricity grid.

426

427 Domestic hot water

428 The domain of domestic hot water includes services dealing with the smarter control of
429 generating, storing and distributing potable hot water in a building.

430

431 Especially in well-insulated residential buildings, provision of domestic hot water can represent
432 an important share of the overall energy demand of a building. Similarly to the heating domain,
433 technical standard EN 15232 has been used as the main source in defining these services.

434

435

436 Cooling

437 This domain focuses on thermal storage, emission control systems, generators and energy
438 consumption for space cooling.

439

440 The relative share of cooling energy consumption in the energy demand of a building will depend
441 on climate and building usage, alongside the technical and geometrical properties of the building
442 envelope, its technical installations and shading devices and the occupant behavior. Especially in
443 Southern climates and specific typologies such as highly glazed office buildings, cooling can
444 represent an important share of the overall energy demand of a building. Similarly to the heating
445 domain, technical standard EN 15232 has been used as the main source in defining these
446 services.

447

448 Controlled ventilation

449 This domain covers services for air flow control and indoor temperature control.

450 The ventilation rate and temperature control are important drivers for the energy demand of a
451 building, and are equally important in relation to human health and thermal comfort. Smart
452 controls can balance the contrasting demands, e.g. by regulating ventilation flow rates based on
453 real-time measurement of indoor air quality parameters such as CO₂ concentrations. Similarly to
454 the heating domain, technical standard EN 15232 has been used as the main source in defining
455 these services¹⁴.

456

457 While many of the services in technical standard EN 15232 are originally proposed for mechanical
458 ventilation systems (and to a large extent also limited to non-residential buildings), they can also
459 be applicable to residential systems and hybrid ventilation systems.

460

461 Lighting

462 This domain focuses on electric lighting managed/controlled by a lighting system based on, for
463 instance, time, daylight, and occupancy.

¹⁴ The 'mechanical ventilation' section of EN15232 has been revised in the 2017 edition and these changes led to the rephrasing on some of the services in this domain compared to the previous interim report.

464 Services for this domain are based on the initial CEN/CENELEC Smart House Roadmap¹⁵ and
465 extended by, e.g. the Ambient Assisted Living Roadmap of the German¹⁶ DKE. The market data
466 and analysis from the PPP Photonics 21¹⁷ was also taken into account.
467 Market uptake was assessed based on the structural analysis from the Gartner reports on Smart
468 Lighting in the context of Smart Cities and smart home¹⁸.

469

470 **Dynamic building envelope**

471 This domain focuses on the control of openings and sun shading systems. Commercially available
472 energy management systems often focus on optimized control of lighting and HVAC systems.
473 However, smarter operation of ‘passive’ building features such as operable shading and opening
474 of windows can reduce the need for heating and/or cooling altogether and can have other
475 impacts, such as on occupant thermal and visual comfort. They are therefore relevant to the SRI.

476

477 The service on shading control is based on standard EN 15232, but expanded to include other
478 types of shading. The services dealing with window opening control and window spectral
479 properties are currently not mapped with international technical standards.

480

481 **(Local) Energy generation**

482 This domain includes services that monitor, forecast and optimize the operation of decentralized
483 power generation and control the storage or delivery of energy to the connected grid. Some of
484 the services which relate to local energy generation have been subject to standardization efforts,
485 specifically those within the 2010 IEC Smart Grid Standardization Roadmap (IEC, 2010). Many of
486 these standards focus however mainly on the grid perspective and communication protocols.
487 From a practical perspective, these aspects are difficult to assess on site. Furthermore, some of
488 these features are assessed in the dedicated ‘demand side management’ domain of SRI.
489 Therefore, the study team has suggested more aggregated services for the ‘local energy
490 generation’ domain.

491

492

493 **Demand side management**

494 This domain focuses on the control of energy demand in response to implicit or explicit signals
495 from the grid (i.e. energy flexibility). The scope includes both explicit and implicit demand-
496 response and both local smart grids (e.g. on a campus or urban level) and (supra)national grid.
497 Furthermore, most of the services presented can apply to any type of energy grids, for example
498 also district heating and cooling grids.

499

500 The definition of the series of this domain is based on both the IEC SMB Smart Grid
501 Standardization Roadmap and consolidated information from the Preparatory Study on Smart
502 Appliances¹⁹ led in the scope of Ecodesign and energy labelling regulations. Some further
503 adaptations were made; in particular streamlining and aggregation of some services, which can
504 be difficult to assess on site or could require too much information.

¹⁵ CEN/CENELEC, Smart House Roadmap 2010

¹⁶ DKE, German Standardization Roadmap AAL (Ambient Assisted Living) 2014

¹⁷ PPP, Photonics 21 Initiative

¹⁸ Gartner, Hype Cycle for the Internet of Things, Hype Cycle for the Connected Home, Hype Cycle for Smart City Technologies and Solutions

¹⁹ <http://www.eco-smartappliances.eu>

505
 506 The DSM domain overlaps to some extent the EV (Electric Vehicle) domain as EVs can provide
 507 storage and flexibility services for the electric grid.
 508

509 **Electric vehicle charging**

510 This domain covers technical services provided by buildings to electric vehicles (EV) through
 511 recharging points, e.g. for electric consumption management and storage capabilities. In
 512 addition to the pure EV functionality, the electric storage from the EV can provide flexibility to
 513 the building and energy grid if properly controlled. Some of these services are derived from the
 514 IEC SG Standardization Roadmap which takes into account the results from the M/468
 515 mandate²⁰. Standards such as IEC 15118²¹ provided information towards the definition of EV
 516 services in the SRI catalogue. This was supplemented by a few services which provide a more
 517 aggregated description of the EV charging capabilities.
 518

519 **Monitoring and control**

520 This domain focuses on sensor data which can be provided by TBS in buildings and can be used
 521 by other services, and/or be combined into one overarching system such as a Home Energy
 522 Management System (HEMS). This for example includes occupancy detection functionalities,
 523 which can be used by multiple TBS such as heating, ventilation and lighting systems.
 524

525 For ease of assessment, it was decided to structure services dealing with monitoring and control
 526 of one single domain under this respective domain of the catalogue. For example the service
 527 “*Report information regarding HEATING system performance*” is listed in the “heating” domain.
 528 Central reporting of all energy use per energy carrier (e.g. all gas use) is however part of the
 529 monitoring and control domain.
 530

531 **Various**

532 During the course of Task 1 and based on suggestions by stakeholders, other smart ready services
 533 have been identified, which are not directly linked to any of the other domains and the scope set
 534 in the terms of reference of this study and Annex 1a of the revised EPBD. This for example
 535 includes services only focussing on security or health without any relation to technical building
 536 systems in the scope of the EPBD, such as services providing personal health monitoring of
 537 occupants or telemedicine services.

538 These suggested services are not part of the proposed SRI calculation methodology developed
 539 in Task 2 of this study. Nevertheless, these services are listed in the “Various” domain to serve
 540 as a reference and some of them might be considered for potential uptake if the scope of SRI
 541 would broaden up in future iterations of the indicator. For the services listed in the ‘various’
 542 domain, no provisional impact scores have been defined.
 543

²⁰ <http://ec.europa.eu/growth/tools-databases/mandates/index.cfm?fuseaction=search.detail&id=450>

²¹ Communication between Electric Vehicles (EV), including Battery Electric Vehicles and Plug-In Hybrid Electric Vehicles, and the Electric Vehicle Supply Equipment

544 3.3.2. PROVISIONAL IMPACT OF THE VARIOUS SERVICES

545 Impacts of smart ready services (and related functionality levels) are expressed on a seven-level
546 ordinal scale: ---, --, -, 0, +, ++, +++. While most of the impacts are positive, the scale also provides
547 the opportunity to ascribe negative impacts. Some services can result in benefits for several impact
548 categories (e.g. energy flexibility) but negatively affect others (e.g. convenience or comfort of
549 occupants might be slightly adversely affected by DSM).

550
551 The provisional impacts are based on expert assessment and, where possible, on applicable
552 standards. At this stage, the impacts are not quantified and are used to support the development of
553 the methodology in Task 2. Stakeholders are invited to provide feedback to fine-tune the provisional
554 impacts.

555 For each service, the market uptake has also been provisionally assessed for each functionality level.
556 based on market analysis studies. The domains cover a broad variety of systems and technologies,
557 some related to emerging technologies, some to connected home, some in to smart city
558 technologies. The latest versions of the Gartner Hype Cycles 2017²² has been the primary source for
559 assessing the maturity of the services and functionality levels.

560
561 This catalogue is intended to support the development of the SRI methodology. Throughout the
562 project it has evolved in an iterative way based on stakeholder inputs and growing insights. A
563 transparent framework will have to be defined and set up to support and frame the evolution of the
564 SRI once it is established. This framework should in particular clarify the procedure to add or remove
565 services and functionality levels, and to update impact scores.

566

567 3.3.3. UPDATING THE SMART SERVICE CATALOGUE

568 The catalogue of smart ready services has been developed in an iterative way throughout this study.
569 It is expected that further updates will still be needed and that an iterative process of reviewing
570 and updating the catalogue will have to be set in place once the SRI is established. The need for
571 further updates originates from the following factors:

- 572 • Many of the services are based on international standards. This increases the credibility and
573 ease of assessment, but might in some cases also hamper innovation since the development
574 and update of standards is often a lengthy and intricate process. It might be needed to review
575 the services and update or add the higher functionality levels to better take into account
576 technological progress and innovation.
- 577 • All impacts in the catalogue are currently highly provisional and need to be further
578 substantiated. Some of these impacts can also evolve over time. Furthermore, some of the
579 impacts could vary according to climatic zones, buildings types, etc.;
- 580 • The list of services considered in the streamlined SRI methodology (see Task 2) could evolve
581 due to changes in the scope of the SRI, advances in inspection methods and protocols,
582 feedback from consumer tests, etc.;
- 583 • Feedback from field tests of the SRI in actual buildings could result in adaptations of the
584 catalogue;;
- 585 • Progress on inspection / assessment methods (such as the use of digital models of buildings,
586 self-reporting from TBS, emergence of product-specific certification labels, etc.) could reduce

²² Gartner, Hype Cycle for the Internet of Things, Hype Cycle for the Connected Home, Hype Cycle for Smart City Technologies and Solutions, 2017

587 the time and efforts needed for SRI assessment. This can shift the cost-benefit balance of the
588 inspections, and generate the opportunity to consider more services in the future.

589
590 A robust process should be set up to regularly revise and update the smart services catalogue in close
591 collaboration with all relevant stakeholders. This also implies agreeing on procedures and quality
592 checks for updating impact scores; and potentially also extends to the development of agreed
593 inspection protocols. In this process, care must be given to maintain a proper balance of assessment
594 efforts versus impact of services to be included in the SRI, as well as the need for maintaining a
595 reasonable balance amongst services and domains. A priori, such a process would preferably be
596 organised at a European level to maintain a uniform approach and prevent market barriers.
597

598 **3.4. DATA PROTECTION, CYBERSECURITY, INTEROPERABILITY AND STANDARDISATION**

599 This section briefly introduces how the SRI links to data protection, cybersecurity, interoperability
600 and related standardisation. Possible links to other building labelling and certification schemes are
601 further discussed in section 4.8 of this report.
602

603 **3.4.1. DATA PROTECTION**

604 After four years of preparation, the EU General Data Protection Regulation (GDPR) was approved by
605 the EU Parliament on 14 April 2016. The actual enforcement date will be 25 May 2018, at that time
606 those organizations in non-compliance may already face fines by the EC for not fulfilling the new
607 requirements. The GDPR replaces the previous Data Protection Directive 95/46/EC and is designed
608 to harmonize data privacy regulations across Europe, to protect and empower all EU citizens' data
609 privacy and to re-shape the way organizations across the EC approach data privacy.
610

611 GDPR will apply to the processing of personal data by controllers and processors in the EU, regardless
612 of whether the processing takes place in the EU or not. The GDPR will also apply to the processing of
613 personal data of data subjects in the EU by a controller or processor NOT established in the EU, where
614 the activities relate to, e.g. offering goods or services to EU citizens (irrespective of whether payment
615 was required by the user) and the monitoring of behavior that takes place within the EU. Non-EU
616 businesses processing the data of EU citizens will also have to appoint a representative in the EU in
617 order to establish a link. Various data subjects must be adhered to according to the law:

- 618 • Breach Notifications
- 619 • Right to Access
- 620 • Data Erasure
- 621 • Data Portability
- 622 • Data Privacy by Design
- 623 • Data Protection Officers

624
625 Many of the smart services listed in the SRI catalogue have the potential to gather large amounts of
626 personalized data. Even seemingly banal data sets such as indoor temperatures, energy consumption
627 profiles or indoor air quality readings can potentially be put to wrong use to get insights in
628 individuals' living patterns, holiday regimes, etc. For system vendors (OEMs), integrators and (data)
629 aggregators of smart building services, it is thus crucially important to implement proper data
630 protection measures. The building owner or occupant should not undertake any action, since the

631 GDPR assigns the responsibility for data protection to the system operator who actually processes
632 and stores personal data.

633

634 In practice, it will not be feasible for an SRI assessor to have a full understanding of how data
635 gathered by sensors in a building will be handled and how data protection is ensured. After all, this
636 is mainly a matter of software and servers on a remote location. Furthermore, data privacy by design
637 will be a prerequisite for all smart services on the EU market as of 25 May 2018 onwards. The
638 approach taken therefore, is the assumption that all smart ready services present in a building are
639 GDPR compliant and hence there is no need for a further detailed assessment of data protection of
640 the smart services and technologies present in a particular building.

641 **3.4.2. CYBER SECURITY IN THE CONTEXT OF THE SRI INDICATOR**

642 Digital technologies are the backbone of smart ready services in buildings. They might also bring
643 about new risks related to data theft, frauds and system hacking. Ensuring cybersecurity is therefore
644 a key issue to foster trust in digital technologies.

645

646 The European Commission has adopted a series of measures to raise Europe's preparedness to ward
647 off cyber incidents. Securing network and information systems in the European Union is an essential
648 aspect of EU's Digital Agenda. The NIS (Network and Information Security) Directive on security of
649 network and information systems was adopted by the European Parliament on 6th of July 2016 and
650 entered into force in August 2016. Member States will have 21 months to transpose the Directive
651 into their national laws, as well as 6 months more to identify operators of essential services.

652

653 In 2004 the EU set up ENISA²³. The European Union Agency for Network and Information Security.
654 ENISA works closely together with Members States and private sector in facing network and
655 information security challenges, as well as delivering advice and solutions on cyber-security.

656

657 On 13 September 2017 the Commission issued a proposal for a cybersecurity package²⁴. The package
658 builds upon existing instruments and presents new initiatives to further improve EU cyber resilience
659 and response. This includes the establishment of an EU cybersecurity certification framework that
660 will ensure the trustworthiness of billion connected devices in diverse sectors such as telecom,
661 energy and transport networks, and new consumer devices, such as connected cars, smart buildings,
662 and many others.

663

664 The proposed certification framework will provide EU-wide certification schemes as a
665 comprehensive set of rules, technical requirements, standards and procedures²⁵. This will be based
666 on agreement at EU level for the evaluation of the security properties of a specific ICT-based product
667 or service.

668

669 Cybersecurity will be an important prerequisite for public trust and greater uptake of smart ready
670 technologies in the building sector. Preferably, the smart readiness indicator will align with the
671 forthcoming EU cybersecurity certification framework, without the need for supplementary
672 certification and assessment efforts. A straightforward solution could be the provision of an
673 additional 'cybersecurity' indicator or symbol on the SRI label, if (- a subset of most relevant -) smart
674 ready technologies present in the building adhere to the cybersecurity certification framework.

²³ <https://www.enisa.europa.eu/>

²⁴ https://ec.europa.eu/info/law/better-regulation/initiatives/com-2017-477_en


²⁵ <https://ec.europa.eu/digital-single-market/en/eu-cybersecurity-certification-framework>

675 Another potential solution to include this initiative in the SRI is the addition of extra service levels to
 676 already proposed services or the inclusion of new services dealing with cyber security. The current
 677 proposed methodology is flexible to deal with such expansions when the forthcoming EU
 678 cybersecurity certification framework becomes operational.

679 3.4.3. INTEROPERABILITY IN THE CONTEXT OF THE SRI INDICATOR

680 While systems and applications at buildings and utilities in the past were operated separately, today
 681 interactions between multiple systems and applications are increasingly important to operate
 682 buildings and energy systems more effectively and create more comfort, well-being and health to
 683 the occupants. To do so, coupling of former separated and heterogeneous technical systems is a
 684 prerequisite for a widespread adoption of smart services. To boost greater market uptake and
 685 prevent vendor-lock-in effects, this will also require connecting physical products and ICT systems
 686 from different vendors. The smart services will be invoked from systems of third parties, therefore,
 687 also latency, bandwidth²⁶ and other properties have to be taken into account. Future interoperability
 688 will need pre-conditions to a building like broadband connectivity²⁷.

689
 690



691

692 *Figure 4: Semantic integration distance for interoperability (source: Offis)*

693 Figure 4 illustrates the different forms of interoperability; the integration distances range from
 694 customized integrations to plug-and-automate integration. This requires solutions to integrate those
 695 systems in a way their functionality is still available and can be adapted to changing needs. This figure
 696 mainly motivates why technical interfaces in the scope of the SRI shall be standardized in order to
 697 achieve a high interoperability, lower integration costs and better operational performance.

698

²⁶ E.g. the call for a voluntary broadband-ready label for buildings, <https://ec.europa.eu/digital-single-market/en/building-infrastructure>

²⁷ Directive 2014/61/EU

699 In the domain of smart appliances, the European Commission has boosted the development of a
 700 common ontology, called SAREF (Smart Appliance Reference) and a standard based on it developed
 701 by ETSI²⁸. These allow matching appliances and systems from different manufacturers, exchanging
 702 energy related information and interacting with any other Building Energy Management System.
 703 Extensions to the SAREF ontology for smart machine-to-machine communication provide
 704 specifications for the energy domain²⁹ and the building domain³⁰. Within the Ecodesign framework
 705 of the European Commission, further focus has been given to interoperability in the product and
 706 service design of smart appliances³¹ and BACS³².

707

708 While such common framework is in place for some specific technologies such as smart appliances,
 709 this is not the case for all domains and technologies. Furthermore, these technical specifications are
 710 not applicable to legacy equipment.

711

712 Whilst interoperability is acknowledged as a very important concern in relation to the SRI, an explicit
 713 evaluation of the interoperability of all equipment in a building would difficult as it requires some
 714 information that is often not readily available to an assessor, especially in case of legacy equipment.
 715 Furthermore, such assessment would need to be performed for many of the TBS present in a
 716 building, requiring large amounts of time and efforts which would have important repercussions on
 717 the cost of an SRI assessment. Annex C of this report provides more discussion on this topic.

718

719 Within the current proposal for an SRI assessment scheme, a different approach has thus been
 720 favored. Instead of evaluating interoperability for each of the TBS separately, technology neutral
 721 services have been introduced in the SRI catalogue. Many of the services inherently require multiple
 722 sensors, actuators and controllers to be interoperable to collectively deliver the specific service. For
 723 example, a service such as “Building preheating control” requires temperature sensors, distribution
 724 pumps, heat generators, etc. to work together seamlessly to deliver the requested service.
 725 Furthermore, specific services have been included in the service catalogue to express how TBS in
 726 different domains can work together. Inherently, some level of interoperability will be required to
 727 make such services actionable. Examples include “Cooling 1-f: Interlock between heating and cooling
 728 control”, “DE-2: Window open/closed control, combined with HVAC system” and “Central reporting
 729 of TBS performance and energy use”.

730

731 If EU wide certification schemes or labels for indicating the interoperability of TBS emerge in the
 732 future, these could be introduced into the SRI methodology in future iterations (see further
 733 discussion in section 4.9.7).

734

3.4.4. STANDARDS IDENTIFIED AND COVERED FOR THE SERVICE CATALOGUE

735 Standards can contribute to the development of an SRI by assisting in identifying or quantifying
 736 functionalities and services in a fast and harmonized way.

737 The ‘smart ready services’ in this study were to a large extent sourced from standards. This is
 738 especially the case for many of the services sourced from EN 15232 ‘Energy performance of buildings
 739 - Impact of Building Automation, Controls and Building Management’ (module M10). This standard

²⁸ <http://www.etsi.org/technologies-clusters/technologies/smart-appliances>

²⁹ SmartM2M; Smart Appliances Extension to SAREF; Part 1: Energy Domain
http://www.etsi.org/deliver/etsi_ts/103400_103499/10341001/01.01.01_60/ts_10341001v010101p.pdf

³⁰ SmartM2M; Smart Appliances Extension to SAREF; Part 3: Building Domain
http://www.etsi.org/deliver/etsi_ts/103400_103499/10341003/01.01.01_60/ts_10341003v010101p.pdf

³¹ Ecodesign Preparatory Study on Smart Appliances (Lot 33) <http://www.eco-smartappliances.eu>

³² Ecodesign preparatory study for Building Automation and Control Systems (BACS) <http://ecodesignbacs.eu/>

740 is the overarching standard that models the impact of Building Automation and Controls Systems
741 (BACS) on the energy consumption of the building. It is used within EPBD and contains a structured
742 list of BACS and Technical Building Management (TBM) functions. Other examples include the
743 lighting control systems as defined in EN 15193-1:2017, Smart Grid Use cases from IEC 62559-2:2015,
744 etc. More general background information on relevant standards for smart ready services is reported
745 in Annex D.

746

747

748

749 **CHAPTER 4 TASK 2 - ROBUST METHODOLOGY FOR THE HARMONISED**
750 **CALCULATION AT EU LEVEL OF THE SRI FOR BUILDINGS**

751 This chapter of the interim report sets out the thinking behind the derivation of a generic
752 methodology that could be applied to the calculation of a smart readiness indicator. It takes into
753 account the comments received on the first draft report and includes a number of new sections as
754 detailed below.

755

756 Section 4.1 describes the factors that need to be considered in the derivation of an SRI. It includes a
757 new sub-section (4.1.1.18) on data protection.

758

759 Section 4.2 then sets out the development of a generic SRI methodology. It draws upon much wider
760 experience in the derivation of multi-criteria decision making methodologies and applies this to the
761 exposition of a generic SRI methodology. An illustration is then presented of how the generic
762 methodology can be applied to a theoretical building using the array of smart readiness elements
763 reported in the Task 1 catalogue. Note, this section has been updated to make use of the modified
764 Task 1 services which were amended in light of stakeholder comments.

765

766 Section 4.3 introduces the reality checks that would need to be taken into account to implement an
767 actual SRI and considers how these are likely to filter the smart readiness services that can be
768 operationalised. It addresses the practical aspects that affect the ability to implement an SRI and
769 includes a review of the maturity of the smart readiness elements reported in the Task 1 catalogue.
770 This section has been updated to make use of the modified Task 1 services which were amended in
771 light of stakeholder comments

772

773 Section 4.4 examines how the generic SRI based on the Task 1 catalogue can be streamlined to make
774 a practically applicable smart readiness indicator. It reviews the Task 1 catalogue of smart readiness
775 services and proposes some consolidation and restructuring. It then applies the proposed
776 streamlined approach to two cases studies – one for a single family home and one for an office
777 building. This section has been updated to make use of the modified Task 1 services which were
778 amended in light of stakeholder comments

779

780 Section 4.5 considers how the SRI methodology can be tailored to address locally specific context
781 and demonstrates its versatility and adaptability to different circumstances.

782

783 Section 4.6 is a new section that covers alternative methodological approaches including:

784

- Incorporating cardinal data assessment of impacts

785

- Using calculation software

786

- Using measured outcome based approaches

787

- Checklist based approaches

788

- Evolutionary hybrid approach

789

790 Section 4.7 (formerly section 3.6) addresses how the information in the SRI can be reported to the
791 various users.

792

793 Section 4.8 is a new section that addresses linkages with other schemes and in particular with EPCs,
794 Building renovation passports and the LEVELS scheme.

795
796 Section 4.9 is a new section that presents the findings from field trials of the streamlined SRI
797 methodology on actual buildings.
798
799 Section 4.10 (formerly section 3.8) presents the provisional conclusions of the work in Task 2.
800
801 Annex F presents a review of the maturity of the smart readiness elements catalogued in Task 1 for
802 use within an SRI methodology.
803
804 Annex G presents an actionable set of smart readiness elements drawn from the streamlined
805 methodology.

806 **4.1. FACTORS TO CONSIDER IN DERIVING AN SRI**

807 This paragraph discusses the issues and principles one would want to include in an SRI and
808 summarises how building smartness has been defined thus far in the project including the three main
809 elements of buildings smartness requested by the Commission.
810

811 The Task 1 work has highlighted the array of smart readiness aspects and features that can be
812 expressed in terms of the domains where they apply, the services and functions they offer. The
813 domains articulate a taxonomy of the systems within which these smart readiness (SR) services are
814 applied. For each of the services several “levels of functionality” are defined to differentiate between
815 levels of smartness capability for a given functionality offered to the building occupant, owner or the
816 grid. In addition, a set of eight higher-level impact criteria has been defined and the effect (expressed
817 in terms of an ordinal ranking system) which each level of functionality is expected to have on these
818 criteria has been estimated.
819

820 The prospective SRI methodology developed in this part of the report needs to take these inputs and
821 use them to derive an output (or outputs) that provides an indicator of how “smart” a building is. In
822 particular, it will (most likely) want to assess the effect these are expected to have on a set of
823 designated impacts (e.g. the eight impact criteria) and award smart-readiness scores based on that.
824

825 Alternatively, another potential methodological approach for the SRI would be not to weigh the
826 different impact scores, but rather structure the methodology along the different domains (e.g. 20%
827 of the overall indicator is based on the smartness aspects related to heating, 15% to lighting, etc.).
828 For the sake of clarity, only the approach based on weighting the impacts is further explored in this
829 document.
830

831 The methodology chosen has to allow the impacts to be assessed and scored; however, at this stage
832 of the indicator development process the policymaking community’s views on the most important
833 impacts and how they should be scored are unknown. Thus, the structure used in the methodology
834 has to be adaptable to allow the policymaking process to establish a collective position on the choice
835 of impacts to be addressed and their relative importance. In practice, it also needs to be developed
836 in such a manner that will help to inform the discussion and facilitate the decision making process.
837

838 As a precursor to the development of an SRI methodology it is important to consider the set of factors
839 that the SRI will need to address. These are now considered in turn.

840 **The audience for the SRI**

841 Prior to designing the SRI, it is essential to consider who it is to be aimed at and hence designed for.
842 It is imperative that this is thought through if the content, organisation and presentation of the SRI
843 is to be salient and motivating and hence to affect positive change.

844

845 In principle the SRI will present smart readiness information with regard to both existing or new
846 buildings and if it is to be an effective stimulus to action it will need to influence decisions regarding
847 the smartness of these buildings. In principle, both building owners and occupiers can make smart
848 building investment decisions and both can be affected by the degree of smartness attained;
849 however, in general the owner will make the smart services investments and the occupier will be
850 affected by them (the owner can be too but only indirectly so if they are not also the occupier and
851 responsible for utility bills). Facility managers too will be an important audience for the SRI as they
852 may operate the smart systems and may influence the investment decisions. In addition to the users
853 and investors, the other important audience for the SRI will be the smart service providers. If an SRI
854 resonates with them it can help organise and position their service offering by providing neutral and
855 common framework wherein the capability of their smart services can be directly compared with
856 those of their competitors including the incumbent non-smart services. This is likely to be critical to
857 the schemes success because experience shows that service providers not only adjust their business
858 models to position their services within the context of such schemes but can also strongly promote
859 and amplify the schemes impact providing it is seen to be a viable and influential instrument. The
860 potential service providers are very broad. They include: DSOs and TSOs, aggregators, micro-grid
861 operators, heat network operators, gas and oil suppliers and service companies, RES and storage
862 suppliers, TBS manufacturers and OEMs, building service engineers and electro-mechanical
863 contractors, facility managers, e-mobility service providers and equipment manufacturers, IT service
864 providers and equipment suppliers, metering companies, building designers, building renovators,
865 ESCOs and multi-utility service company providers, maintenance servicing companies, water utilities
866 and service companies, third party assessors, health service providers, certification and accreditation
867 agencies.

868

869 Ideally the SRI needs to resonate with all the key actors and needs to provide a framework that
870 enables each party to find what they need regarding the articulation of smart services and
871 capabilities within it. However, each of these parties is likely to have quite different needs and
872 expectations and this implies that to the extent possible the SRI should be structured so that it can
873 reflect and convey relevant information at the level each needs. Ultimately though it is the building
874 occupiers, bill payers and owners who are the most important audience and thus their needs should
875 take precedence.

876 **The SRI value proposition**

877 Establishing the value proposition of the SRI and considering how this affects its impact as a change
878 vector is important for the SRI's success but also design. The key value propositions articulated in the
879 Commissions call for tender are:

880

881 1) Readiness to adapt in response to the needs of the occupant (e.g. the heating system can be
882 switched on or shifted to lower temperatures when there is nobody at home) and to empower
883 building occupants by taking direct control of their energy consumption and/or generation (i.e.
884 prosumer);

885

886 2) Readiness to facilitate maintenance and efficient operation of the building in a more automated
887 and controlled manner (e.g. anticipate problems with clogged filters; use of CO₂ sensors to control
888 the flow rate of ventilation systems); and

889
890 3) Readiness to adapt in response to the needs/situation of the grid (e.g. reduce consumption when
891 there is not enough electricity in the grid system or switch on home appliances which could modulate
892 peak electricity production - generally stemming from renewables).

893
894 The methodology also needs to be mindful of the desires of users of the SRI and that it is possible
895 that building occupiers, service bill payers and owners might express their priorities differently. In
896 the absence of doing market research to establish what the value proposition among these key
897 audiences is, it is speculative to imagine what these may be. A priori it is likely to reflect a blend of
898 desires regarding smart capabilities to minimise total expenditure on utilities and services, increasing
899 comfort and convenience, providing health alerts and improving the health of indoor environments,
900 provision of smart aesthetic experiences, and identification of faults and facilitation of maintenance.
901 It may also address safety (e.g. fire) and security services but these are outside the scope of the
902 current study as they are outside the scope of the EPBD. While facilitating e-mobility and helping
903 reduce energy bills is likely to feature highly on people's priorities enhancing grid-flexibility is not
904 except to the extent that it is a trigger to bill reduction (i.e. at best it is likely to be perceived as a
905 means to an end and not an objective in its own right). This is likely to be a very important factor in
906 how the SRI could be rolled out because if its value proposition to end customers is presented
907 primarily in terms of grid flexibility engagement then engagement with the scheme and impact are
908 likely to be low. More likely it would require careful packaging and presentation of the value
909 propositions of which flexibility is one among many.

910 In addition, to be successful it will be necessary to structure the SRI so its value proposition is of
911 greater value than its cost of implementation. Otherwise engagement with the SRI will not occur.

912 **Policy objectives**

913 The broad policy objectives for the SRI have been articulated in the Commission's tender document
914 for the study and behind these is the intention that the SRI should support the EU's broad energy
915 policy agenda by facilitating energy savings in buildings, improving grid balancing capability and
916 thereby facilitating deeper penetration of intermittent RES, and facilitating the move towards low
917 carbon transport via stimulating adoption of e-mobility solutions. In a higher level sense these
918 objectives equate to a desire to support the decarbonisation of the energy system, increase energy
919 security and provide value for money to end-users and bill payers. Due to its wide scope and multi-
920 faceted nature the SRI will interface with many other policy domains and objectives, however. These
921 concern health, economic efficiency and employment, consumer rights and data protection, and
922 digital technologies (e.g. cyber security) among others. In principle, the SRI should comply with
923 consumer rights, data protection and cyber security concerns and requirements.

924
925 It is important though to have clarity regarding the policy-related objectives to ensure the scheme is
926 designed in a manner that best satisfies them.

927
928 Moreover, since work started on this project an agreed text between the Parliament and Council for
929 the revised EPBPD has been drafted which states that the objectives with regard to the SRI are as
930 follows:

931
932 "The smart readiness indicator should be used to measure the capacity of buildings to use
933 information and communication technologies and electronic systems to adapt the operation of

934 buildings to the needs of the occupants and the grid and to improve the energy efficiency and overall
935 performance of buildings. The smart readiness indicator should raise awareness amongst building
936 owners and occupants of the value behind building automation and electronic monitoring of
937 technical building systems and should give confidence to occupants about the actual savings of those
938 new enhanced-functionalities. Use of the scheme for rating the smart readiness of buildings should
939 be optional for Member States”

940

941 This text clearly outlines the purpose of the SRI and this needs to be reflected in the methodology
942 used to derive it.

943 **The information to be conveyed**

944 The preceding discussion of the audience, value proposition and policy objectives should inform the
945 decisions about the information the SRI should convey. The art is to convey the information which
946 will best stimulate change that supports the policy objectives without provoking unintended
947 consequences. As the stimulation of this positive change relies on the target audience being
948 receptive to and motivated by the information they receive this requires the information to embrace
949 the elements which can achieve this while retaining the required policy-related content. In the case
950 of the SRI the target audience is very complex because the diverse set of smart service providers are
951 also key actors and vectors of positive change. The great complexity of information which defines
952 and describes the smart service capability cannot be ignored either.

953

954 The information needs of the end-user of the building (building occupier, owner, bill payer) are likely
955 to be contradictory. On the one hand consumer research and behavioural science studies find that
956 end-users decision-making is most influenced when information that informs the process is simple
957 and limited (i.e. there is only a small amount of it). On the other hand, the same types of research
958 will find that un-transparent information that does not relate to something tangible to the end-user
959 is not accessible and is not utilised in their decision-making. The former observation would tend to
960 drive the SRI in the direction of an aggregate indicator that pulls together scores across all the
961 impacts of concern to (and hence motivating) to end-users. The latter observation would tend to
962 mitigate against such simplified compound scores/rankings because the information they contain
963 becomes muddled together and hence loses transparency and meaning. This is a particular problem
964 for a smartness indicator because there is no common understanding of what smartness means and
965 hence of what is being indicated when a compound indicator is used.

966

967 If one considers the issue from the perspective of service providers they are likely to want the
968 information conveyed in the indicator to be able to clearly position the value propositions of their
969 services against the rest of the market and incumbent (non-smart) services. As these services are
970 inherently diverse this implies conveyance of information with a high degree of granularity. For some
971 stakeholders such as DSO's, aggregators etc., additional quantified information such as energy
972 consumption and flexibility metrics might be useful, alongside a compound score from the indicator.
973 Furthermore, some audiences might want to receive additional information besides the scoring of
974 the building in its present condition. To reach the policy objectives of spurring the uptake of smart
975 services in the building stock, a valuable addition could be to provide tangible suggestions on the
976 next steps to increase the smartness of a specific building.

977 Communication of the information

978 The form taken to communicate the information to the target audience will also affect its impact as
979 positive change agent. In general research has proven that heuristic scales which convert underlying
980 scores into more accessible rankings (such as A to G scales, 0 to 5 stars etc.) are more easily accessible
981 by a non-technical audience than quantified numerical scores. Firstly, the heuristic scales clearly
982 indicate all the end points and where the service offering lies upon it. Secondly, using a limited set
983 of quantised levels makes it easier to process the information and act upon it. The decision making
984 process can be much more tractable with such scales because a service procurer could follow a
985 simple horizontal rule e.g. nothing worse than a class B, rather than having to get lost in the technical
986 details behind these rankings. Such information presentation can partly overcome the problems
987 highlighted in the previous section. This can however only be successful if end-users feel that the
988 scale reflects something they understand and care about. For other audiences, such as utility
989 providers or contractors, quantified numeric scores could be preferred over heuristic scales.

990
991 The choice of media used to communicate the information is another aspect any SRI scheme would
992 need to consider. For some intended audiences, secured (online) datasets might for example be
993 preferred over a printed output. As far as the methodology is concerned though, this is a secondary
994 issue, and can be settled upon at a later stage closer to implementation.

995 The integrity of the SRI

996 The integrity of the SRI will be crucial for its success. If the target audience does not believe the
997 information it contains it will not make any positive impact in their procurement and utilisation
998 decisions. The strength of belief in the schemes integrity will be clearly be affected by the integrity
999 of the rating and assessment process and the perception of this.

1000 The credibility of the SRI

1001 The credibility of the SRI will also be crucial for its success. If the target audience does not believe
1002 the technical basis for the scoring is sound then it will undermine its impact. For some audiences a
1003 quantification in physical metrics (kWh,...) could increase the perceived credibility. This might
1004 however also entail additional risks towards credibility, in case the predicted values differ
1005 significantly from measured data in its actual operation.

1006 Adaptability to context

1007 The SRI methodology needs to avoid unintended perverse outcomes by being adaptable to relevant
1008 contextual factors. These can include variations by building type, by climate, by culture and the
1009 impact it has on the desire to have certain services. These in turn can lead to some smart services or
1010 even whole domains being inappropriate in some contexts. The scoring methodology deployed
1011 needs to be capable of adaptation to reflect this context and to avoid penalisation for the absence
1012 of irrelevant or impossible/impracticable services. It also needs to be adaptable to reflect divergence
1013 in priorities and implementation capabilities by jurisdiction. The implication of these concerns is that
1014 the methodology should be modular and flexible.

1015 Smart ready and smart now

1016 The distinction between the two concepts is potentially important in the design of an indicator. The
1017 term smart ready implies that the building itself is smart but its potential to realise the benefits from
1018 smart services may be constrained by limiting factors in the capability of the services it connects to
1019 at its boundary. This recognises the distinction between smart readiness as opposed to operational
1020 smart capability.

1021

1022 This is the spirit in which the methodology presented in the rest of the report aims to represent
1023 smart readiness.

1024 Future proofing – allowing and encouraging innovation

1025 The SRI and its methodology should not be inhibitors to innovation but rather should encourage it,
1026 thus, it is important that the methodology is such that positive innovations can be reflected and
1027 rewarded as early as possible. This means that the methodology should allow relevant new
1028 capabilities to be reflected as soon as possible and address future proofing needs by: allowing new
1029 solutions, recognising building smart readiness and avoiding negative lock-in effects, and recognising
1030 the distinction between smart readiness as opposed to operational smart capability. Furthermore,
1031 the impact of a rapidly changing landscape of policies and commercially available services can be
1032 incorporated by some extent by recognising a distinction between smart readiness as opposed to
1033 operational smart capability.

1034 Fairness and a level playing field for market actors

1035 The SRI methodology and scoring system needs to create a level playing field for market actors and
1036 aim for technology neutrality through the definition of functional capability rather than the
1037 prescription of certain technological solutions. The manner in which the smart readiness services
1038 were defined in the Task 1 catalogue reflects this principle.

1039 The potential usage of qualifying preconditions

1040 As the definition of what constitutes a smart building is open to interpretation some stakeholders
1041 have proposed that some preconditions should be imposed before a building is considered eligible
1042 to receive an SRI. For example, this was proposed in the first stakeholder meeting for the building
1043 energy performance. Others have suggested that certain services should satisfy minimum
1044 qualification thresholds for health or air quality before they become eligible. The methodology
1045 presented in this report is agnostic on this topic and is structured such that it could be used with or
1046 without such qualifying preconditions.

1047 Interaction with other policy instruments

1048 At present it is unclear how the SRI would interact, or operate in conjunction with, other policy
1049 relevant instruments - most notably EPCs. It is therefore important that the methodology set out
1050 permits any form of interaction deemed appropriate.

1051 Treatment of fixed (static) versus transportable (mobile) smartness features

1052 In principle there is a distinction between smart services that are embedded in the building and those
1053 that can be readily taken somewhere else. Capability for remote operation of smart building services
1054 by the occupant or their designated operative would need to stay with any future
1055 occupant/designated operative of that building for the SRI score to remain unchanged subsequent
1056 to a change in occupancy.

1057 Time and cost requirements

1058 Assessing the smartness of a building will require to inspect the building and its systems on site. The
1059 time and efforts needed for this will depend on multiple variables such as the number of services to
1060 be inspected, the detail of the assessment of each of the services, the size and accessibility of the
1061 building and the experience of the assessor. The costs for deriving an SRI will also be affected by the
1062 requested qualifications of the assessor and the additional efforts needed for operating any
1063 accompanying calculation software, in administrative tasks, travel time to the inspection site, etc.
1064 An important consideration in deriving the SRI methodology will thus be to balance the desire of a
1065 sufficiently detailed assessment with the desire to keep the time and cost requirements limited.

1066 Building-specific features

1067 Buildings and building usage display a great variety across the building stock. Ideally, an SRI reflects
1068 this complexity by encompassing some differentiation with regard to building usage typologies (e.g.
1069 residential, offices, educational buildings) and potentially also the age of a building (e.g. newly
1070 constructed versus existing building stock). Even within a single building differentiation can occur if
1071 it mixes different functions or if smart features are only present in specific parts of the building. The
1072 SRI methodology should be flexible to accommodate this large variation and for example allow for
1073 the roll-out of specific versions tailored towards a specific building type.

1074 The SRI assessment process and aides to assessment

1075 In theory an SRI assessment could be conducted by a variety of different actors including: specialised
1076 third party assessors, the building occupants, facility managers, building owners, hired contractors,
1077 DSO/TSO operatives, IT service providers, building service engineers, ESCOs, smart service providers,
1078 etc. For the assessment to be reliable it is likely to necessitate that a competent and independent
1079 party should make the assessment (much as is the case for most EPCs). For the time being it is also
1080 expected that an assessor would need to have access to the building to be able to make an inspection
1081 on site. It is likely though, that as an SRI scheme matures that the assessment process would evolve
1082 to reflect on-going developments. Thus, as more and more of smart readiness features and
1083 associated service offerings become classified and standardised in accordance with the scope and
1084 definitions used in the scheme the means of making the assessment could evolve. Initially many
1085 service offerings and capabilities would require on-site visual assessment supported by access to
1086 relevant service documentation (either as hard copies or electronically). This process would be
1087 facilitated by the provision of clear markings on the products and documentation descriptions to
1088 indicate at a glance the service offerings the equipment provides with a one-to-one correspondence
1089 to the service and functionality level taxonomy used in the scheme. As the scheme matures it is
1090 conceivable that this information could be made available for packaged smart-ready products via
1091 some form of standardised signalling and reading/scanning process e.g. via QR codes or similar on
1092 the smart readiness equipment, documentation or associated web-sites. Equally, in principle smart-

1093 ready services installed as equipment systems by contractors (and not just supplied as packaged
1094 products that non-professional users can install and use) could also be subject to a smart readiness
1095 capability assessment by the contractor who then leaves on site smart readiness capability status
1096 information in a form that facilitates the assessment process. Again this could be via QR codes or
1097 similar.

1098

1099 The process could be further facilitated were one central point to be established where this smart
1100 readiness status information would be deposited each time a new SRI service is added or an old one
1101 removed. Nor does this status information necessarily need to be stored and recorded on site. It
1102 could be loaded into a cloud-based server such that a SRI assessor would be granted access to this
1103 information to be able to make the assessment (either remotely or in conjunction with a site visit).
1104 Equally the systems could be provided with live remote status assessment capability to facilitate their
1105 remote and automated assessment.

1106

1107 Under such scenarios the assessor could be charged with making an aggregate assessment of the
1108 smart readiness service status information provided by packaged equipment suppliers, system
1109 installers and related service providers; each of whom could be held legally liable for the accuracy of
1110 the information they communicate into the system. Some kind of occasional sampling and
1111 verification process could then be established to support the integrity of this system.

1112

1113 A self-assessment process wherein owners, occupiers or facility managers make the assessment and
1114 communicate it to the managing authority is also conceivable but may suffer from low engagement
1115 and lack of credibility.

1116

1117 Then a working assumption is made that a competent third-party assessor will make a site visit to
1118 the premises to conduct the SRI assessment and compute its score. This may evolve over time into
1119 more sophisticated and less intrusive and costly assessment processes as the scheme becomes
1120 established.

1121

1122 It is important to appreciate that owners, facility managers and occupiers may affect access to a
1123 building to make an SRI assessment or equally may need to grant permission to access related data.
1124 This implies that they have to see the SRI as something they value in order for them to engage in and
1125 support the assessment process.

1126

1127

Data protection

1128 With the advent of the General Data Protection Directive (GDPR) data protection will be a key
1129 requirement for the smart readiness indicator. This will not only affect smart services in buildings
1130 but also the SRI certification itself. In particular, the building owner and occupant will need to
1131 consent to their data being used for any purpose and the data will need to be anonymised if it is to
1132 be used for statistical and research purposes. In addition, data owners will need to be granted access
1133 on request to any data that they own.

1134

1135 **4.2. DEVELOPMENT OF A GENERIC SRI METHODOLOGY**

1136 This section sets out the development of the generic SRI methodology. It begins by briefly reviewing
 1137 multi-criteria decision making methodologies in general and then leads from that to the exposition
 1138 of the generic SRI methodology.

1139 **4.2.1. MULTI-CRITERIA DECISION-MAKING METHODS**

1140 This section discusses multi-criteria decision making (MCDM) methods that have been applied to
 1141 energy/environmental decision-making including reviewing how they work and the
 1142 compromises/value judgements they necessarily entail between different impact criteria, different
 1143 areas of impact and different degrees of measurability i.e. cardinal, ordinal, qualitative metrics. It
 1144 references and borrows from the DG GROW Points System for Complex Products study³³ (VITO &
 1145 WSE 2017), where such an exercise was conducted. It then summarises the implications this has for
 1146 the design of a generic SRI.

1147
 1148 The derivation of a smart readiness indicator, which involves the assessment of numerous impact
 1149 criteria related to building's smart service capability, is a manifestation of a multi-criteria decision-
 1150 making process and like all multi-criteria assessment problems faces a challenge of how to determine
 1151 preferred outcomes given the presence of more than one assessment criterion.

1152
 1153 A more general understanding of the theory and principles involved in all such processes can be
 1154 helpful to contextualise thinking on how methods to address these challenges could be derived and
 1155 applied in the future. This section provides a very brief introduction to the theory MCDM and multi-
 1156 criteria decision analysis (MCDA) that aims to position the SRI methodology framing in its broader
 1157 context any thereby better understand the principles and theory behind the derivation and use of
 1158 points-systems approaches for multi-criteria assessment.

1159
 1160 In general, models that support MCDM are concerned with structuring and solving decision and
 1161 planning problems involving multiple criteria. The rationale for creating such a structured framework
 1162 is to support decision-makers confronting such problems. Usually there is no unique and
 1163 unequivocally optimal solution to an MCDM problem that can be derived without incorporating
 1164 preference information. Thus MCDM models are designed to provide a framework that will allow
 1165 such preference information to be assessed in conjunction with deterministic or empirical
 1166 information so that decisions which involve the assessment of multiple criteria can be reached within
 1167 a structured framework.

~~1168~~
 1170 MCDM has been an active area of research since the 1970s and draws upon knowledge in many fields
 1171 including: mathematics, behavioural decision theory, economics, computer technology, software
 1172 engineering and information systems. There are several MCDM-related organisations including the
 1173 International Society on Multi-criteria Decision Making³⁴, Euro Working Group on MCDA (Euro
 working Group)³⁵, and INFORMS Section on MCDM (INFORMS)³⁶.

1175

³³ <https://points-system.eu/>

³⁴ <https://www.mcdmsociety.org/>

³⁵ <http://www.cs.put.poznan.pl/ewgmcda/>

³⁶ <http://connect.informs.org/multiple-criteria-decision-making/home>

1176 MCDM typologies

1177 It should be noted that there are different classifications of MCDM problems and methods. A major
1178 distinction between MCDM problems is based on whether the solutions are explicitly or implicitly
1179 defined.

1180 • *Multiple-criteria evaluation problems*: These problems consist of a finite, discrete number of
1181 alternatives, explicitly known in the beginning of the solution process. Each alternative is
1182 represented by its performance in multiple criteria. The problem may be defined as finding
1183 the best alternative for a decision-maker (DM), or finding a set of good alternatives. There
1184 may also be a need to sort or classify the alternatives. In this context sorting would be
1185 undertaken to place the alternatives into a set of preference-ordered classes (such as
1186 assigning star ratings to hotels). Classifying refers to assigning alternatives to non-ordered
1187 sets (such as diagnosing patients based on their symptoms).

1188 • *Multiple-criteria design problems (multiple objective optimisation problems)*: In these
1189 problems, the alternatives are not explicitly known and an alternative (solution) may be
1190 found by solving a mathematical model. The number of alternatives may either be infinite
1191 (when some variables are continuous) or typically very large if the variables are countable
1192 (when all variables are discrete).

1193 The SRI belongs to the set of multi-criteria evaluation problems which is reflected in the catalogue
1194 of smart readiness domains, services and functionalities presented in Task 1; however, regardless of
1195 whether the problem is of the evaluation or design type, preference information is required in order
1196 to differentiate between solutions in the decision model.

1197 It is beyond the scope of this exercise to review all the potential MCDM methods (see Annex M for
1198 a list); however, the recently completed study on Ecodesign Points Systems for Complex products
1199 provides an extensive review of the application of points system methods to multi-criterion energy
1200 and environmental evaluation exercises as applied to technologies and other energy using or related
1201 systems, e.g. Task 2 report of Points System Study (VITO & WSE, 2017). The cases covered include
1202 many applied to the energy and environmental performance evaluation of buildings including the
1203 BREEAM, LEED and DGNB schemes. In so doing it considers the effectiveness, enforceability,
1204 transparency, and accuracy/reproducibility of these methods.

1205 The key concept to understand is that because multi-criteria evaluation problems involve
1206 comparisons and judgements between inherently different criteria that they are necessarily
1207 subjective. There is no “right” answer to these evaluations but if good methodological practice is
1208 used the problem can be framed in a manner that allows judgements and preferences to be
1209 compared and treated within an organised framework, that maximises transparency, fairness of
1210 consideration and treatment and allows the designated decision makers to reach a collective
1211 position. The Analytic Hierarchy Process (AHP) is a good example of this. It is a MCDM tool that was
1212 first articulated in the 1970s and has the practical value of creating a framework that enables
1213 alternative choices across different assessment criteria sets to be compared and ranked against each
1214 other. In particular, it permits the assessment of sets of qualitative and quantitative criteria to be
1215 assessed within a common analytical structure in order to rank outcomes based on the preferences
1216 embedded in the model. The AHP does this by initially decomposing the decision problem into a
1217 hierarchy of sub-problems (much as the Task 1 smart services catalogue structure would imply). Then
1218 the decision-maker(s) evaluate the relative importance of its various elements by pairwise
1219 comparisons. The AHP converts these evaluations to numerical values (weights or priorities), which
1220 are used to calculate a score for each alternative. Decision situations to which the AHP can be applied
1221 include:

- 1222 • Choice – The selection of one alternative from a given set of alternatives, usually where there
- 1223 are multiple decision criteria involved.
- 1224 • Ranking – Putting a set of alternatives in order from most to least desirable
- 1225 • Prioritisation – Determining the relative merit of members of a set of alternatives, as
- 1226 opposed to selecting a single one or merely ranking them
- 1227 • Resource allocation – Apportioning resources among a set of alternatives
- 1228 • Benchmarking
- 1229 • Quality management – Dealing with the multidimensional aspects of quality and quality
- 1230 improvement
- 1231 • Conflict resolution – Settling disputes between parties with apparently incompatible goals
- 1232 or positions.

1233 The AHP does not determine a "correct" decision, but rather enables decision-makers to find one
 1234 that best suits their objective and understanding of the problem. It provides a comprehensive and
 1235 rational framework for structuring a decision problem, representing and quantifying its elements,
 1236 relating those elements to overall goals and for evaluating alternative solutions.

1237 There have been thousands of applications of AHP to complex decision-making situations. These
 1238 encompass applications in a very diverse set of problems involving planning, resource allocation,
 1239 priority setting and selection among alternatives, forecasting, total quality management, business
 1240 process re-engineering, quality function deployment and balanced scorecards. It has particular
 1241 application in group decision-making and is used around the world in a wide variety of decision
 1242 situations, in fields such as government, business, industry, healthcare, shipbuilding and education.
 1243 Commercial software to assist in applying AHP is available. Due to its intensive development nature
 1244 the AHP is probably not best suited to the derivation of a multi-criterion public policy evaluation
 1245 framework like the SRI, but aspects of its structuring of the MCDM problem that allow structured
 1246 assessment of choice, ranking, prioritisation, resource allocation (e.g. assessment time & cost for the
 1247 SRI) and benchmarking should be. These thoughts, and particularly how they have been applied to a
 1248 points type evaluation framework inspire the development of the methodology set out below. In
 1249 particular, the methodology set out in this Task is informed by the methodology developed and
 1250 tested for the DG GROW Points System for Complex Products study (VITO & WSE, 2017).

1251 **4.2.2. DERIVATION OF A GENERIC SRI METHODOLOGY**

1252 This section describes the derivation of the generic SRI. It introduces a generic SRI scoring system
 1253 and describes its elements, its modularity, and its flexibility.

1254
 1255 The Task 1 work has highlighted the array of smart readiness aspects and features that can be
 1256 expressed in terms of domains, services and functions. The domains articulate a taxonomy of the
 1257 systems within which these smart readiness (SR) features are applied. For each of the services several
 1258 "levels of functionality" are defined to differentiate between levels of implementation of smartness
 1259 for a given functionality offered to the building occupant, owner or the grid. In addition, a set of eight
 1260 higher-level impact criteria are defined and the effect (expressed in terms of an ordinal ranking
 1261 system) that each level of functionality is expected to have on these criteria has been estimated.

1262
 1263 The prospective SRI methodology needs to take these inputs and use them to derive an output (or
 1264 outputs) that provides an indicator of how "smart" a building is. In particular, it will (most likely) want
 1265 to assess the effect these are expected to have on a set of designated impacts (e.g. the eight impact
 1266 criteria) and award smart-readiness scores based on this.

1267
 1268 The methodology chosen has to allow the impacts to be assessed and scored; however, at this stage
 1269 of the indicator development process the policymaking community's views with regard to the most

1270 important impacts and how they should be scored are not fully known. Thus, the structure used in
 1271 the methodology has to be adaptable to allow the policymaking process to establish a collective
 1272 position on the choice of impacts to be addressed and their relative importance. In practice, it also
 1273 needs to be developed in such a manner that will help to inform the discussion and facilitate the
 1274 decision making process.

1275

1276 *An SRI methodology*

1277 It follows to consider what characteristics a general SRI methodology should have. Currently the
 1278 envisioned methodology is that of a multi-criteria assessment based on the predicted impacts of the
 1279 smart services present in a building. Prospective alternative approaches, such as assessing the 'level
 1280 of smartness features implemented' (merely counting the features without taking into account their
 1281 predicted impacts) or direct quantification or even measurement of physical characteristics, etc. are
 1282 not pursued for now because in the former case they are likely to be too simplistic and lack
 1283 credibility, whereas the latter approach implies a level of determinism that could result in practical
 1284 difficulties for smart readiness assessments. Rather it aims to strike a balance between facility of
 1285 implementation and the correct characterisation of impacts that best satisfies the considerations set
 1286 out in Section 4.1.

1287

1288 In all multi-criteria assessment methodologies which result in a single score or indicator, the
 1289 following approach is taken:

1290

- 1291 • identify the relevant impact criteria to be used in the assessment
- 1292 • develop a methodology to determine the effect that sub-elements have on each impact
 1293 criteria and thereby allow scoring per impact criteria
- 1294 • develop a system of weightings to determine an overall score across the impact criteria.

1295 If (for the sake of simplicity) it were to be assumed that there are just three relevant impact criteria
 1296 (in fact the Task 1 report has identified eight³⁷) and the indicator can be expressed as a simple
 1297 weighted sum, then the overall score N becomes:

1298

1299

$$N = A \times a + B \times b + C \times c$$

1300

1301 Where a, b and c are the relative weightings given to the impact criteria scores A, B and C. Normally
 1302 a, b and c would add up to 1 (to normalise the outcome) and A, B and C would be scored on a scale
 1303 that corresponds to the final scale for N (e.g. it could be on a scale of 0 to 100, in which case A, B and
 1304 C would also each be scored on a scale of 0 to 100). Such a system would give a final score for N of
 1305 from 0 to 100 and this in turn could be transposed into a heuristic scale (such as A to G, or 1 to 5
 1306 stars) using a classification system that defines the grades in terms of the score N: noting that
 1307 heuristic scales are valuable because they tend to be more accessible and memorable for users and
 1308 hence easier to incorporate in their decision-making processes. Exactly this methodology can be
 1309 applied for the SRI, even though the number and nature of impact criteria (A, B, C...X) and the
 1310 weightings to be applied to them (a, b, c, ...x where the sum of a to x is 1) remain to be consolidated
 1311 in the policymaking process.

1312

1313 Under such a structure it would be possible to begin with the most tractable (important and viable)
 1314 impact criteria and to add more in the future as they become sufficiently viable to assess. Each time
 1315 a new impact criterion is added the weightings a, b, c, to x would need to be adjusted so that their

³⁷ Namely: energy savings on site, flexibility for the grid and storage, self-generation, comfort, convenience, health, maintenance & fault prediction, information to occupants.

1316 sum still adds up to 1. It should be noted that the BPIE smartness indicator³⁸ intrinsically follows this
 1317 approach but in that case there are 12 primary impact criteria (of which 3 are compound impact
 1318 parameters made up of two sub-criteria) and these are implicitly each given a weighting of 1/12 to
 1319 each of these i.e. it is implicitly assumed that each are of equal importance. This is essentially a
 1320 special case of the methodology outlined above, but one that was developed by a project team
 1321 without formally being informed by a representative public policy decision-making process to agree
 1322 the impact criteria to be included and the relative weightings they should have.

1323
 1324 Note, in principle, an initial set of impact criteria could be those highlighted in the tender document
 1325 i.e. the readiness to: adapt in response to the needs of the occupant; facilitate maintenance and
 1326 efficient operation; adapt in response to the needs/situation of the grid. Also, in principle these
 1327 impacts could be further grouped based on their impact on a higher level impact criteria, such as
 1328 greenhouse gas emissions, or energy security, and in this case analysis could be done to assess how
 1329 much they are likely to contribute to these higher level impacts. Such a grouping process would
 1330 require the introduction of an analytical step to determine the likely importance of each of these
 1331 impact criteria on the higher level impacts. Alternatively, the method could simply assess each
 1332 impact criterion separately and use weightings to reflect the importance they have on these higher
 1333 level impacts.

1334
 1335 *How can each impact criterion be evaluated?*

1336 Deriving a score (A, B, C ...X) for each impact criterion requires information on the impact each SR
 1337 feature (i.e. service functionality level) has on the impact criterion and derivation of a rating system
 1338 for the given parameter. The Task 1 work presented the study team's initial ordinal impact rankings
 1339 for each SR service functionality level per impact criterion (or in some cases this is omitted when
 1340 there is no information). In some instances, a standard exists that would allow an approximate
 1341 quantitative impact value³⁹ to be estimated. In many cases there is currently no agreed system for
 1342 determining the magnitudes of impacts. Annex F presents a partial review to clarify the state of
 1343 knowledge on what is known about the impact of each SR feature on each of the eight designated
 1344 impact criteria. Ultimately, if ordinal rankings (such as the scale ---, --, -, 0, +, ++, +++ used in Task 1)
 1345 are to be meaningful then there will need to be a systematic and publicly legitimate effort to imagine
 1346 the quantified limits of these scales and the intermediate values the ordinal rankings are most likely
 1347 to correspond to.

1348
 1349 Furthermore, and critically, the ordinal rankings by impact criterion in Task 1 are set at the domain
 1350 level (e.g. heating, cooling, DHW, etc.) yet what matters is the overall impact across the domains on
 1351 the impact criterion. To translate from domain level impacts to whole building impacts requires a
 1352 mapping exercise for typical buildings. This will be elaborated further for certain key impact criteria
 1353 in Task 4 but in the meantime use is made of some simple existing data to attempt this for some
 1354 exemplar impact criteria, in order to demonstrate the principle.

1355

³⁸ Actually this is a "Smart-Ready Built Environment Indicator", which only rates the boundary conditions and not the buildings themselves.

³⁹ The underlying aim is to pinpoint features of a building which can augment its smartness. An exact quantification of the resulting effects of the smart features is therefore not necessarily needed. Calculating the energy savings or flexibility in terms of financial gains or kWh, or quantifying the healthier living environment in DALYs would be a very complicated undertaking, requiring highly complex calculation methodologies and extensive in-situ inspections. This is not considered at this step within the intended framework for the SRI. Rather simplified expressions representing average effects could be favoured as the basis of this calculation (e.g. in line with the methodology of 'classes' as reported in the EN15232 standard on energy savings from BACS).

1356 *Potential impact interactions between services*

1357 It should also be noted that theoretically there could be interactions between services that ideally
1358 should be taken into account. Whenever these could exist they should be identified and ideally the
1359 relationship between them established.

1360 **4.2.3. THEORETICAL APPLICATION OF TASK 1 ELEMENTS WITHIN THE GENERIC METHODOLOGY**

1361 This section shows how the generic methodology can be applied to a theoretical building using the
1362 array of Task 1 smart readiness catalogue elements. It shows how weighting the domains and/or
1363 impacts affects the outcomes. It also shows the degree to which organising the elements in terms of
1364 their impact progressively contributes to the final SRI score and thus helps clarify the potential trade-
1365 offs that can be envisaged from limiting the number of elements that are assessed in order to make
1366 a viable scheme.

1367

1368 The following sections present illustrations of the process of applying the generic methodology for
1369 the case where equal weightings are applied and also for the case where differentiated weightings
1370 are applied. They begin with an exposition of how the methodology could be applied to any building
1371 and then considers the specific case of a hypothetical single family home.

1372 **Equal weightings case study**

1373 In order to illustrate the generic SRI methodology it is applied here based on the distinctions made
1374 in the Task 1 analysis. In particular, it is assumed that the impact criteria to be addressed are the
1375 same as those identified in the Task 1 analysis, namely:

- 1376 • Energy savings
- 1377 • Flexibility for the grid
- 1378 • Self-generation
- 1379 • Comfort
- 1380 • Convenience
- 1381 • Health
- 1382 • Maintenance & fault prediction
- 1383 • Information to occupants

1384 Under this example, using the eight impact criteria provisionally proposed in the Task 1 report then
1385 the generic model set out before would become:

1386

$$1387 \quad N = A \times a + B \times b + C \times c + D \times d + E \times e + F \times f + G \times g + H \times h$$

1388

1389 Where:

1390 A = the impact score (from 0 – 100) for Energy Savings

1391 B = the impact score (from 0 – 100) for Flexibility for the grid and storage

1392 C = the impact score (from 0 – 100) for Self-generation

1393 D = the impact score (from 0 – 100) for Comfort

1394 E = the impact score (from 0 – 100) for Convenience

1395 F = the impact score (from 0 – 100) for Health

1396 G = the impact score (from 0 – 100) for Maintenance and health prediction

1397 H = the impact score (from 0 – 100) for Information to occupants

1398

1399 And:

- 1400 a = the impact weighting (from 0 – 100%) for Energy Savings
 1401 b = the impact weighting (from 0 – 100%) for Flexibility for the grid and storage
 1402 c = the impact weighting (from 0 – 100%) for Self-generation
 1403 d = the impact weighting (from 0 – 100%) for Comfort
 1404 e = the impact weighting (from 0 – 100%) for Convenience
 1405 f = the impact weighting (from 0 – 100%) for Health
 1406 g = the impact weighting (from 0 – 100%) for Maintenance and health prediction
 1407 h = the impact weighting (from 0 – 100%) for Information to occupants

1408
 1409 In this first illustration of the generic method the impact criteria weightings are weighted equally i.e.
 1410 at 12.5% each (i.e. at 100%/8 given that there are 8 impact criteria).

1411 In practice, the impact of SR features on these criteria has to be assessed at the domain level where
 1412 the SR features are applied. In this example the domains considered are also the same as in the Task
 1413 1 analysis, namely:

- 1414 • Heating
- 1415 • Domestic hot water
- 1416 • Cooling
- 1417 • Controlled ventilation
- 1418 • Lighting
- 1419 • Dynamic building envelope
- 1420 • Energy generation
- 1421 • Demand side management
- 1422 • Electric vehicle charging
- 1423 • Monitoring and control.

1424 For each of these domains the same services as applied in the Task 1 analysis are assumed. E.g. in
 1425 the case of heating the following 12 services are considered (see Table 1).

1426 *Table 1 - Heating services considered in Task 1*

Heating-1 Heat control - demand side

- Heating-1a Heat emission control
 Heating-1b Emission control for TABS (heating mode)
 Heating-1c Control of distribution network hot water temperature (supply or return) - Similar
 function can be applied to the control of direct electric heating networks
 Heating-1d Control of distribution pumps in networks
 Heating-1e Intermittent control of emission and/or distribution - One controller can control
 different rooms/zones having same occupancy patterns
 Heating-1f Thermal Energy Storage (TES) for building heating
 Heating-1g Building preheating control

Heating-2 Control heat production facilities

- Heating-2a Heat generator control (for combustion and district heating)
 Heating-2b Heat generator control (for heat pumps)
 Heating-2c Sequencing of different heat generators
 Heating-2d Heat system control according to external signal (e.g. electricity tariff, gas pricing,
 load shedding signal etc.)
 Heating-2e Heat recovery control (e.g. excess heat from data centres)

1427
 1428 Each service can be delivered with a varying level of SR functionality. In the Task 1 analysis these
 1429 range from one to up to four functionality levels depending on the service considered (they can be

1430 as little as two functionality levels or as many as four levels). An example is the different functionality
 1431 levels ascribed to the service of heat emission control (within the heating domain) which are defined
 1432 in Task 1 as shown in Table 2.

1433 *Table 2 - Functionality levels for the heat emission control service from Task 1*

Functionality level	Functionality description
0	No automatic control
1	Central automatic control (e.g. central thermostat)
2	Individual room control (e.g. thermostatic valves, or electronic controller)
3	Individual room control with communication between controllers and to BACS
4	Individual room control with communication and presence control

1434

1435 For each service Task 1 then ascribes an impact (functionality) rating (from 0 to +++) for each impact
 1436 criterion, as shown in Table 3 (for the example above).

1437 *Table 3 - Example of ordinal impact scores per functionality level from Task 1*

Functionality levels		IMPACTS							
		Energy savings on site	Flexibility for the grid and storage	Self generation	Comfort	Convenience	Health	maintenance & fault prediction	information to occupants
level 0	No automatic control	0	0	0	0	0	0	0	0
level 1	Central automatic control (e.g. central thermostat)	+	0	0	+	+	0	0	0
level 2	Individual room control (e.g. thermostatic valves, or electronic controller)	++	0	0	++	++	0	0	0
level 3	Individual room control with communication between controllers and to BACS	++	0	0	++	+++	0	+	0
level 4	Individual room control with communication and presence control	+++	0	0	++	+++	0	+	0

1438

1439 In this illustration of the generic SR methodology these Task 1 functionality rankings per service and
 1440 impact criteria are assumed to be accurate⁴⁰. Furthermore, a priori and for the sake of simplicity, it
 1441 is assumed that each functionality level grading is equivalent across services for any given impact
 1442 criterion. Thus, if a functionality level is graded at +++ for two different services when considering a

⁴⁰ This is a working assumption to permit demonstration of the method. Many of the ordinal scores derived in Task 1 are the study team's own estimates aimed at indicating the relative importance of the (levels of) services on the impact categories and stimulating discussion on this. Some of these values will need to be further quantified in case these specific services are taken into account for an applied methodology.

1443 given impact criterion (e.g. energy savings) then the relative impact is provisionally considered to be
 1444 the same (unless differentiated weightings are subsequently applied as discussed further below).
 1445 This allows the ordinal rankings to be converted into the quasi numerical impact scores shown in
 1446 Table 4.

1447 *Table 4 - Ordinal functionality level rankings mapped to nominal impact scores*

Ordinal ranking	Nominal impact score
++++	4
+++	3
++	2
+	1
0	0
-	-1
--	-2
---	-3
----	-4

1448
 1449 For any given service there is a maximum SR score it is possible to attain for the impact criterion in
 1450 question. When aggregated across all the services these maxima can be used to derive a normalised
 1451 score by dividing the sum of the nominal impact scores by the sum of the maximum possible nominal
 1452 impact scores and multiplying by 100 to attain an overall percentage of the maximum score. This
 1453 process, which produces an overall SRI score for a building, is illustrated in the single family house
 1454 examples shown further below in section 4.2.3. In the current methodological example, the
 1455 maximum is derived by simply summing the potential maximum score for all services. In the later
 1456 section 4.4 which presents a more practical and streamlined version of the generic methodology,
 1457 this approach is further refined, since based on technical considerations a maximum score on all
 1458 criteria is very unlikely⁴¹.

1459 **Broad approach**

1460
 1461 The generic SR methodology organises these elements into a multi-criteria hierarchical decision-
 1462 making model to derive an overall SRI. It does this through a process which evaluates the effect that
 1463 the level of functionality of the SR services have on the chosen impact criteria followed by
 1464 aggregating these into a common score.
 1465

1466
 1467 The methodological steps applied are as follows:

- 1468 • Select the impact criteria to be used (for this illustration they are the same eight as those
 1469 identified in the Task 1 report)
- 1470 • Consider what weighting should be applied to the impact criteria to derive a final SRI (for
 1471 this illustration they are all weighted equally)
- 1472 • Consider the impact that each level of functionality of the SR services has on each chosen
 1473 impact criterion (This illustration uses the gradings (i.e. ----, ---, --, -, 0, +, ++, +++, +++++)
 1474 applied in the Task 1 report as the starting point for this. It then converts them into a
 1475 corresponding numerical score (i.e. -4, -3, -2, -1, 0, 1, 2, 3, 4) and uses this to derive a % score
 1476 by dividing it by the maximum nominal impact score i.e. if the maximum ordinal score it is
 1477 possible to attain for the service/impact criterion/domain combination in question is +++++

⁴¹ As an example, the current list features some services which are specifically geared towards heating boilers, while others focus on heat pumps. In a small scale residential building it is highly uncommon that both systems will be present.

1478 and the score attained by the particular building is + then then maximum nominal score is 4
 1479 and the actual score is 1 thus the normalised score is $\frac{1}{4} = 25\%$.
 1480 • A decision is then required regarding how to weight these scores within domains and across
 1481 domains – in this illustration it is assumed a priori that the scores are directly comparable
 1482 within a domain i.e. should have the same weight for each service considered. In the case of
 1483 cross-domain weightings these are considered to be equal for all the impact criteria in this
 1484 equal weightings case study, but is also reasonable to apply differentiated weightings as is
 1485 considered in the next case study (considered in section 4.2.5).
 1486

1487 **Weighting decisions**

1488

1489 In general, decisions on weightings need to be made on:

- 1490 • The impact criteria (initially eight in the Task 1 report and these are provisionally assumed
 1491 to be equally weighted (i.e. equally important) in this illustration of the generic SR
 1492 methodology)
- 1493 • The domains (these are provisionally assumed to be equally weighted (i.e. equally important)
 1494 in this illustration of the generic SR methodology; however, as this is known not to be the
 1495 case depending on the impact criterion and building type in question a variant is shown
 1496 further below in this section where impacts are weighted by the assumed importance of the
 1497 domain to the impact criteria.
- 1498 • The services considered (presently assumed to be the same as those set out in the Task 1
 1499 analysis and equally weighted)
- 1500 • The functionality levels (presently assumed to be the same as those set out in the Task 1
 1501 analysis with the ordinal rankings also as set out in that report – for this illustration of the
 1502 generic methodology it is assumed that the relative effect of identical service functionality
 1503 grades is the same across different impact criteria, domains and services).
 1504

1505 **Single Family House – case study**

1506

1507 For this example, a case study is examined of a hypothetical semi-smart single family house (SFH).

1508 The house is smart in that it has moderately sophisticated:

- 1509 • heat demand control
- 1510 • heat production control
- 1511 • domestic hot water production control
- 1512 • cooling demand control
- 1513 • lighting occupancy control
- 1514 • window open/closed control, combined with HVAC system
- 1515 • monitoring & control of HVAC systems
- 1516 • reporting information regarding historical energy consumption
- 1517 • EV charging capabilities.

1518 On the other hand, it is not so smart because it has no on-site distributed generation (and hence no
 1519 smart control of this), no DSM capability, and no fault detection capability.

1520

1521 When equal weightings are applied (as discussed previously) this building scores 1.268 out of a
 1522 maximum possible score of 3.513 and thus attains a normalised score of $35.2\% = (100 \times 1.238/3.513)$
 1523 % (see Table 5). Interestingly, while this system applies equal weightings some domains have a larger
 1524 number of SR services than others (e.g. DSM has 17 SR services with a maximum total score of 1.188
 1525 while Lighting has four SR services with a maximum total score of 0.15). This implies that the simple
 1526 process of accounting for the SR services also implies a set of preferences and hence there could be

1527 an argument for setting limits on the relative importance of the domains as well as the impact
1528 criteria.

1529 *Table 5 - Scores attained in equal-weighting single family house case study*

Domain	Actual Scores	Max Possible Scores	Normalised Score
Heating	0.4125	0.6125	67%
DHW	0.1125	0.1125	100%
Cooling	0.1375	0.15	92%
MV	0	0.1	0%
Lighting	0.075	0.15	50%
Dynamic building envelope	0.125	0.175	71%
Energy generation	0	0.1125	0%
Demand side management	0	1.1875	0%
Electric vehicle charging	0.075	0.2125	35%
Monitoring and control	0.3	0.7	43%
Total SRI score	1.2375	3.5125	35.2%

1530

1531 **Differentiated weightings case study**

1532 In the previous case study all aspects in the generic methodology as applied to the Task 1 analysis
1533 were weighted equally, however, this in itself implies a certain set of preferences. In this section a
1534 case study with differentiated weightings is investigated.

1535 Table 6 shows an illustrative set of weightings to be applied at the domain level as a function of the
1536 impact criterion considered. These are not purely arbitrary but rather are selected based on certain
1537 notions and understanding. The weightings applied to energy savings on-site are intended to be fairly
1538 typical of the relative importance of each domain to an average existing European single family
1539 house, although it should be noted they are not typical of new-build and in reality will vary by climate,
1540 culture and other locally pertinent factors. Having noted this, they are presented here simply to
1541 illustrate how weightings can be applied and are in not intended to indicate the most appropriate
1542 values that should be applied. Equal weightings by domain are applied for those impact criteria
1543 where there is currently no information on the relative importance of different domains to the
1544 impact criterion in question. Where a domain is thought to have no importance for the impact
1545 criterion considered it's weighting is set to 0% and the other domain weightings adjusted accordingly
1546 so the total per impact criteria always adds up to 100%. Note, as the generic method is adapted
1547 towards a specific applied method it is expected that specific weightings would be derived as a
1548 function of building type and possibly climate (see section 4.5 on tailoring the SRI); however, it is
1549 equally possible for users of the system to develop their own weightings to reflect their priorities
1550 and locally pertinent factors.

1551 *Table 6 - Domain-level weightings per impact criteria assumed in weighted case study*

Domain	Impact criterion							
	Energy savings on site	Flexibility for the grid and storage	Self generation	Comfort	Convenience	Health	maintenance & fault prediction	information to occupants
Heating	66%	14%	0%	40%	10%	10%	10%	7%
Domestic hot water	18%	14%	0%	10%	10%	10%	10%	7%

Cooling	4%	14%	0%	15%	10%	10%	10%	7%
Controlled ventilation	3%	0%	0%	10%	10%	10%	10%	7%
Lighting	7%	0%	0%	10%	10%	10%	10%	7%
Dynamic building envelope	2%	0%	0%	5%	10%	10%	10%	7%
Energy generation	0%	14%	80%	0%	10%	10%	10%	7%
Demand side management	0%	14%	10%	5%	10%	10%	10%	7%
Electric vehicle charging	0%	14%	10%	0%	10%	10%	10%	7%
Monitoring and control	0%	14%	0%	5%	10%	10%	10%	40%
Total	100%	100%	100%	100%	100%	100%	100%	100%

1552

1553

1554 **Single Family House – case study**

1555

1556 For this example a case study is examined of the same semi-smart single family house considered in
1557 section 4.2.3.

1558

1559 When the differentiated weightings of Table 6 are applied to this building it attains a total SR score
1560 of 2.554 out of a maximum possible score (for a fully smart ready building) of 5.347 and thus a
1561 normalised score of 47.8% = $(100 \times 2.554/5.347)\%$ (see
1562 Table 7).

1563

1564 Interestingly, the application of differentiated weightings by domain can mitigate the impact of the
1565 equal weightings case study approach that could be said to favour domains with more SR services
1566 options. For example although DSM has 17 SR services in both the equal and differentiated weighting
1567 case studies the maximum total score of 0.984 is less for the differentiated weighting case study than
1568 the equal weighting cases study (where it is 1.188). On the other hand the importance of some
1569 domains, such as heating, has increased. Overall the total normalised SR score for this building is
1570 higher than for the equal weightings case which is indicative that the SR functions it has are better
1571 adapted to its needs than the equal weightings approach might imply.

1572

Table 7 - Scores attained in differentiated-weighting single family house case study

Domain	Actual Scores	Max Possible Scores	Normalised Score
Heating	1.698333	2.360833	72%
DHW	0.157857	0.157857	100%
Cooling	0.13375	0.13875	96%
MV	0	0.0825	0%
Lighting	0.0675	0.13125	51%
Dynamic building envelope	0.098333	0.115833	85%
Energy generation	0	0.281548	0%
Demand side management	0	0.983929	0%
Electric vehicle charging	0.05119	0.142857	36%
Monitoring and control	0.347321	0.951786	36%
Total SRI score	2.554286	5.347143	47.8%

1573

1574 **4.2.4. VIABILITY ANALYSIS**

1575 This section presents an initial analysis of factors pertinent to the viability of the generic
1576 methodology.

1577 **Number of SR service functions required to be assessed**

1578 The Task 1 analysis identified 99 (or 112 including the 'various' domain) SR services that in theory
 1579 could have an effect on each impact criterion. It also identified 8 impact criteria which means in
 1580 principle that there could be $8 \times 99 = 792$ individual service impacts to be assessed were a
 1581 comprehensive SR assessment to be made. However, this accounting ignores that many of these
 1582 service functions have no effect on specific impact criteria (i.e. they have a grading of 0 for the
 1583 specific impact criterion considered regardless of the level of functionality they offer).

1584
 1585 *NOTE: Due to time constraints related to the revision of the model numbers mentioned in the*
 1586 *remainder of this section have not been updated since the first progress report with the amended list*
 1587 *of services, although this will be done for the subsequent version. The principles and conclusions they*
 1588 *illustrate remain fully valid though.*

1589
 1590
 1591 Table 8 shows the number of non-zero services (see column headed "100% of the potential total
 1592 impact") for each impact criterion. The impact criteria with the most number of non-zero (i.e.
 1593 impactful) services are Comfort (which has 70) and the one with the least is Health and Wellbeing ,
 1594 which has 18. In total there are 377 non-zero (i.e. impactful) services across the 8 impact criteria in
 1595 the Task 1 analysis. Nonetheless, not all of these non-zero services provide the same impact for any
 1596 given impact criterion, thus they are not equally important in determining the overall SR impact per
 1597 impact criterion. Figure 5 to Figure 12 show how the proportion of total SR impact varies as a function
 1598 of the number of services assessed when the service impacts are ordered in sequence of those with
 1599 the most impact to those with the least impact. Table 8 also indicates the number of services
 1600 necessary to be assessed to attain 100%, 80% or 50% of the total impact per impact criterion.

1601
 1602 This analysis is important because any practical SRI scheme will be constrained by time and resources
 1603 and thus there is likely to need to be a basis for prioritising which SR services should be assessed in
 1604 practice and which offer more marginal benefits. From this analysis it can be seen that were it
 1605 required to determine 100% of the potential SR impact over the 8 impact criteria 377 services would
 1606 need to be assessed, whereas the number falls to 246 and 13 respectively if 80% or 50% of the total
 1607 impact is required. Alternatively, another means of reducing the number of services requiring
 1608 assessment would be to omit certain impact criteria from the assessment. E.g. if only energy savings
 1609 (to 80% of the potential total impact), flexibility for the grid (to 50% of the potential total impact),
 1610 convenience (to 50% of the potential total impact) and information to occupants (to 50% of the
 1611 potential total impact) to be included then the total number of services requiring assessment would
 1612 fall to 74 (= 15+15+25+19). Of course there are other alternative approaches that could be applied
 1613 to reduce the number of SR services to be assessed. These could include setting a maximum number
 1614 of services to be assessed per impact criteria (e.g. the 10 with the highest impact per criterion) or
 1615 applying differentiated impact criteria weightings and then ordering all the services to identify those
 1616 that have the highest total impact across the impact criteria and selecting a given number of those
 1617 to be assessed (e.g. the top 50). It is also expected that in practice this list would vary by building
 1618 type. These issues are considered further in sections 0 and 4.4.


1619 *Table 8- Sensitivity of the total impact score to the number of SR services assessed*

Impact parameter	No. of SR service functions required to be assessed to determine		
	100% of the potential total impact	80% of the potential total impact	50% of the potential total impact

Energy savings	58	15	8
Flexibility for the grid	44	32	15
Self-generation	30	23	12
Comfort	70	48	25
Convenience	66	44	25
Health and Wellbeing	18	13	7
Maintenance & fault prediction	44	35	20
Information to occupants	47	36	19
All	377	246	131


1620
1621

1622 *Figure 5 - Share of energy savings impact attained as a function of the number of SR services assessed*




1623
1624

1625 *Figure 6 - Share of grid flexibility impact attained as a function of the number of SR services assessed*



1626
1627


1628 *Figure 7 - Share of self-generation impact attained as a function of the number of SR services assessed*



1629
1630

1631


Figure 8 - Share of comfort impact attained as a function of the number of SR services assessed



1632
1633

1634


Figure 9 - Share of convenience impact attained as a function of the number of SR services assessed



1635
1636

1637

Figure 10 - Share of health impact attained as a function of the number of SR services assessed




1638

1639

1640

Figure 11 - Share of maintenance & fault prediction impact attained as a function of the number of SR services assessed

1641




1642

1643

1644
1645

Figure 12 - Share of information to occupants' impact attained as a function of the number of SR services assessed




1646
1647

1648 In aggregate, the same analysis can be done to see the sensitivity of the total SRI score to the number
1649 of services assessed, as is shown in Figure 13 and Figure 14 for the equal and differentiated
1650 weightings services respectively. For the equal weightings case 80% of the total SRI is captured by
1651 the top 63 most important SR services. For the differentiated weightings case it is by the top 62 most
1652 important SR services. The gentleness of the curve in both cases indicates that selection of the
1653 services to be assessed in order of their impact on the total SRI score only offers a modest potential
1654 to reduce the number of services requiring assessment for a given quality of SRI score i.e. the share
1655 of the total SRI score determined per tranche of services assessed is relatively constant; however,
1656 this is only the case when it is assumed that all of the services are pertinent and that there is no
1657 causality between them (both issues examined below).

1658


1659 For simpler buildings, such as residential buildings, this assumption is especially unlikely to be true
1660 and thus there is potentially much greater potential to reduce the number of SR services that need
1661 to be assessed. Figure 15 and Figure 16 show the equivalent data to Figure 13 and Figure 14 but for
1662 the explicit hypothetical single family house case study considered in section 4.2.3 respectively.

1663 *Figure 13 - Share of total SR impact attained as a function of the number of SR services assessed for the equal*
1664 *weightings case study*



1665
1666

1667 *Figure 14 - Share of total SR impact attained as a function of the number of SR services assessed for the*
1668 *differentiated weightings case study*




1669
1670

1671 For both the equal and differentiated weightings single family home case studies respectively it is
1672 only necessary to assess 40 of the 92 possible services to attain the full SR impact for a fully smart
1673 home. This is because 52 of the comprehensive list of SR services are (provisionally) not considered

1674 to be pertinent to the typical single family home case and hence allow a considerable reduction in
1675 the expected assessment effort. Nonetheless, there is not much sensitivity to the priority given to
1676 the SR services assessed which indicates that further reduction in the number of SR services included
1677 in the assessment would entail a significant information loss for the SRI unless whole classes (e.g.
1678 whole domains) were to be excluded.


1679 *Figure 15 - Share of total SR impact attained as a function of the number of SR services assessed for the equal*
1680 *weightings case study*



1681

1682
1683

Figure 16 - Share of total SR impact attained as a function of the number of SR services assessed for the differentiated weightings case study



1684
1685

1686

Causality between service functionality across impact criteria

1687
1688
1689
1690
1691
1692
1693
1694
1695

The previous analysis assumed that service functionality levels are independent of each other from one impact criterion to another; however, this is not necessarily the case. In cases where it can be shown that providing a service functionality level with a specific impact rating for a given impact criterion automatically leads to a specific rating for a different impact criterion then an auto-completion scoring approach can be used for the second impact criterion (i.e. it is not necessary to do a separate and independent assessment). In principle, this could also apply to other impact criteria and could allow a significant economy in the total assessment time required to attain a given amount of SR impact information.

1696 **4.3. PRACTICAL CONSIDERATIONS**

1697 This section introduces the reality checks that would need to be taken into account to implement an
1698 actual SRI and how these are likely to filter the elements that can be operationalised.

1699 **4.3.1. PRACTICAL ELEMENTS THAT AFFECT THE ABILITY TO IMPLEMENT AN SRI**

1700 To be able to implement an SRI it is necessary that:

- 1701 • smart readiness service functionality is defined and that impacts can be ascribed to the level
- 1702 of functionality delivered
- 1703 • it is technically feasible to conduct an assessment
- 1704 • the time/cost of assessment is acceptable
- 1705 • the building occupants are willing to allow access for an assessment to be conducted
- 1706 • the information derived is assessable and understandable for the target audience.

1707

1708 *Ability to define functionality and ascribe impact outcomes to the function*

1709 If the SRI is to have solid technical foundations then it is essential that smart service functionality
1710 and functional levels can be defined and that impacts can be ascribed to those levels with a
1711 reasonable degree of confidence. Although the Task 1 smart readiness service catalogue defines a
1712 set of smart readiness services, functionality levels and impacts part of this is not founded on EU,
1713 international or national standards but rather is based on the study team's considered opinion.
1714 Wherever possible the functionality has been linked to definitions provided in standards but the
1715 reality is that many of the smart readiness services identified are not yet defined in standards
1716 anywhere. When they exist most standards will define services and functionalities but relatively
1717 ascribe performance levels and impacts to functionality. A notable exception, much used in this
1718 methodology, is EN15232-1:2017 *Energy performance of buildings. Impact of Building Automation,*
1719 *Controls and Building Management*. This standard not only defines services for BACS, but also defines
1720 functionality levels for each and presents a simplified method to ascribe energy savings impacts to
1721 those functionality levels (via the so-called BACS factor method) that is based on hundreds of
1722 TRANSYS building energy performance simulations. This is used in the methodology presented here
1723 to ascribe energy savings impacts to BACS related smart services and as such the impacts associated
1724 with this standard are the most reliable of all those reported in the Task 1 smart services catalogue.
1725 Note, the BACS factor method is not as reliable as the full impact assessment methods presented in
1726 the standard (which rely on detailed application of the suite of other building energy performance
1727 standards pertaining to each TBS) but the full methods are far too time consuming and involved to
1728 be imaginable for application in an SRI.

1729

1730 *Technical feasibility of conducting an assessment*

1731 The technical capability to assess a smart readiness service and determine its level of functionality is
1732 key to being able to implement an SRI. If a service cannot be assessed it cannot be ranked and
1733 included in a scoring system. The experience is mixed with the smart readiness services reported in
1734 the Task1 catalogue. Many are not in standards and there is thus no documented experience of trying
1735 to assess them. Those which are defined in standards are more likely to have some practical
1736 experience of being assessed. This is the case for the BACS services defined in EN15232 and eu.bac⁴²
1737 among others have developed a certification scheme based on these. In these cases there is good
1738 degree of confidence in the ability to conduct a technical assessment. For other smart services, which

⁴² cert.eubac.org/

1739 are not defined in standards, this has to be imagined and has not yet been put to the test. The
 1740 findings in this regard are therefore somewhat speculative.

1741

1742 *Time and cost of making an assessment*

1743 If it takes too long and hence is too costly and inconvenient for an SRI assessment to be made then
 1744 the practical acceptability of the SRI will be insufficient and the benefit-reward ratio will be deemed
 1745 unfavourable. There is relevant experience from EPCs and from the eu.bac voluntary certification
 1746 scheme of the length of time it takes to conduct an assessment of technical building systems and
 1747 BACS which has been leveraged for the estimates provided in the methodology discussions. In
 1748 general, the assessment time needed for any given smart service will depend on how easy it is to
 1749 locate and identify the smart service and then to determine its functional capabilities. This process
 1750 can be facilitated by the availability of technical documentation and information indicated on the
 1751 products or displays concerned. It will also depend on the expertise and competence of the assessor.
 1752 While most smart services can be found in a single physical location (e.g. a control point, display
 1753 panel or plant room) some are distributed throughout a building and require room-by-room
 1754 inspection. These are likely to be more time consuming to assess although often they are also
 1755 comparatively simple to inspect visually (e.g. lighting is controlled by presence detection or not). By
 1756 contrast some of other services listed in the Task 1 catalogue will be very challenging to assess
 1757 without some kind of facilitation.

1758

1759 *Willingness to grant access*

1760 If assessments require physical inspection and on-site presence then it is necessary for inspectors to
 1761 be granted access and the right to conduct an assessment by the building occupants. This can be one
 1762 of the more challenging aspects and is especially the case when the assessment is not legally
 1763 enshrined, as it is for the EPCs. The willingness of occupants to grant access may be partly conditional
 1764 on the value added that they perceive the SRI to offer them. Thus inspection access is likely to be
 1765 sensitive to this aspect. Retrieving access can be especially challenging in multi-tenant buildings for
 1766 which communal TBS need to be assessed, e.g. heating installations in a technical room which is not
 1767 directly accessible by all tenants.

1768

1769 *Ability of the target audience to assess the SRI information*

1770 The degree to which the target audience can assess the SRI information it is presented will also affect
 1771 the degree to which the SRI scheme is successful or not. If the information is not comprehensible
 1772 and is meaningless to them then it will have a very limited motivational impact and be a weak change
 1773 agent. Again there is experience of the extent to which users process the information in EPCs that
 1774 can partly inform this determination, but it is likely that any prospective SRI would need to be pilot
 1775 tested prior to full implementation to ensure it satisfies minimum comprehension and interpretation
 1776 criteria.

1777

4.3.2. REVIEW OF THE MATURITY OF THE TASK 1 ELEMENTS

1778 The maturity of each of the smart readiness services cited in the Task 1 catalogue is reviewed and
 1779 reported in Annex F (see below). This review considers the factors which determine the degree to
 1780 which these services are mature enough to be deployed within a practical SRI scheme. For each
 1781 service the review considers:

- 1782 • the degree to which the functionality of the service is described and defined in standards
 1783 or a commonly adopted methodological framework, or is still nebulous and in need of
 1784 definition

- 1785 • the degree by which the impact can be ascribed to the functionality
- 1786 • the basis by which the impacts associated with the functionality may be determined
- 1787 • the degree to which the functionality can be determined by inspection.

1788 In general it is found that the degree to which the functionality of the services are defined in
1789 standards or a commonly accepted methodological framework is high for the classic TBS domains
1790 (heating, DHW, cooling, controlled ventilation and lighting) and is low for the services in the other
1791 domains except for about half the services in the Monitoring & Control domain. There are almost no
1792 relevant standards and common methodological frameworks for the DSM services and only two
1793 partially applicable standards/frameworks for the Electric Vehicle (EV) domain.

1794
1795 This also strongly influences the degree of confidence that can be had in the estimation of the
1796 impacts associated with the functionality levels. With the exception of the energy savings on site
1797 impacts for the BACS defined in EN15232 almost all the other impacts are based on the provisional
1798 expert opinion of the study team. Clearly, more work would be needed for the level of confidence in
1799 the impacts ascribed to be increased. In this respect, feedback from stakeholders is also very much
1800 likely to help.

1801
1802 The degree to which the services can be assessed varies with the lower level (less smart) services
1803 being more straightforward to assess visually than some of the higher level services, which can be
1804 sensitive to the nature of the control algorithms applied. A general observation, stretching across all
1805 the smart readiness domains, is that when smartness depends on the capability associated with a
1806 control algorithm that it will not be straightforward to assess. As a result, many of the capabilities
1807 defined here will need classification and indication, or some smart signalling and reading device, to
1808 enable an inspector to assess their capability.

1809
1810 Considering these aspects it is evident that attempting to apply the SRI methodology to all the smart
1811 readiness services cited in the Task 1 catalogue is not currently viable for a practical scheme. Many
1812 of the smart readiness services cited are poorly defined and in a non-standardised/commonly
1813 agreed, manner. When this is the case the confidence with which their functionalities can defined is
1814 low and the confidence with which impacts can be ascribed to the functional levels is also low. The
1815 ambiguity surrounding these aspects also reduces the viability of making an assessment of these
1816 services and renders the time required to inspect them unacceptably high. As a consequence, it is
1817 necessary to streamline and rationalise the Task 1 smart readiness services in such a way that would
1818 allow them to be used in a viable scheme.

1819 **4.4. STREAMLINING THE SMART READY SERVICE CATALOGUE**

1820 This section examines how the generic SRI can be streamlined to make a practical smart readiness
1821 indicator.

1822 **4.4.1. STREAMLINING THE SRI ELEMENTS**

1823 This paragraph applies the Annex F review findings on the Maturity of Task 1 elements reported in
1824 section 4.3.2 and proposes a reduced and restructured set of services that could be immediately
1825 viable (i.e. technically and feasibly actionable) within an SRI today. It conducts a screening process
1826 to make this assessment that is informed by the practicality considerations set out in section 4.3.1.
1827

1828 This reduced/amalgamated set of services that have been retained after this screening process are
 1829 then applied in two building case studies presented in sections 4.3.2 to determine and illustrate their
 1830 viability in terms of being able to be assessed, and the management of assessment time/costs/and
 1831 site-access.

1832
 1833 In principle, the methodology can be streamlined by the omission of services, the restructuring of
 1834 services, and the application of logical triage processes. Services could be omitted if they are
 1835 irrelevant or have a very modest impact. In addition, services whose attribution of impacts is not yet
 1836 fully developed or confirmed could also be omitted. As this streamlined methodology is intended to
 1837 be actionable at the present time then any service that is currently too poorly defined and too
 1838 difficult to be assessed should be omitted until it is sufficiently mature to be included. Restructuring
 1839 of services could be considered when the restructuring: improves the clarity regarding the service's
 1840 functionality and impacts, when it helps to focus on the main impact and saves assessment time.
 1841 Triage can be helpful in optimising the assessment process and thereby saving assessment time. With
 1842 these thoughts, and the findings from the maturity review of section 4.3.2, in mind the remainder of
 1843 this section proposes appropriate streamlining actions to be taken in to the streamlined SRI
 1844 methodology.

1845 **Heating domain**

1846 Most of the heating services are actionable, defined in standards and have impacts (at least in terms
 1847 of energy savings) that are attributable to their functionality levels. The exceptions are:

- 1848 • Heating 2d - *Heat system control according to external signal*
- 1849 • Heating 2e - *Heat recovery control (e.g. excess heat from data centres).*
- 1850 • Heating-3 - *Report information regarding heating system performance*

1851
 1852 Were any to be omitted on the grounds of low relevance they would be:

- 1853
- 1854 • Heating-1b: Emission control for TABS (heating mode)
- 1855 • Heating-1f: Thermal Energy Storage (TES) for building heating
- 1856 • Heating-1d: Control of distribution pumps in networks
- 1857 • Heating-2c: Sequencing of different heat generators
- 1858 • Heating-2d: Heat system control according to external signal (e.g. electricity tariff, gas
 1859 pricing, load shedding signal etc.)
- 1860 • Heating-2e: Heat recovery control (e.g. excess heat from data centres)

1861
 1862 However, the TABS, TES and heat recovery services are relevant if these systems are present and it
 1863 is only because they are rare that they are less relevant to typical buildings today. Sequencing of heat
 1864 generators is only relevant when multiple generators are present, which is often restricted to large
 1865 buildings. Good control of distribution pumps can save a significant proportion of pumping energy
 1866 but this is less important than the main heating loads.

1867
 1868 Heating 2d - Heat system control according to external signal (e.g. electricity tariff, gas pricing, load
 1869 shedding signal etc.). This is a partial DSM partial Monitoring & Control feature and hence should be
 1870 viewed under these sections. For convenience it makes sense to move it to the M&C section;
 1871 however, it should be noted that there is no standard or agreed protocol available to define this
 1872 service.

1873

1874 Heating 2e - Heat recovery control (e.g. excess heat from data centres). Heat Recovery is addressed
 1875 under EN15232 for Mechanical (Controlled) Ventilation and has been revised in the 2017 edition.
 1876 Other specific heat recovery systems (such as heat recovery from data centres) only come into play
 1877 for some specialised buildings and risk to overburden the assessment process. As a result, this service
 1878 is simplified to only encompass ventilation heat recovery, and hence moved into the ventilation
 1879 section and reformulated in line with EN15232:2017.

1880

1881 Heating-3 - *Report information regarding heating system performance* has been introduced since
 1882 the first progress report. It links the information reporting function to the TBS in question (the same
 1883 approach is done for DHW and cooling) but was previously partially covered in a non-TBS specific
 1884 manner under Monitoring & Control. While there is no established standard or protocol addressing
 1885 how this should be done the descriptions of the functionality are unambiguous and it should be
 1886 straightforward to assess.

1887

1888 The other services (including 1b, 1d, 1f, and 2c) are clearly actionable so there is little reason to omit
 1889 any of these from the streamlined methodology, providing sensible triage is deployed as now
 1890 discussed.

1891 → **Triage**

1892 *Heating type*

1893 Is heating present? If not ignore the whole TBS. If it is assess if it is supplied by Combustion, District
 1894 Heating, Electric Resistance, Heat Pump, Solar or a combination thereof?

1895 • Assuming combustion ignore: Heating 2b

1896 • Assuming heat pumps ignore: Heating 2a

1897 • Assuming district heating ignore: Heating 2b

1898 • Assuming electric resistance ignore: Heating 2a, Heating 2b

1899 • Is there only one heat source? If so ignore Heating 2c

1900 *Estimated time required to make triage = 4 mins*

1901

1902 *TABS/TES*

1903 Is TABS present? If not ignore Heating 1b, Cooling 1b

1904 Is TES present? If not ignore Heating 1f, Cooling 1g

1905 *Typical time required to make triage = 1 min*

1906 **DHW domain**

1907 The first four (of six) DHW services all apply to storage based DHW systems thus a simple triage will
 1908 avoid the need to assess them if storage is not present.

1909

1910 All the services except DHW-1c and DHW-3 are defined in standards, are actionable and have
 1911 attributable impacts; however, determining capabilities without supporting documentation could be
 1912 challenging.

1913

1914 DHW-1c - *Control DHW production facilities* is no longer included in the latest version of EN1532 and
 1915 hence is not clear if this is still an actionable service.

1916

1917 DHW-3 - *Report information regarding domestic hot water performance* has been introduced since
 1918 the first progress report. It links the information reporting function to the TBS in question (the same

1919 approach is done for heating and cooling) but was previously partially covered in a non-TBS specific
 1920 manner under Monitoring & Control. While there is no established standard or protocol addressing
 1921 how this should be done the descriptions of the functionality are unambiguous and it should be
 1922 straightforward to assess.

1923
 1924 DHW-2 - *Control of DHW circulation pump* is defined within EN15232 but is likely to be of limited
 1925 relevance and difficult to assess therefore it is omitted from the streamlined method.

1926 → **Triage**

1927 Is DHW storage present? If not ignore all DHW storage-related services (lines 16-20).

1928 *Typical time required to make triage = 1 min*

1929 **Cooling domain**

1930 With the partial exception of Cooling-3 *Report information regarding cooling system performance* all
 1931 the cooling services are actionable, defined in standards and have impacts (at least in terms of energy
 1932 savings) that are attributable to their functionality levels. Were any to be omitted on the grounds of
 1933 low relevance they would be:

- 1934
- 1935 • Cooling-1b: Emission control for TABS (cooling mode)
 - 1936 • Cooling-1g: Thermal Energy Storage (TES) for building cooling
 - 1937 • Cooling-1d: Control of distribution pumps in networks
 - 1938 • Cooling-2b: Sequencing of different cooling generators

1939
 1940 However, the TABS, TES and heat recovery services are relevant if these systems are present and it
 1941 is only because they are rare that they are less relevant to typical buildings today. Sequencing of
 1942 cooling generators is only really found in very large buildings but is relevant when multiple
 1943 generators are present. Good control of distribution pumps can save a significant proportion of
 1944 pumping energy but this is less important than the main heating loads.

1945
 1946 Cooling-3 - *Report information regarding cooling system performance* has been introduced since the
 1947 first progress report. It links the information reporting function to the TBS in question (the same
 1948 approach is done for heating and DHW) but was previously partially covered in a non-TBS specific
 1949 manner under Monitoring & Control. While there is no established standard or protocol addressing
 1950 how this should be done the descriptions of the functionality are unambiguous and it should be
 1951 straightforward to assess.

1952
 1953 All the services are clearly actionable so there is little reason to omit any of these from the
 1954 streamlined methodology, providing sensible triage is deployed as now discussed.

1955 → **Triage**

1956 *Cooling type*

1957

1958 Is cooling present? If not ignore all cooling services.

1959 *Time required to make triage = 1 min*

1960

- 1961 Is there only one cooling generator? If so ignore Cooling 2b
 1962 *Time required to make triage < 1 min*
 1963
 1964 *TABS/TES*
 1965 Is TABS present? If not ignore Cooling 1b
 1966 Is TES present? If not ignore Cooling 1g
 1967 *Typical time required to make triage = 1 min*

1968 **Controlled ventilation**

- 1969 Most of the ventilation services are actionable, defined in standards and have impacts (at least in
 1970 terms of energy savings) that are attributable to their functionality levels. None should evidently be
 1971 omitted on the grounds of low relevance except potentially:
 1972
 1973 Ventilation 2b - *Room air temp. control (Combined air-water systems)* – which has modest impact
 1974 and is likely to be difficult to assess (it concerns the levels of coordinated control within combined
 1975 air-water systems)
 1976
 1977 Ventilation-5 for *Humidity control* and Ventilation-6 on *Reporting information regarding Indoor Air*
 1978 *Quality* are services have been added to the Task 1 services catalogue since the first progress report.
 1979 These two services are not yet defined in standards or any commonly available evaluation protocol.
 1980 In the case of the humidity control the functional levels could be difficult to assess so for now is
 1981 omitted from the streamlined methodology; however, the information reporting functional levels
 1982 are unambiguous and hence can safely be retained.
 1983
 1984 *Ventilation 4 – Heat recovery control: icing protection* is defined in EN15232 but has rather modest
 1985 impacts. It may therefore be a candidate for omission from the streamlined methodology.

1986 → **Triage**

- 1987 Is controlled ventilation present (in any central form) if not ignore all CV services.
 1988 *Typical time required to make triage = 1 min*
 1989
 1990

1991 **Lighting**

- 1992 Lighting is a moderately important energy use in households but is important in non-residential
 1993 buildings. If a walk-through inspection is required it could be somewhat time consuming so some
 1994 may consider it is a moot issue whether lighting should be assessed in households. Nonetheless it is
 1995 kept in the streamlined methodology for all building types. In part this is because it is certainly
 1996 technically assessable. Note, the energy savings impacts ascribed to good lighting control solutions
 1997 in EN15232 seem very conservative against those that can be derived from EN15393 and were
 1998 reported in the Lot 37 Ecodesign Lighting Systems study. It is likely then that the impacts are greater
 1999 than currently captured in the Task 1 catalogue and SRI methodology.
 2000
 2001 All of the three lighting services are actionable, defined in standards and have impacts (at least in
 2002 terms of energy savings) that are attributable to their functionality levels. None should evidently be

2003 omitted on the grounds of low relevance although the impacts of the Lighting-1b *Mood and time*
 2004 *based control of lighting in buildings* service are somewhat less than the others.

2005
 2006 Lighting-1b *Mood and time based control of lighting in buildings* has been altered since the first
 2007 progress report so that its impacts are framed in terms of the EN 15193-1, CEN-TR 16791 and EN
 2008 12464-1 standards. While these are helpful they do not avoid the need for a walkthrough assessment
 2009 which could be deemed to be too high of an assessment burden for inclusion in the streamlined
 2010 methodology.

2011

2012 → **Triage**

2013 Determine if any lighting has presence or daylight level detection.
 2014 *Typical time required to make triage = uncertain (depends on availability of documentation and floor*
 2015 *areas)*
 2016 *Note that this service can typically differ amongst rooms in a building. In principle, this can be dealt*
 2017 *with by assessing the services on room level and eventually calculating a surface-weighted overall*
 2018 *score. Such endeavour can however greatly affect the inspection time. Experience with EPC*
 2019 *certification schemes have highlighted that measuring all floor surfaces or counting all lighting*
 2020 *fixtures of a given type can require substantial amounts of time. It is therefore advisable that in the*
 2021 *rollout of a SRI, inspection protocols define criteria to allow for inspecting only the main lighting types.*

2022 **Dynamic building envelope**

2023 DE1- *Window solar shading control* is (mostly) defined in standards and has impacts (at least in terms
 2024 of energy savings, comfort and health & wellbeing (avoidance of overheating and glare)) that are
 2025 largely attributable to the functionality levels. However, this service has added a final functionality
 2026 level of *Predictive blind control* which does not feature in EN15232 and hence, while in principle this
 2027 should have the greatest impact on energy, comfort and convenience the increase in effect has not
 2028 been simulated in the same way the other functionality level options have been.

2029
 2030 The following two DBE services are not yet defined in any standards or commonly accepted
 2031 protocols.

2032
 2033 DE2- *Window open/closed control, combined with HVAC system*

2034 DE3- *Changing window spectral properties*

2035

2036 It is thought feasible (albeit it needs to be verified) to inspect whether the windows open or close in
 2037 response to the HVAC control and thus this service is added compared to the first progress report.
 2038 Inspecting the spectral properties of windows may be too challenging and time consuming, however,
 2039 and to this service is currently omitted from the streamlined SRI due to being difficult to action.
 2040 Neither service should evidently be omitted on the grounds of low relevance.

2041

2042 → **Triage**

2043 If no DBE features (e.g. blinds, automated window opening or spectrally controlled windows) omit
 2044 all DBE services.

2045 *Typical time required to make triage = 3 min*

2046 **Energy generation**

2047 If there is energy generation on site then unfortunately there are currently no set of standards or
 2048 commonly used protocols applicable to address EG1 – EG5 (EG1- *Amount of on-site renewable energy*
 2049 *generation*, EG2-*Local energy generation information*, EG3- *Storage of locally generated energy*, EG4-
 2050 *Optimizing self-consumption of locally generated energy*, EG-5- *CHP control*) thus the assessment of
 2051 these capabilities is currently challenging. The EG1 service simply quantifies how much RES is
 2052 produced and hence is not really a smart service but a generation quantification service. EG2
 2053 concerning local energy generation information is important, essentially encompasses the service in
 2054 EG 1 and should be feasible to assess despite the lack of standrads or protocols, so it is proposed to
 2055 include this within the streamlined service subject to its practicality being verified. For EG 3 it should
 2056 also be possible to assess if there is on site storage or not so this is also included. For EG 4 and 5 the
 2057 assessment may be too challenging so these need further investigation before their status within the
 2058 streamlined methodology is confirmed.

2059

2060 Note, in the case of EG4-*Optimizing self-consumption of locally generated energy* service assumes
 2061 this is a goal whereas it could be argued that economic optimisation of EG in a way that optimises
 2062 the proportion of generation used for self-consumption, self-storage and selling into the grid (locally
 2063 or more widely) would be more indicative of user needs. Thus, the relevance of its inclusion may not
 2064 be deemed sufficient by all parties.

2065

2066 Overall the number of energy generation services included since the first progress report has been
 2067 expanded to provide more balance across the domains; however, there is a need to verify the
 2068 actionability of some of these services before a definitive decision is made. If future standardisation
 2069 efforts provide more sophisticated definitions and classification of self-generation smart services
 2070 then these could be integrated into future versions of the streamlined SRI.

2071 → **Triage**

2072 If no on-site energy generation (or storage thereof) capabilities omit all EG services.

2073 *Typical time required to make triage = 2 mins*

2074

2075 **DSM**

2076 From the current list of 21⁴³ separate DSM services defined within the revised Task 1 services
 2077 catalogue, currently only one of the services is supported by standards or an agreed assessment
 2078 protocol. This means the services are weakly defined, very hard (if not impossible) to assess and have
 2079 rather low confidence in the attribution of impacts to functionality levels. The only DSM capability
 2080 within buildings that is currently standardised is from EN15232:2017 as follows:

⁴³ Note the services are listed from 1 to 22 but the service DSM-16 that was included in the first progress report has since been deleted

2081

Table 9 – Standardised DSM service

7.5	Smart Grid integration							
0	No harmonization between grid and building energy systems; building is operated independently from the grid load							
1	Building energy systems are managed and operated depending on grid load; demand side management is used for load shifting							

2082

2083

2084

2085

2086

2087

2088

2089

2090

2091

2092

2093

2094

2095

2096

2097

2098

2099

2100

2101

2102

2103

2104

2105

2106

2107

2108

2109

2110

2111

2112

2113

2114

2115

2116

2117

2118

2119

2120

2121

2122

2123

2124

This simplified service has been incorporated into service DSM-18 on *Smart Grid Integration* although this is very aggregate and thus will not, by itself, capture much of the potential DSM functionality that is an important driver of grid flexibility. It does, however, capture the essential distinction of whether the building is capable of smart grid integration or not, although it does not distinguish which services can be integrated and to what degree. Thus it could be argued that the SRI should (or must) aim to capture the most pertinent DSM grid balancing capabilities, which would currently seem to pertain to DSM control of Heat Pumps, DHW and potentially smart appliances (DSM 4 and DSM 14). Note, while electric vehicles are also very important for grid-balancing they are discussed under that domain heading.

In the first progress report it was suggested that for DSM control of heat pumps the functionality could be defined as:

0: Simple control with fixed thermostat

1: Room thermostat with schedules

2: Heating control managed by input from apps, connected agenda's or presence detection

3: Optimisation of the heating demand inside the building

4: Optimisation taking into account external (price) signals

And that a similar list could also be made for DHW. An alternative approach was also suggested of adding the level four functionality (4: Optimisation taking into account external (price) signals) into the relevant services for heat pumps (in the heating and cooling domains) and the DHW domains although this risks diluting the current TBS specific services which are based on established standards. In the end a different approach is advocated as expounded in this section further below.

In the case of smart appliances, although much work is on-going it is yet to produce applicable results.

Note:

DSM 7 *Fault location and detection* largely overlaps with MC 4 Fault Detection – and as the latter is based on EN15232:2017 the former (which has no supporting standard) can be omitted.

DSM-16 *Charging EV for a certain range* – is partially covered in the EV section and hence can be omitted.

DSM-5 *Power flows measurement and communications*, DSM-6 *Energy delivery KPI tracking and calculation*, DSM-11 *Demand prediction*, DSM-12 *Renewables generation prediction* and DSM-17 *Energy storage penetration prediction* have significant overlap with the Monitoring & Control *Feedback and reporting* functions of MC 5-7 and hence could be merged into those within one aggregate assessment process – see M&C discussion below.

The other DSM functions cited are rather more niche and less central to the principal grid-balancing functionality in the Commission's tender document.

2125 → **DSM Conclusion**

2126 For the streamlined SRI replace the original current Task 1 DSM service listing with the following four
 2127 DSM services, numbers DSM 18, 19, 21 & 22 respectively, as shown in Table 10.

2128 *Table 10 - DSM services*

Service	Level 0	Level 1	Level 2	Level 3	Level 4
Smart Grid Integration	No harmonization between grid and building energy systems; building is operated independently from the grid load	Building energy systems are managed and operated depending on grid load; demand side management is used for load shifting			
DSM control of equipment	Not present	Smart appliances and/or DHW subject to DSM control	Heating or cooling subject to DSM control	Heating and cooling subject to DSM control	Heating, cooling, DHW and appliances subject to DSM control
Reporting information regarding DSM	None	Reporting information on current DSM flows and controls	Reporting information on current, historical and predicted DSM flows and controls		
Override of DSM control	No occupant override	Manual override and reactivation	Scheduled override of DSM control and reactivation	Scheduled override of DSM control and reactivation with artificial intelligence	

2129 Although the DSM control of equipment service is not supported by standards it should still be
 2130 assessable and captures the main value proposition regarding the degree to which equipment that
 2131 could have an impact on grid-balancing is able to do so. The attribution of impacts to these
 2132 functionality levels remains arbitrary but they are correctly ordered in terms of their likely scale of
 2133 grid-balancing capability for most building types. Note, since the first progress report this service has
 2134

2135 been slightly amended to have a more logical progression of functionality and is included in the
2136 revised service catalogue as DSM-19 *DSM control of equipment*.

2137

2138 DSM-21 on *Information regarding DSM* and DSM-22 on *Override of DSM control* are thought to be
2139 highly relevant and should be feasible to assess in an unambiguous manner although this will need
2140 to be verified.

2141 → **Triage**

2142 If no smart grid integration or DSM control of equipment are present omit all DSM services.

2143 *Typical time required to make triage = 1-4 minutes if documentation or building managers can be*
2144 *consulted.*

2145 **Electric Vehicles**

2146 Like the DSM section the services listed for EVs are not defined in any standards or protocols. In
2147 principle, the key smart building service capabilities needed to support E-mobility are:

- 2148 • charging capability (which is the product of the no. of assessable charge points and their
2149 charging speed)
- 2150 • communication and control to enable the most economic charging (e.g. to support grid
2151 balancing via optimisation in response to network price signals)
- 2152 • bi-directional communication and control to allow the EV batteries to sell power to the grid
2153 and be managed as part of an EV battery network to support grid balancing via
2154 optimisation in response to network price signals.

2155 Even these functions are only partly defined in standards or protocols (e.g. charging modes (but not
2156 full capabilities) are defined in IEC 61851-1-2017 (3rd Edition, February 1, 2017): *Electric vehicle*
2157 *conductive charging system – Part 1: General requirements*. While communication capabilities of
2158 Electric Vehicles and Electric Vehicle Supply Equipment (EVSE) is set out in ISO/IEC/DIS 15118(E) *Road*
2159 *vehicles – Vehicle to grid communication interface – Part 1: General information and use-case*
2160 *definition* (which also details certain services).

2161

2162 Given that the principal goals are to promote E-mobility by facilitating convenient vehicle charging
2163 and to manage EV charging/storage in ways that support grid-balancing and RES penetration it is
2164 proposed to completely restructure the Task 1 EV services to reflect this as best as possible within
2165 the current state of the art by two simplified services as shown in the first two rows of Table 11:

2166

Table 11 - EV services

Service	Level 0	Level 1	Level 2	Level 3
Charging	Not present	Low charging capacity	Medium charging capacity	High charging capacity
Grid balancing	Not present	1 way (controlled charging)	2 way (also EV to grid)	/
EV Charging - connectivity	EV charging information	No information available	Reporting information on EV charging	Communication with a back-

	and connectivity		status occupant	to	office compliant to ISO 15118
--	------------------	--	-----------------	----	-------------------------------

2167

2168 Since the first progress report the first two services have been brought into the revised service
 2169 catalogue as EV-15 and EV-16 respectively. The charging capacity referenced in EV-15 is yet to be
 2170 fully defined but could be via the development of a simple algorithm reflecting the charging speed
 2171 of the available sockets (which will partly correlate to the IEC 61851-1-2017 charge modes 1 to 4)
 2172 and the number of available sockets (normalised to the building type or area). This capability really
 2173 only has an impact on the Energy, Flexibility (as a necessary but insufficient condition) and
 2174 Convenience impact factors.

2175

2176 The grid balancing capability of EV-16 (which would complete the grid-balancing impact of the
 2177 charging service) is also not yet fully defined via standards and hence is kept very simple and
 2178 aggregate here. Charging communication capability is defined in ISO/IEC/DIS 15118(E). Strictly
 2179 speaking it could be argued that the grid balancing service is not yet sufficiently mature to be
 2180 included in the streamlined methodology but it is quite likely that means of defining these simple
 2181 functionality levels could be rapidly established and it represents the fastest track by which EV
 2182 capability (as specified in the tender document) could be integrated into an actionable SRI. The same
 2183 is true for the charging service but again if necessary implementers of the streamlined SRI could
 2184 devise simple algorithms to classify the charging capability into the 4 levels expressed here.

2185

2186 Lastly, since the first progress report an additional service EV-17 on *EV Charging connectivity* has
 2187 been added to reflect the value of reporting charging status information to occupants. This service
 2188 is also not defined in standards but the functionality levels are reasonably unambiguous and hence
 2189 it is thought they should be feasible to assess, although this needs verification.

2190 → **Triage**

2191 If no EV charging points omit all EV services.

2192 *Typical time required to make triage = 1-4 minutes.*

2193 **Monitoring and Control**

2194 Since the first progress report new user information services have been added at the domain level
 2195 for heating, DHW, cooling, EG, DSM and EV. This has removed the need for some of the monitoring
 2196 and control functions that were previously included in the monitoring and control section.
 2197 Consequently, it has been deemed appropriate to retain the following services in the streamlined
 2198 methodology:

2199

2200 MC-3 Run time management of HVAC systems

2201 MC-4 Fault detection

2202 MC-9 Occupancy detection: connected services

2203 MC-13 Central reporting of TBS performance and energy use

2204

2205 The service MC-2 *Control of thermal exchanges*, which addresses energy (heat, cold)
 2206 exchange/management among zones within one building or among different buildings will be
 2207 inexistent in SFH and MFH and rare in any building type. Furthermore, it is not defined in any
 2208 standard or protocol, therefore, MC-2 can be ignored as it is irrelevant or not currently assessable.

2209

2210 In practice the assessment of MC-1 *Heating and cooling set point management* & MC-3 *Run time*
 2211 *management of HVAC systems* would be assessed at the same control point and at the same time to
 2212 reduce the assessment time needed. And although MC-1 is now dropped from this section the same
 2213 function is captured in the domain level checks and would be assessed in the same synergistic
 2214 manner.

2215

2216 Of the original MC-5 – MC-7 services on feedback and reporting only MC-5 is defined within a
 2217 standard (EN15232:2017). MC-6 and MC-7 are variants of this and would be assessed at the same
 2218 instant and same point as MC-5. This significantly reduces the actual time required to conduct their
 2219 assessment as the capability regarding present, historical, & predicted consumption (one set of
 2220 capabilities) and presenting actual values, trending and predictive (another set of capabilities) can
 2221 be assessed collectively. This means the additional time allocated to the assessment required for the
 2222 MC-6 and MC-7 services can be ignored as the assessment time is already captured in MC-5. It should
 2223 be noted that there is significant overlap between MC 5 – MC 7 and the services Heating-3, Cooling-
 2224 3 and DH-3 which essentially report the same information but for the heating, cooling and DHW
 2225 services specifically. It may often occur that the reporting of the TBS specific and building aggregate
 2226 information is done at the same interface and so the assessment process would significantly overlap.
 2227 For this reason the MC-5 to MC-7 services are now no longer necessary within the streamlined
 2228 methodology.

2229

2230 The service MC-8 *Reporting information on IAQ* is now replaced by the new Ventilation-6 *Reporting*
 2231 *information regarding IAQ* service and is treated in the ventilation domain.

2232

2233 Services MC-9 – MC-10 concern occupancy detection functionality and its use to control TBSs. The
 2234 value of occupancy detection is mostly to be able to deactivate TBSs that are not needed and hence
 2235 to save energy; however, some of this is already captured in functionality defined within the heating,
 2236 cooling and lighting domains. The MC-9 and MC-10 services are not yet codified in standards or
 2237 assessment protocols; however, MC-9 is more readily accessible and provides a distinct service from
 2238 the domain level occupancy control functions. Therefore it is proposed to retain MC-9 in the
 2239 streamlined methodology subject to its assessability being verified but to omit MC-10.

2240

2241 Services MC-11 is concerned with the remote control of buildings so that absent users are able to
 2242 adjust TBS/devices from a distance. It is not currently defined in any standards or protocols. Note,
 2243 MC-11 was referred to as MC-9R in the first draft report.

2244

2245 MC-12 is concerned with the ability to switch appliance of centrally within the home.

2246

2247 MC-13 is concerned with Central reporting of TBS performance and energy use. While this service
 2248 overlaps with the Heating-3, DHW-3 and Cooling-3 services it is retained in the streamlined
 2249 methodology to cover the instances where there is only reporting of the total (across TBS) energy
 2250 consumption per energy carrier (as is common with less advanced smart meters without sub-
 2251 metering at the TBS level).

2252 → **M&C Conclusions**

2253 Include:

- 2254 • MC-3 Run time management of HVAC systems
- 2255 • MC-4 Fault detection
- 2256 • MC-9 Occupancy detection: connected services

- 2257 • MC-13 Central reporting of TBS performance and energy use
 2258 within the streamlined methodology.
 2259

2260 **Summary of changes**

2261 Once all these changes have been made the list of services that remains in the streamlined SRI
 2262 methodology is as follows:

2263 *Table 12 – List of services: heating*

Code	Service	Maximum functionality level
Heating-1a	Heat emission control	4
Heating-1b	Emission control for TABS (heating mode)	3
Heating-1c	Control of distribution network hot water temperature (supply or return) - Similar function can be applied to the control of direct electric heating networks	2
Heating-1d	Control of distribution pumps in networks	4
Heating-1e	Intermittent control of emission and/or distribution - One controller can control different rooms/zones having same occupancy patterns	3
Heating-1f	Thermal Energy Storage (TES) for building heating	2
Heating-1g	Building preheating control	2
Heating-2a	Heat generator control (for combustion and district heating)	2
Heating-2b	Heat generator control (for heat pumps)	3
Heating-2c	Sequencing of different heat generators	3
Heating-3	Report information regarding heating system performance	4

2264

2265 *Table 13 - List of services: cooling*

Code	Service	Maximum functionality level
Cooling-1a	Cooling emission control	4
Cooling-1b	Emission control for TABS (cooling mode)	3
Cooling-1c	Control of distribution network chilled water temperature (supply or return)	2
Cooling-1d	Control of distribution pumps in networks	4
Cooling-1e	Intermittent control of emission and/or distribution	3
Cooling-1f	Interlock between heating and cooling control of emission and/or distribution	2
Cooling-1g	Control of Thermal Energy Storage (TES) operation	2
Cooling-2a	Generator control for cooling	2
Cooling-2b	Sequencing of different cooling generators	3
Cooling-3	Report information regarding cooling system performance	4

2266

2267

Table 14 – List of services: DHW

Code	Service	Maximum functionality level
DHW-1a	Control of DHW storage charging (with direct electric heating or integrated electric heat pump)	2
DHW-1b	Control of DHW storage charging (using heat generation)	3
DHW-1d	Control of DHW storage charging (with solar collector and supplementary heat generation)	3
DHW-3	Report information regarding domestic hot water performance	4

2268

2269

Table 15 - List of services: CV

Code	Service	Maximum functionality level
CV-1a	Supply air flow control at the room level	3
CV-1b	Adjust the outdoor air flow rate	3
CV-1c	Air flow or pressure control at the air handler level	4
CV-2a	Room air temp. control (all-air systems)	2
CV-2c	Heat recovery control: prevention of overheating	1
CV-2d	Supply air temperature control	3
CV-3	Free cooling	3
CV-6	Reporting information regarding IAQ	3

2270

2271

Table 16 - List of services: lighting, DE, EG, DSM, EV and MC

Code	Service	Maximum functionality level
Lighting-1a	Occupancy control for indoor lighting	3
Lighting-2	Control artificial lighting power based on daylight levels	4
DE-1	Window solar shading control	4
DE-2	Window open/closed control, combined with HVAC system	3
EG-2	Local energy generation information	4
EG-3	Storage of locally generated energy	3
EG-4	Optimizing self-consumption of locally generated energy	2
EG-5	CHP control	1
DSM-18	Smart Grid Integration	1
DSM-19	DSM control of equipment	4
DSM-21	Reporting information regarding DSM	2
DSM-22	Override of DSM control	3
EV-15	EV charging capacity	3
EV-16	EV grid balancing	2
EV-17	EV charging information and connectivity	2
MC-3	Run time management of HVAC systems	3

MC-4	Detecting faults of technical building systems and providing support to the diagnosis of these faults	2
MC-9	Occupancy detection: connected services	2
MC-13	Feedback - Reporting information	3

2272

2273

In total there are at least 50 smart readiness services definitely included in this streamlined approach as opposed to 99 in the Task 1 catalogue. The number could be as high as 52 if the EG-4 and EG-5 services are found to be viable to assess.

2274

2275

2276

2277

2278

2279

2280

2281

2282

Crucially, these 50 are the most actionable services in the sense that they are mostly defined in standards and should be feasible to assess via independent inspection. Furthermore, their impacts are more attributable to their functionality levels than is the case for those services that have been omitted from the Task 1 catalogue. Annex G lists the amalgamated subset of technically actionable services.

2283

2284

2285

2286

2287

In the following sections, two case studies are applied to this streamlined methodology to explore how it could be applied for typical (i.e. representative) building types. Due to time constraints related to the revision of the model these case studies have not yet been updated since the first progress report with the amended list of full and streamlined services, although this will be done for the subsequent version. The principles and conclusions they illustrate remain fully valid though.

2288

4.4.2. CASE STUDY 1 – A SINGLE FAMILY HOUSE

2289

2290

2291

This section applies the streamlined methodology to a Single Family House case study and reports the outcomes in terms of the scores attained but also the aspects that affect feasibility including assessment time if done uniquely for the SRI or as part of an EPC process.

2292

Table 17 - Single Family House case study

Reference buildings	External building component	Area ²³ [m ²]	U-Value [W/m ² K]	Thermal bridge [W/m ² K]	A/V ²⁴ [m ⁻¹]	Floor area [m ²]	Share of window area ²⁵ [%]
Semi-detached house  View Southeast	Facade north	0	0.34	0.1	0.52	165	9
	Facade west	30					
	Facade south	71					
	Facade east	30					
	Roof / upper floor ceiling	100	0.25				
	Ground plate	86	0.52				
	Windows	22	1.3				

2293

2294

2295

2296

2297

2298

2299

For this example a case study is examined of a hypothetical semi-smart single family house. This house is essentially the same as the High Performance single family house in the Ecofys/WSE technical building systems study (Ecofys & WSE, 2017). The building is a partly refurbished, i.e. the insulation of roofs and walls have been improved to a moderate level, and modern double-glazed windows have been installed. Heating is provided by a gas boiler with radiators, which is the case for

2300 more than 40% of the residential space heating consumption of the EU28 building stock (with a
 2301 heating system exchange rate of about 3.6% per year at EU level, gas fired heating systems will still
 2302 remain the norm in the near future). Domestic hot water is provided by the heating system without
 2303 a circulation system. The building has no space cooling and uses natural ventilation.

2304
 2305 The house is smart in that it has quite sophisticated but perfectly mainstream and cost-effective
 2306 energy savings controls of its technical building systems including:

- 2307 • heat demand control for heat emitters via TRVs and for the system via weather
 2308 compensation and optimum stop/start
- 2309 • heat production control includes variable temperature control depending on the load
 2310 (depending on supply water temperature set point)
- 2311 • monitoring & control of HVAC systems can be done by remote control (via smart phone) of
 2312 the heating system
- 2313 • reporting information regarding current and historical energy consumption
- 2314 • basic (dumb) EV charging capabilities.

2315 On the other hand it is not so smart because it has no on-site distributed generation (and hence no
 2316 smart control of this), no DSM capability including no EV-related grid balancing capability, and no
 2317 fault detection capability. As it has no cooling, hot water storage, controlled ventilation⁴⁴ or blinds
 2318 these domains are excluded.

2319
 2320 The full details from the SRI methodology spreadsheet are shown in the landscape table below.
 2321 Under the rationalised (streamlined) SRI methodology this building scores 53% out a maximum
 2322 potential score for this building of 100% (Table 18). If relevant documentation were to be available
 2323 it is (tentatively) estimated that a competent qualified inspector would require 30 minutes to do this
 2324 assessment once access to the premises has been granted. If documentation is not available the
 2325 estimated inspection time increases to ~47 minutes. Were the same building to have no smart
 2326 readiness services the inspection time is estimated to be 20 minutes and were it to have all possible
 2327 smart readiness services and capabilities it is estimated to be 51 minutes with documentation and
 2328 90 minutes without. It should be noted that at the current time the large majority of single family
 2329 buildings will have very few smart readiness features and thus the expected inspection times are in
 2330 the 20 to 40 minutes range with an average probably of around half an hour.

2331 *Table 18 - Single Family House case study – SRI scores and assessment times*

	Inspection time (mins)		SRI
Functionality level	SFH with documents	SFH without documents	
0	20	20	0%
Case Study	30	47	53%
4/Max	51	90	100%

2332
 2333
 2334

⁴⁴ Note small extractor fans in toilets and bathrooms and cooker hood extractor fans are not counted as “controlled ventilation” because their loads are too small and they only provide very localised extraction.

2335

Table 19 - Single Family House case study: SRI scores at service level

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
<i>Heating-1 Heat control on the demand side</i>				
Heating-1a	Heat emission control	Individual room control (e.g. thermostatic valves, or electronic controller)	2	4
Heating-1b	Emission control for TABS (heating mode)	NA	0	0
Heating-1c	Control of distribution network hot water temperature (supply or return) - Similar function can be applied to the control of direct electric heating networks	Outside temperature compensated control	1	2
Heating-1d	Control of distribution pumps in networks	Variable speed pump control (pump unit (internal) estimations)	3	4
Heating-1e	Intermittent control of emission and/or distribution - One controller can control different rooms/zones having same occupancy patterns	Automatic control with optimum start/stop	2	3
Heating-1f	Thermal Energy Storage (TES) for building heating	NA	0	0
Heating-1g	Building preheating control	Program heating schedule in advance	1	2
<i>Heating-2 Heat control on the supply side</i>				
Heating-2a	Heat generator control (for combustion and district heating)	Variable temperature control depending on the load (depending on supply water temperature set point)	2	2
Heating-2b	Heat generator control (for heat pumps)	NA	0	0
Heating-2c	Sequencing of different heat generators	NA	0	0
Heating-2d	Heat system control according to external signal (e.g. electricity tariff, gas pricing, load shedding signal etc.)	NA	0	0
Heating-2e	Heat recovery control (e.g. excess heat from data centres)	NA	0	0

2336

2337

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
Lighting-1a	Occupancy control for indoor lighting	Manual on/off switch	1	3
Lighting-2	Control artificial lighting power based on daylight levels	Manual (per room / zone)	1	3
EG-1R	Local energy production and renewable energies	None	0	2
DSM-1R	Smart Grid Integration	None	0	1
DSM-2R	DSM control of equipment	None	0	4
EV-1R	EV charging	Low charging capacity	1	3
EV-2R	EV grid balancing	None	0	2
MC-1	Heating and cooling set point management	Adaptation from a central room	3	3
MC-3	Run time management of HVAC systems	Individual setting following a predefined time schedule including fixed preconditioning phases	1	2
MC-4	Detecting faults of technical building systems and providing support to the diagnosis of these faults	No central indication of detected faults and alarms	0	2
MC-5	Reporting information regarding current energy consumption	Indication of actual values only (e.g. temperatures, meter values)	1	3
MC-6	Reporting information regarding historical energy consumption	Indication of actual values only (e.g. temperatures, meter values)	1	3
MC-7	Reporting information regarding predicted energy consumption	None	0	3
MC-8	Reporting information regarding IAQ	CO alarms at boiler	1	1
MC-9R	Technical building systems independent occupancy detection	Remote control of main TBS	1	3

2338

2339

2340

2341

2342 It is also pertinent to consider how the assessment time would change were all the TBS to be present
 2343 (e.g. DHW, cooling, controlled ventilation and dynamic building envelope domains as well as those
 2344 included in the case study). In this case the estimated inspection time would rise to 46 minutes for a
 2345 building with no smart capabilities and to 125 minutes for one the maximum smart capabilities and
 2346 supporting documentation, Table 20. In fact very few single family buildings have all possible TBS
 2347 domains and thus this would be a-typical.

2348 *Table 20 - Single Family House with all domains – SRI scores and assessment times as a function of the smart*
 2349 *functionality level*

Functionality level	Inspection time (mins)		SRI
	SFH with documents	SFH without documents	
0	46	46	0%
1	85	170	54%
2/Max	119	236	83%
3/Max	124	255	99%
4/Max	125	256	100%

2350

2351

2352 The weighting of impacts by domain applied in this analysis is as shown in Table 21, however, in
 2353 principle any (including equal) weightings could be applied. Those used here are intended to better
 2354 reflect the contribution smart functionalities make to the overall impacts as a function of the domain
 2355 they apply to; however, many of the values applied are rather arbitrary and more work is required
 2356 to establish any agreed recommended weightings. Note, when equal weightings per impact
 2357 parameter are shown it simply indicates that the study team currently has no insight into what any
 2358 recommended weightings could be and does not indicate that there is no rational to apply
 2359 differentiated weightings for the impact parameter concerned.

2360

2361

Table 21 - Domain-level impact weightings used in the Single Family House case study

Domain	Energy savings on site	Flexibility for the grid and storage	Self generation	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Heating	52%	2.5%	0%	40%	10%	10%	10%	7%
Domestic hot water	14%	2.5%	0%	10%	10%	10%	10%	7%
Cooling	7%	2.5%	0%	15%	10%	10%	10%	7%
Controlled ventilation	4%	2.5%	0%	10%	10%	10%	10%	7%
Lighting	8%	2.5%	0%	10%	10%	10%	10%	7%
Dynamic building envelope	4%	0.0%	0%	5%	10%	10%	10%	7%
Energy generation	0%	2.5%	80%	0%	10%	10%	10%	7%
Demand side management	0%	40%	10%	5%	10%	10%	10%	7%
Electric vehicle charging	0%	40%	10%	0%	10%	10%	10%	7%
Monitoring and control	10%	5.0%	0%	5%	10%	10%	10%	40%
Total	100%	100%	100%	100%	100%	100%	100%	100%

2362

2363 By contrast the eight impact criteria are all weighted equally. In other words scoring under any of
 2364 *Energy savings on site, Flexibility for the grid and storage, Self-generation, Comfort, Convenience,*
 2365 *Health, Maintenance & fault prediction, or Information to occupants* all counts equally to the final
 2366 SRI score. Again, these could be weighted differently to give more prominence to some impacts than
 2367 others.

2368
 2369 Underpinning the overall SRI score the case study building attains the ordinal impact scores by impact
 2370 criterion as shown in Table 22. While energy has the largest potential for scoring (reflecting the wide
 2371 array of smart services that influence energy consumption), there are potentially major contributions
 2372 from flexibility, comfort, convenience and information to occupants. There is less for maintenance
 2373 and fault prediction, health and self-generation. This could be because some existing smart services
 2374 that address maintenance and fault prediction or health were not identified for the Task 1 catalogue
 2375 or it may be that there are only limited smart services available for these impacts. In the case of self-
 2376 generation it reflects the consolidation of the smart services into actionable measures made for this
 2377 streamlined methodology. More could be added were the services more mature and better defined.

2378
 2379 The *Maximum with all domains* row shows what could be scored were all possible services present
 2380 and all domains. It is rather misleading though as this could never be the case as many of the smart
 2381 services (and especially those that relate to the TBS) are effectively mutually exclusive e.g. a building
 2382 would not have district heating, combustive heating, heat pumps, solar heating, TABS and Thermal
 2383 Energy Storage, but most likely would just have one of these. As a result the apparent dominance of
 2384 energy in this row is an artefact and would not be reflected in any actual building using this
 2385 streamlined methodology.

2386 *Table 22 - Ordinal impact scores for the Single Family House case study, the case study with maximum smart*
 2387 *capability and for an equivalent building having with all possible domains and smart-services*

	ORDINAL IMPACT SCORES							
	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Case study	20	4	0	19	15	6	0	8
Case study Maximum	42	22	2	28	33	7	3	14
Maximum with all domains	106	31	2	67	73	21	7	16


2388

2389 4.4.3. CASE STUDY 2 – AN OFFICE

2390 This section applies the streamlined methodology to an office case study and reports the outcomes
 2391 in terms of the scores attained but also the aspects that affect feasibility including assessment time.

2392

Table 23 - Office case study: building characteristics

Reference buildings	External building component	Area ³⁵ [m ²]	U-Value [W/(m ² K)] ³⁶	Thermal bridge (W/m ² K)	A/V ³⁷ [m ⁻¹]	Reference surface [m ²]	Share of window area ³⁸ [%]
Office building  View Northeast	Facade north	576	0.60	0.1	0.37	1,676	22
	Facade west	187					
	Facade south	598					
	Facade east	234					
	Roof / upper floor ceiling	591	0.40				
	Ground plate	591	0.60				
	Windows	611	1.3				

2393

2394

2395 For this example a case study is examined of a hypothetical office building. This building is essentially
 2396 the same as the High Performance office in the Ecofys/WSE technical building systems study. The
 2397 building has a gas-fired boiler and hydronic heat distribution via radiator emitters. Space cooling is
 2398 provided by a chiller that distributes coolth via a hydronic system using fan-coils. Domestic hot water
 2399 is via localised instantaneous heaters and does not have storage. Controlled ventilation is supplied
 2400 via an air handling unit but does not use heat recovery.

2401

2402 The office is smart in that it has quite sophisticated but mainstream and cost-effective energy savings
 2403 controls of its technical building systems including:

2404

- 2405 • heat demand control for heat emitters via eTRVs and for the system via weather compensation and optimum stop/start
- 2406 • Individual room/zone demand driven control with communication between controllers and BACS and presence detection
- 2407 • heat production control includes variable temperature control depending on the load (depending on supply water temperature set point)
- 2408 • variable airflow and chiller capacity by means of variable speed drives on ventilation fans and the chiller compressor
- 2409 • cooling circuit temperature (supply or return) with weather compensation, optimum start/stop and variable speed pump controls for network distribution pumps
- 2410 • control of cooling emitters provided by individual room demand control with communication and presence detection
- 2411 • air flow control at the room/zone level via demand control: wherein the system is controlled by sensors measuring indoor air parameters or adapted criteria (e.g. CO₂, mixed gas or VOC sensors)
- 2412 • air flow or pressure control at the air handler level via automatic flow or pressure control with demand evaluation
- 2413 • advanced air supply and humidity controls
- 2414 • lighting control per task light source using occupancy and daylight responsive controls with dimming and daylight responsiveness for circulation lighting

2421

2422

2423

- 2424
- 2425
- 2426
- 2427
- 2428
- user-friendly BEMS system in place but with energy savings functions activated. Runs diagnostics, reports faults and provides informative displays of energy consumption, indoor conditions and possibilities for improvement
 - basic (dumb) EV charging capabilities
 - motorized operation of window blinds with manual control.

2429

2430 On the other hand it is not so smart because it has no on-site distributed generation (and hence no

2431 smart control of this) and no DSM capability including no EV-related grid balancing capability.

2432

2433 The full details from the SRI methodology spreadsheet are shown in the landscape table below.

2434

2435 Under the rationalised (streamlined) SRI methodology this building scores 60% out a maximum

2436 potential score for this building of 100% (Table 24). If relevant documentation were to be available

2437 it is (tentatively) estimated that a competent qualified inspector would require 2.5 hours to do this

2438 assessment once access to the premises has been granted. If documentation is not available the

2439 estimated inspection time increases to 4.3 hours. Were the same building to have no smart readiness

2440 services the inspection time is estimated to be 1.4 hours and were it to have all possible smart

2441 readiness services and capabilities it is estimated to be 4.3 hours with documentation and 8.8 hours

2442 without. It should be noted that at the current time the large majority of offices will have smart

2443 readiness capabilities of and below those shown in the case study.

2444

Table 24 - Office case study: SRI scores and assessment times

Functionality level	Inspection time (hrs)		SRI
	Office with documents	Office without documents	
0	1.4	1.5	0%
Case Study	2.5	4.3	60%
4/Max	4.3	8.8	100%

2445

2446

Table 25 – Office case study: SRI scores at the service level

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
<i>Heating-1 Heat control on the demand side</i>				
Heating-1a	Heat emission control	Individual room control with communication and presence control	4	4
Heating-1b	Emission control for TABS (heating mode)	NA	0	0
Heating-1c	Control of distribution network hot water temperature (supply or return) - Similar function can be applied to the control of direct electric heating networks	Outside temperature compensated control	1	2
Heating-1d	Control of distribution pumps in networks	Variable speed pump control (pump unit (internal) estimations)	3	4
Heating-1e	Intermittent control of emission and/or distribution - One controller can control different rooms/zones having same occupancy patterns	Automatic control with optimum start/stop	2	3
Heating-1f	Thermal Energy Storage (TES) for building heating	NA	0	0
Heating-1g	Building preheating control	Thermostat self-learning user behaviour (presence, setpoint)	2	2
<i>Heating-2 Heat control on the supply side</i>				
Heating-2a	Heat generator control (for combustion and district heating)	Variable temperature control depending on the load (depending on supply water temperature set point)	2	2
Heating-2b	Heat generator control (for heat pumps)	NA	0	0
Heating-2c	Sequencing of different heat generators	NA	0	0
Heating-2d	Heat system control according to external signal (e.g. electricity tariff, gas pricing, load shedding signal etc.)	NA	0	0
Heating-2e	Heat recovery control (e.g. excess heat from data centres)	Heat recovery on/off control	1	3

2447

2448

Draft Second Progress report

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
Cooling-1 <i>Cooling control on the demand side</i>				
Cooling-1a	Cooling emission control	Individual room control with communication and presence control	4	4
Cooling-1b	Emission control for TABS (cooling mode)	NA	0	0
Cooling-1c	Control of distribution network chilled water temperature (supply or return)	Outside temperature compensated control	1	2
Cooling-1d	Control of distribution pumps in networks	Variable speed pump control (pump unit (internal) estimations)	3	4
Cooling-1e	Intermittent control of emission and/or distribution	Automatic control with optimum start/stop	2	3
Cooling-1f	Interlock between heating and cooling control of emission and/or distribution	Total interlock	2	2
Cooling-1g	Control of Thermal Energy Storage (TES) operation	NA	0	0
Cooling-2 <i>Cooling control on the supply side</i>				
Cooling-2a	Generator control for cooling	Variable temperature control depending on outdoor temperature	1	2
Cooling-2b	Sequencing of different cooling generators	NA	0	0

2449
2450

2451

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
DHW-1a	Control of DHW storage charging (with direct electric heating or integrated electric heat pump)	NA	0	0
DHW-1b	Control of DHW storage charging (using heat generation)	NA	0	0
DHW-1c	Control of DHW storage temperature, varying seasonally: with heat generation or integrated electric heating	NA	0	0
DHW-1d	Control of DHW storage charging (with solar collector and supplementary heat generation)	NA	0	0
DHW-2	Control of DHW circulation pump	NA	0	0

2452

2453

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
<i>CV-1 Air Flow Control</i>				
CV-1a	Supply air flow control at the room level	NA	0	0
CV-1b	Adjust the outdoor air flow rate	NA	0	0
CV-1c	Air flow or pressure control at the air handler level	NA	0	0
<i>CV-2 Air Temperature Control</i>				
CV-2a	Room air temp. control (all-air systems)	NA	0	0
CV-2b	Room air temp. control (Combined air-water systems)	Coordination	1	1
CV-2c	Heat recovery control: prevention of overheating	NA	0	0
CV-2d	Supply air temperature control	NA	0	0
CV-3	Free cooling	NA	0	3

2454

2455

2456

Draft Second Progress report

Code	Service	Case study functionality level	Functionality level	Maximum functionality level
Lighting-1a	Occupancy control for indoor lighting	Automatic detection (manual on / dimmed or auto off)	3	3
Lighting-2	Control artificial lighting power based on daylight levels	Automatic dimming	4	4
EG-1R	Local energy production and renewable energies	Motorized operation with manual control	1	4
DSM-1R	Smart Grid Integration	None	0	2
DSM-2R	DSM control of equipment	None	0	1
EV-1R	EV charging	None	0	4
EV-2R	EV grid balancing	Low charging capacity	1	3
MC-1	Heating and cooling set point management	None	0	2
MC-3	Run time management of HVAC systems	Adaptation from a central room	2	3
MC-4	Detecting faults of technical building systems and providing support to the diagnosis of these faults	Individual setting following a predefined time schedule including fixed preconditioning phases	2	2
MC-5	Reporting information regarding current energy consumption	No central indication of detected faults and alarms	0	2
MC-6	Reporting information regarding historical energy consumption	Indication of actual values only (e.g. temperatures, meter values)	1	3
MC-7	Reporting information regarding predicted energy consumption	None	0	3
MC-8	Reporting information regarding IAQ	None	1	3
MC-9R	Technical building systems independent occupancy detection	None	0	2

2457
2458
2459
2460

2461 The weighting of impacts by domain applied in this analysis is as shown in Table 26, however, in
 2462 principle any (including equal) weightings could be applied. Those used here are intended to better
 2463 reflect the contribution smart functionalities make to the overall impacts as a function of the domain
 2464 they apply to.

2465

2466

Table 26 - Domain-level impact weightings used in the Office case study

Domain	Energy savings on site	Flexibility for the grid and storage	Self generation	Comfort	Convenience	Health	maintenance & fault prediction	information to occupants
Heating	49%	2.5%	0%	40%	10%	10%	10%	7%
Domestic hot water	10%	2.5%	0%	10%	10%	10%	10%	7%
Cooling	6%	2.5%	0%	15%	10%	10%	10%	7%
Controlled ventilation	7%	2.5%	0%	10%	10%	10%	10%	7%
Lighting	10%	2.5%	0%	10%	10%	10%	10%	7%
Dynamic building envelope	7%	0.0%	0%	5%	10%	10%	10%	7%
Energy generation	0%	2.5%	80%	0%	10%	10%	10%	7%
Demand side management	0%	40%	10%	5%	10%	10%	10%	7%
Electric vehicle charging	0%	40%	10%	0%	10%	10%	10%	7%
Monitoring and control	11%	5.0%	0%	5%	10%	10%	10%	40%
Total	100%	100%	100%	100%	100%	100%	100%	100%

2467

2468 By contrast the eight impact criteria are all weighted equally. In other words scoring under any of
 2469 *Energy savings on site, Flexibility for the grid and storage, Self-generation, Comfort, Convenience,*
 2470 *Health, Maintenance & fault prediction, or Information to occupants* all counts equally to the final
 2471 SRI score. Again, these could be weighted differently to give more prominence to some impacts than
 2472 others.

2473

2474 Underpinning the overall SRI score the case study building attains the ordinal impact scores by impact
 2475 criterion as shown in Table 27. While energy has the largest potential for scoring (reflecting the wide
 2476 array of smart services that influence energy consumption), there are potentially major contributions
 2477 from flexibility, comfort, convenience and information to occupants. There is less for maintenance
 2478 and fault prediction, health and self-generation. As mentioned for the single family home case study,
 2479 this could be because some existing smart services that address maintenance and fault prediction or
 2480 health were not identified for the Task 1 catalogue or it may be that there are only limited smart
 2481 services available for these impacts. In the case of self-generation it reflects the consolidation of the
 2482 smart services into actionable measures made for this streamlined methodology. More could be
 2483 added were the services more mature and better defined.

2484

2485 Table 27 - Ordinal impact scores for the Office case study, the case study with maximum smart capability and
 2486 for an equivalent building having with all possible domains and smart-services

ORDINAL IMPACT SCORES								
	Energy	Flexibility	Self-generation	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Case study	33	3	0	31	26	6	4	8
Case study Maximum	63	22	2	43	43	6	5	12

2487

2488 4.5. TAILORING THE SRI

2489 This chapter considers issues about how the applicability of the methodology is likely to vary
 2490 depending on specific circumstances (building type, climate, site specific conditions, user
 2491 preferences etc.). Local and site-specific context will mean that some domains, services and services
 2492 are either not relevant, not applicable or not desirable and thus the SRI needs to be flexible enough
 2493 to accommodate this. Equally depending on the local context SRI scheme operators may wish to
 2494 elevate some aspects of the SRI (domains or impacts) and downgrade others – for example some
 2495 operators of the SRI may be primarily concerned about promoting grid flexibility while others may
 2496 be concerned about EV facilitation and on-site energy savings through enhanced control. Examples,
 2497 are given of how to apply the methodology to address this variety of needs through either omitting
 2498 and rescaling elements or by adapting the weightings within the common SRI framework.

2499 4.5.1. TAILORING TO TAKE ACCOUNT OF THE BUILDINGS NEEDS AND CONTEXT

2500 Clearly, if a building has a technical building system or feature it should get a higher SRI score if that
 2501 TBS/feature is smart than if it is not, but it is more subjective as to whether a building should be
 2502 considered less smart if it doesn't have the TBS/feature in the first place.

2503
 2504 Many of the smart readiness services catalogued in Task 1 are associated with technical building
 2505 systems that are often not required or appropriate depending on the context in question. At the
 2506 whole domain level, depending on the climate, internal loads, building function and overall building
 2507 energy performance a building may not need:

- 2508 • Heating (sometimes, but increasingly true in advanced passive buildings)
- 2509 • Cooling (often)
- 2510 • Controlled ventilation
- 2511 • Controlled blinds or dynamic building envelope features.

2512
 2513 It is inappropriate to give a building which doesn't need these TBSs a poorer SRI score than one which
 2514 does simply because these TBS could be made to be comparatively smart compared to less smart
 2515 options. This is for example the case if one considers the example of a highly advanced passive solar
 2516 house using solar shades and ventilation or window opening control which eliminates the need for
 2517 mechanical cooling, hence also doesn't need the TBS for controlling these.

2518

2519 Equally a building may not have or need:

- 2520 • storage for domestic hot water or associated circulation pumps
- 2521 • blinds or dynamic building envelope features
- 2522 • on-site energy generation such as RES
- 2523 • local storage, such as batteries
- 2524 • parking facilities (and hence EV charging capabilities).

2525

2526 Therefore, any viable SRI methodology needs to be flexible enough to adapt to locally specific
 2527 context. The methodology presented in this report is fully flexible in this regard because it allows the
 2528 users to exclude any unnecessary TBS or service and re-normalise the SRI score so that the building
 2529 is not penalised for its absence. Equally, whenever relevant, it would be possible to add new services
 2530 (not mentioned in the report above) and adjust the scoring in a similar manner.

2531

2532 Not only can the methodology be tailored to take account of the presence or absence of TBSs and
 2533 services, but it can also be tailored to take account of the relative priority to be placed on the ten
 2534 distinct domains and the eight impacts. Sometimes this could be appropriate due to technical factors.
 2535 For example, the climate in a specific location may alter the average importance of the different
 2536 domains in a typical building-type for the on-site energy consumption and savings. An alternative
 2537 example, could be that in a specific jurisdiction some flexibility options are made available by the
 2538 DSOs whereas in another they are not – and this could provide a technical distinction in the relative
 2539 importance of different DSM and EV charging services to the overall smart outcome of the building
 2540 (notwithstanding the smart readiness versus smart capability now distinction). Equally, in different
 2541 jurisdictions there are likely to be different priorities placed on the promotion of the various smart
 2542 services and the importance of different impacts. This also means that for any given jurisdiction the
 2543 SRI methodology could be applied in a manner which makes sense for the specificities of the building
 2544 stock, climate, culture, service offerings and policy priorities that are present there. On the other
 2545 hand, the SRI will be most effective if it retains a minimum level of harmonisation as discussed in
 2546 section 4.9.9.

2547

4.5.2. EXAMPLES OF HOW THE METHODOLOGY CAN BE TAILORED TO NEEDS AND CONTEXT

2548 The methodological framework presented in this report is flexible enough to allow any of the types
 2549 of contextual adjustments implied above. If a TBS or service is not present and not relevant then the
 2550 methodology is applied in a way that discounts the absent TBS/service and renormalizes the scoring.
 2551 It does this by setting the actual scores attained and the maximum scores that could be attained for
 2552 the absent services to zero (the normalisation formulae will then set the maximum attainable score
 2553 for a service to zero and ignore (discount) all normalisation ratios having a zero-value denominator).

2554

2555 In the SFH case study presented earlier this exact process is followed for the absent TBS domains of
 2556 cooling, controlled ventilation and dynamic building envelope; but it is also applied for the absent
 2557 services of:

- 2558 • Emission control for TABS (heating mode)
- 2559 • Thermal Energy Storage (TES) for building heating
- 2560 • Control of DHW storage charging (with direct electric heating or integrated electric heat
 2561 pump)
- 2562 • Control of DHW storage charging (using heat generation)
- 2563 • Control of DHW storage temperature, varying seasonally: with heat generation or integrated
 2564 electric heating

- 2565 • Control of DHW storage charging (with solar collector and supplementary heat generation)
- 2566 • Control of DHW circulation pump

2567 Note, that the TABS and TES services are discounted because the building does not use or need these.
 2568 In the case of DHW it is different, because the building does have a DHW service but not one that
 2569 utilises storage or circulation pumps.

2570
 2571 Interestingly, the building does not have its own energy generation (i.e. RES) but the domain is
 2572 retained and the building is set (and hence scored) at functionality level 0 out of a possible maximum
 2573 functionality level of 2 on the Local energy production and renewable energies service. In this case
 2574 the missing service is not discounted and thus the building's SRI score is lower than it would have
 2575 been had a renormalisation process been applied. This is because it can be argued that the building
 2576 would be a smarter building if it had this capability; however, this judgement is contestable and some
 2577 users of the methodology might prefer to follow a discounting and renormalisation process in this
 2578 instance too.

2579
 2580 In the Office case study presented above none of the domains are absent and hence no discounting
 2581 and renormalisation process is applied at the whole domain level. Discounting and renormalisation
 2582 is applied, however, for the following absent and unnecessary services:

- 2583 • Emission control for TABS (heating mode)
- 2584 • Thermal Energy Storage (TES) for building heating
- 2585 • Heat generator control (for heat pumps)
- 2586 • Sequencing of different heat generators
- 2587 • Heat system control according to external signal (e.g. electricity tariff, load shedding signal
 2588 etc.)
- 2589 • Control of DHW storage charging (with direct electric heating or integrated electric heat
 2590 pump)
- 2591 • Control of DHW storage charging (using heat generation)
- 2592 • Control of DHW storage temperature, varying seasonally: with heat generation or integrated
 2593 electric heating
- 2594 • Control of DHW storage charging (with solar collector and supplementary heat generation)
- 2595 • Control of DHW circulation pump
- 2596 • Emission control for TABS (cooling mode)
- 2597 • Control of Thermal Energy Storage (TES) operation
- 2598 • Sequencing of different cooling generators
- 2599 • Controlled ventilation - Supply air flow control at the room level
- 2600 • Controlled ventilation - Adjust the outdoor air flow rate
- 2601 • Controlled ventilation - Air flow or pressure control at the air handler level
- 2602 • Controlled ventilation - Room air temp. control (all-air systems)
- 2603 • Controlled ventilation - Heat recovery control: prevention of overheating
- 2604 • Controlled ventilation - Supply air temperature control

2605
 2606 In all cases, this is because the service the smart services refer to is provided by another solution. For
 2607 example as the building uses combustion based heating via a single boiler with hydronic distribution
 2608 and emission via radiators the TABS, TES, heat-pump control, heat generator sequencing and
 2609 external signal control smart services are unnecessary and inapplicable. The same is true of the TABS
 2610 and TES cooling solutions, the DHW storage and distribution solution (as localised instantaneous
 2611 water heating is used), and all the controlled ventilation smart services that are not applicable to the
 2612 solution which is actually used (a combined air-water system).
 2613

2614 The exclusion and renormalisation process described above is not the only means by which the
2615 methodology is adapted to contextual circumstances – the other method is by adjustment of the
2616 normalised weighting factors that are applied to the domains and/or to the impacts. In the two case
2617 studies presented in this report uneven (i.e. unequal) weighting factors are applied by domain for
2618 the following impacts (Energy savings on-site, Flexibility for the grid and storage, Self-generation,
2619 Comfort, Information to occupants) but even (equal) weightings by domain are applied for the
2620 impacts of Convenience, Health, and Maintenance & fault prediction. The rationale for this is that
2621 in the case of the unequally weighted impacts across domains some domains are thought to be more
2622 important to the overall impact than others. For example smart services in the heating, domestic hot
2623 water, cooling, controlled ventilation and lighting domains have no impact on self-generation so are
2624 weighted to zero for this impact. By contrast the importance of specific TBS to the energy-saving on-
2625 site varies depending on the building type (as well as other factors) and as a result the weightings
2626 applied to the TBS domains for the SFH and Office cases studies are not identical, but rather are
2627 adjusted to take account of the relative importance of each TBS to the buildings energy consumption
2628 (based on typical European buildings in this case). These examples are indicative of the application
2629 of a technical determination process that aims to ensure the overall SRI reflects the true impact of
2630 the potential smart readiness services on the impacts in question. As these can vary systematically
2631 according to context the methodology needs to be (and is) flexible enough to allow such contextual
2632 calibration to take place.

2633
2634 The other means of using the weightings capability is to apply differentiated weighting by impact
2635 type in the derivation of the overall SRI score. In the SFH and Office case studies presented above
2636 each of the eight impact criteria are treated (and hence weighted) equally, thus no impact criterion
2637 is considered to be more relevant than another. However, users of the methodology may have
2638 different perspectives on this issue and may wish to apply differential weightings by impact criterion.
2639 For example, if the scoring attributed to the discrete smart service functions or functionality levels is
2640 not considered to be sufficiently well-founded for some of the impact criteria these could be
2641 weighted downwards (or even to zero and hence discarded) compared to the remaining impact
2642 criteria.

2643
2644 It should be noted, that in all cases the methodology requires the weightings to sum to 100% across
2645 both the impact criteria and across the domains for each impact criteria. Thus adjusting the
2646 weighting for one element upwards requires that for another to be adjusted downwards to ensure
2647 the sum is always 100%.
2648

2649 **4.6. EVOLUTIONARY METHODOLOGICAL APPROACHES**

2650 The methodology put forward above is not the only approach that could be used for the SRI. In
2651 principle the SRI could also be determined using methodologies based on:

- 2652 • calculation based approaches i.e. using an algorithm and/or software
- 2653 • measured outcome based solutions potentially including real time dynamic measurement
2654 data and a rated realtime indicator
- 2655 • a checklist approach
- 2656 • an evolutionary hybrid approach.

2657
2658 These options are examined in more depth below.
2659

2660

4.6.1. INCORPORATING CARDINAL DATA ASSESSMENT OF IMPACTS

2661

2662

2663

2664

2665

2666

2667

2668

2669

2670

2671

2672

2673

2674

2675

2676

2677

2678

2679

2680

2681

2682

2683

2684

2685

2686

2687

2688

2689

2690

2691

2692

2693

2694

2695

2696

2697

2698

2699

2700

2701

2702

2703

2704

2705

2706

2707

2708

The SRI methodology set out in the earlier sections of this report is based on applying ordinal rankings dependent on the SR capabilities present within a building. These rankings are derived by provisional expert evaluations of the study team with input from stakeholders and/or from exogenously derived rankings, such as those presented within standards (harmonised or otherwise). Were there to be a migration over time with an evolving maturity of the SRI towards the use of measured outcomes (see section 3.6.3) and/or calculated outcomes then cardinal impact data would become available which is intrinsically preferable to the use of less precise ordinal data.

This raises the question of how such cardinal data could be substituted for the ordinal rankings set out in the current method?

In fact the approach that could be followed is quite straightforward. The ordinal ranking methodology proposed for the SRI is already normalised against the eight overarching impact parameters such that for each impact parameter a building is awarded a score based on its relative attainment of the maximum possible score. Cardinal data can be similarly normalised and mapped onto this scale. By way of illustration consider the case of the EN15232 standard for BACS, which includes a simplified BACS factor method that ascribes progressively higher cardinal energy savings impacts to progressively more advanced BACS solutions for specific technical building systems. Under the current, even more simplified, SRI methodology these impacts, which are associated with BACS classes ranked from D to A within the standard, are mapped to the ordinal scores; however, it would be equally possible (and presumably preferable) to use the BACS factors directly in a cardinal impact score. The table below shows the EN 15232 BAC efficiency factors for thermal energy use for non-residential buildings. To calculate the (cardinal) impact the BACS class has on the building's thermal energy use the energy consumption of the TBS is multiplied by the BAC efficiency factor. Thus, in the case of an education building the thermal-energy TBS energy consumption would be multiplied by a factor 1.20 for a class D BACS and by 0.8 for a class A BACS thus the class A BACS would be expected to consume $0.8/1.20 = 66.7\%$ of the class D BACS solution i.e. to use 33.3% less energy for an equivalent TBS service. As class A is the highest BACS service and class D the lowest they define the two end-points on the normalised scale. Under the ordinal ranking system the class A solution scores ++++ = 4 while the class D solution scores no + i.e. = 0. So in this case a score of 4 is equivalent to an energy saving of 33.3%, a class B score a saving of 26.7%, and a class C score to a saving of 16.7%.

There are two ways this cardinal information could be included within the scheme. The simplest approach would be to normalise it by the highest potential score. In this case this is a score of 4 for a 33.3% energy saving, so under the cardinal approach the highest score would remain 4, the next highest class B would become $3.2 = 4*26.7/33.3$, the class C would be $2.0 = 4*16.7/33.3$, and the class D would remain 0.

A more sophisticated approach would be to weight all the energy savings scores (whether ordinal or cardinal) by the expected energy consumption of each TBS as a proportion of the total building energy consumption (see weightings discussion) and to apply the savings estimates directly. Thus, if the given TBS being treated with cardinal data (from the example above) is expected to account for 40% of the total building energy consumption then the energy savings scores attained would be allocated for a class A solution leading to 33.3% energy savings for the TBS in question of $1.33 (= 0.4*0.333)$ of the maximum possible points awardable for on-site energy savings in the building.

2709

2710

Table 28 BAC efficiency factors for non-residential buildings as defined in EN 15232

Table A.1 — Overall BAC efficiency factors $f_{BAC,th}$ – Non-residential buildings

Non-residential building types	Overall BAC efficiency factors $f_{BAC,th}$			
	D	C	B	A
	Non energy efficient	Reference Standard	Advanced	High energy performance
Offices	1,51	1	0,80	0,70
Lecture hall	1,24	1	0,75	0,5 ^a
Education buildings (schools)	1,20	1	0,88	0,80
Hospital	1,31	1	0,91	0,86
Hotels	1,31	1	0,85	0,68
Restaurants	1,23	1	0,77	0,68
Wholesale and retail trade service buildings	1,56	1	0,73	0,6 ^a
Other types - sport facilities - storage - industrial buildings - etc.		1		

^a These values highly depend on heating/cooling demand for ventilation.

2711

2712

2713

2714

2715

2716

2717

Note, this example illustrates how it is possible to combine cardinal and ordinal data assessments within the SRI methodology and this means that as and when cardinal data is available for use it can be substituted for the simpler ordinal data without compromising the rest of the assessment framework. The modular nature of the SRI methodology enables this blended approach to be applied in an evolutionary manner.

2718

4.6.2. USING CALCULATION SOFTWARE

2719

2720

2721

2722

2723

2724

2725

2726

2727

2728

2729

2730

2731

2732

2733

2734

2735

In theory calculation-based approaches could be used to determine the SRI in place of metered outcomes (discussed in 3.6.3). These could use software or algorithms to award points based on a simulated set of outcomes based on the known behaviours and performance of smart readiness technologies and solutions. The software used by some MS to calculate building energy performance for EPCs is an example of this type of approach as applied specifically to building energy performance. There is a wide variety of current practice in the use of such calculation software and in reality it is understood that most EPC implementations do not currently capture the majority of energy savings that could be achieved via the deployment of smart energy savings technologies such as BACS, although they could be amended to do so.

In principle, calculation software could also be used to assess impact parameters other than energy savings on site. However, there appears to be less maturity in the development and deployment of calculation tools to address the other SRI impact parameters covered in the current methodology. Thus, the use of calculation tools is something that could be fostered and encouraged in the implementation of the SRI whenever such tools are available and viable. A next step could entail a detailed review of all available calculation tools and the documentation of their capabilities and suitability of use to derive specific SRI pertinent impacts. In the event that such tools are available

2736 for specific SR impacts or services it should be possible to integrate them within the SRI assessment
 2737 methodology in place of, or as a supplement to, using the current methodology which is based on
 2738 ascribing ordinal rankings linked to impact scores for specific smart readiness capabilities. An
 2739 illustration of how this could be done is discussed in the previous section.

2740
 2741 More generally, using calculation software to determine the SRI could be particularly relevant for
 2742 design-time SRI assessments i.e. those based on building digital models.

2743 4.6.3. USING MEASURED OUTCOME BASED APPROACHES

2744 Some comments received on the interim report raised the issue of whether it might be viable to
 2745 move towards an outcome-based approach rather than one based on assessing inputs. In an ideal
 2746 situation an assessment based on measuring outcomes (in terms of energy performance, health,
 2747 comfort etc.) is preferable because it is fully technologically neutral and could be structured to award
 2748 scores that are proportional to the smart building outcomes which are achieved. The method put
 2749 forward in the interim report did not (so far) pursue this approach because an outcome-based
 2750 approach is only possible when outcomes are measured and when there is a framework in place to
 2751 normalise the outcomes that can be transposed to an SRI. Currently, building energy consumption
 2752 can be measured when smart meters for each energy flow (e.g. electricity, gas, etc.) are in place and
 2753 in theory this could be used to create a dynamic measure of building consumption that in turn could
 2754 be normalised to produce an energy performance score that relates to the **energy savings on site**
 2755 impact parameter. The normalisation process could take into account floor area (perhaps
 2756 differentiated by the relative areas of internal spaces as a function of the activities conducted within
 2757 them), building type, climate, and even occupancy (if this latter is also measured). In principle,
 2758 measurements could also be done for the other seven impact parameters as follows

- 2759 • **Flexibility for grid and storage:** could measure the magnitude of energy stored, of demand
 2760 rescheduled from peak, and of the flow of stored energy from the building to the energy
 2761 network on demand
- 2762 • **Self-generation:** the amount of energy generated (perhaps expressed as a normalized ratio
 2763 of the building energy consumption)
- 2764 • **Comfort:** internal temperatures (when occupied) and the relative deviation from best
 2765 practice set-points for occupied spaces
- 2766 • **Convenience:** this impact category assesses the gains in terms of convenience in terms of
 2767 “making the life easier” for the occupant, e.g. by requiring less manual interactions to control
 2768 the technical building system
- 2769 • **Health and wellbeing:** measurements of indoor air quality, light levels and light quality
- 2770 • **Maintenance and fault prediction:** impacts from the point of view of the asset management
 2771 or TBS perspective
- 2772 • **Information to occupants:** a set of of most relevant measurable information could be
 2773 identified and the extent to which this is provided gauged.

2774
 2775 While this approach undoubtedly has merit it presents some practical problems at present. First,
 2776 only parameters that can be measured can be accounted for and yet for the large majority of existing
 2777 buildings only a few or none of the relevant parameters are currently metered. While increasing
 2778 metering and intelligent diagnostics of building data is desirable and is an aspect of smartness, if the
 2779 SRI is fully tied to the presence of this capability it would dramatically limit its scope (i.e. the
 2780 proportion of existing buildings that could attain an SRI score and the proportion of impacts that
 2781 could be assessed). In addition, requiring the inclusion of metering capability is likely to add costs
 2782 that may also deter some building users from engaging with the SRI. Furthermore, smart metering
 2783 capabilities are not harmonised across the EU and hence this could also be a driver of divergence.

2784 Finally, measured data can only be available for buildings that are already in operation. This would
2785 prohibit using the SRI methodology to inform decision making during the design stage for newly
2786 constructed or renovated buildings.

2787
2788 Conversely, metered data is more straightforward to assess remotely and were sufficient data to be
2789 available in this form it could remove the need for on-site inspection (i.e. enable either instantaneous
2790 and remote (if needed) assessment, and/or instantaneous automatic on-site evaluation and
2791 reporting) and could allow a real-time dynamic indicator of smartness to evolve. Thus, the presence
2792 of real time or short interval metering and/or measurement capability is a plus from a smart
2793 readiness perspective but any methodology that makes it a precondition of attaining a smart
2794 readiness rating risks excluding important aspects of smartness which are not contingent on having
2795 smart metering.

2796
2797 Consequently, it could be appropriate to aim to implement the scheme in such a way that it could
2798 migrate towards a measured outcomes approach in the future for those services where this makes
2799 sense. This would require sufficient metering capability to be place as well as the establishment of
2800 agreed normalised ranking systems for the services concerned so that these can be used to create
2801 normalised benchmarks and hence SRI scores (which could be a blend of the input based ordinal
2802 approach, calculated values and measured outcomes). This line of reasoning would also be
2803 consistent with awarding SRI bonuses to buildings that have greater metering (ideally dynamic
2804 metering) of smart readiness outcomes.

2805 **4.6.4. CHECKLIST BASED APPROACHES**

2806 At least one reviewer has proposed that a checklist approach be considered. In fact, the methodology
2807 proposed is based on a checklist method wherein a set of prospective smart services are assessed
2808 methodically and awarded points based on the degree of sophistication of the solution adopted. In
2809 addition to providing an overall SRI score the information assembled from the assessment process
2810 could be used to provide detailed information to the building user/owner on what was scored for
2811 each service against the potential score for each service, supported by ancillary information on what
2812 would be needed to score more highly for each service. Thus, there is no contradiction between the
2813 methodology proposed and the supply of checklist related information to the occupants and owners.

2814 **4.6.5. EVOLUTIONARY HYBRID APPROACH**

2815 Considering the elements reviewed above it seems sensible to envisage an SRI methodology that
2816 evolves from the initial quasi checklist-based score derived using manual on-site assessment to one
2817 that progressively replaces this by calculation, or ideally measured outcome-based assessment for
2818 specific smart services as these become viable. In the event that outcome-based assessments using
2819 dynamic metering become viable then it may no longer be necessary for the specific service to be
2820 assessed manually but rather it could be done via a display interface to the user and/or assessor.

2821
2822 In practice, calculation methods and/or look-up tables using cardinal data could be derived for the
2823 assessment of some of the smart services in the near-term and could be applied in preference to the
2824 less rigorous ordinal ranking assessment approach on a case by case basis. At this juncture a process
2825 could be imagined wherein implementers of the SRI are permitted to use on a smart service by smart
2826 service basis one of the following:

- 2827 a) the ordinal assessment method set out in this report
- 2828 b) an approved calculation-based method

2829 c) an approved metered (measured) outcomes-based method.

2830 As such methods are developed as alternative more-rigorous approaches to the simplified ordinal
2831 method the authorities operating the SRI could grant the freedom to users and/or assessors to use
2832 the more robust approaches.

2833
2834 The modular approach put forward in the basic organisation and design of the SRI methodology
2835 allows this flexibility in the way the SRI is rolled-out. It means that trade-offs related to accuracy and
2836 the ease and speed of assessment can be adjusted based on the willingness of the building
2837 user/owner/manager to engage with the SRI, the resources available to make assessments and the
2838 desire for accuracy. Ordinal assessment can give way to cardinal impacts derived from calculations
2839 or preferably measured impacts as and when such approaches are developed and demonstrated to
2840 be viable for use. This approach ensures that a minimum rigour is always in place but that there is
2841 freedom to evolve and apply more accurate and dynamic assessments for specific services if these
2842 become available. It should be noted that this approach could also potentially allow engagement of
2843 voluntary schemes that go into greater depth for specific smart services.
2844

2845 4.7. ORGANISING AND REPORTING THE SRI

2846 This section briefly considers how the SRI information could be organised and reported to determine
2847 if the methodology is flexible enough to accommodate presenting the SR information within any
2848 preferred reporting structure.
2849

2850 Section 4.1 listed the factors to consider in the SRI's development and highlighted the need for it to
2851 work for each of its key audiences. For it to work as an effective positive change agent it needs to
2852 inform and motivate these audiences to consider the adoption of beneficial smart readiness
2853 technologies within the buildings they have an influence over.
2854

2855 The most important audience is that which makes the capital equipment and services investment
2856 decisions for buildings which therefore brings into play the owners, occupants and facility managers.
2857 These audiences are likely to have a spectrum of needs from SR services and to have priorities that
2858 reflect these. They will need to feel the information presented to them is credible, reliable and
2859 informative but that it reflects their interests and priorities. Equally though the SRI is intended to
2860 work as a policy instrument that helps promote public policy objectives and thus it needs to
2861 encompass both sets of perspectives.
2862

2863 Good practice with the presentation of information to consumers and end-users is to "keep it
2864 simple", and to present numerical data via heuristic scales that aid and motivate the decision-making
2865 process without overloading it. The aggregate SRI scores produced in the streamlined methodology
2866 could be readily transposed into such a scale e.g. in Table 29.

2867 *Table 29 – Example of SRI scores and scale*

SRI	Class
>86%	A
>72%	B
>58%	C
>44%	D
>30%	E

>16%	F
16% or less	G

2868

2869

2870

2871

2872

2873

2874

2875

2876

2877

2878

2879

2880

2881

2882

2883

2884

2885

Such an approach would present an easy way to summarise and communicate the overall SRI value proposition; however, it will certainly invite questions about what it really represents. What type of smartness is being considered within it? What kind of impacts are being assessed? Etc. If users feel they do not understand the rating it is less likely to resonate with them and less likely to impact their decision making. One way to address this could be to complement the overall heuristic classification with additional scoring data that explains more about what is contained within the overall ranking. This could comprise sub-scores or heuristic rankings by impact type, e.g. an A to G or 1 to 5 heuristic ranking for each of the eight impacts identified in the Task 1 work (or a reduced sub-set thereof). Alternatively or also sub-scores could be given by domain. This type of hybrid approach of combining a main ranking that would be emphasised in the presentational format with lower emphasis sub-scores or rankings, which are related to more tangible and hence explicable components, that feed the overall score could allow the users to get the main message at a glance while being able to probe deeper should they want more detail and/or reassurance about the nature of the elements feeding into the overall score. The choice of presentational format (which is not considered here) can also influence the most appropriate blend. Impacts could also be further aggregated into priority groups scores e.g. into energy, flexibility and e-mobility.

2886

2887

2888

2889

2890

2891

2892

2893

2894

2895

2896

Happily the SRI methodology allows all sorts of additional scoring and ranking data to be presented in addition to the principal score and associated heuristic ranking class. In principle, data on scores could be presented by impact type, by domain type or even at each service level in whatever manner is found to be most effective with the target audience. Complementing the overall score with presentation of more granular data also has the benefit of enabling the distinct service offerings to better convey the impact of their services and this will be important in assisting their engagement with and use of the scheme. If service providers find the SRI and related information to be helpful in promoting their services they are likely to use it in their promotional material and to help communicate the value proposition to their customers. This can create an important amplifying effect that allows the scheme to gain traction faster and increase its effectiveness.

2897

2898

2899

2900

2901

2902

The decision regarding the most appropriate level of detail and formats by which the SR information should be presented should be tested through consumer and market research supplemented by stakeholder discussion; however, the key conclusion is that the streamlined methodology is capable of supplying the SR information in whatever level of aggregation or granularity is deemed most beneficial.

2903

2904

2905

2906

2907

2908

Lastly, if the SRI is to act as a stimulus to change efforts will be necessary to explain it and its sub-components to building occupants and owners. Some EPCs now include recommendations on how to best improve the energy performance of a property and the same approach could be implemented for the SRI, wherein recommendations on how best to raise specific aspects of the SRI score are provided. The provision of such information will help to empower occupant/owners in how they can benefit from improved SRTs and services.

2909

4.8. LINKAGES WITH OTHER SCHEMES

2910

2911

2912

2913

The SRI does not act in a vacuum and thus it is legitimate to consider how it might interact with other building policy initiatives and in particular the EPCs, the LEVEL(S) scheme and the building renovation passports.

2914

4.8.1. LINKAGE WITH EPCs

2915 Energy performance certificates (EPCs) are mandated under the EPBD and must be produced and
2916 communicated to prospective purchasers and tenants whenever a building is due to change tenancy
2917 or ownership. Member States may base the EPC assessments on either calculated performance using
2918 standardised methodologies or on measured energy performance (usually based on historic energy
2919 bill data). While EPCs are mandatory the SRI is a voluntary initiative. According to the agreed text for
2920 the revision to the EPBD on a common general framework for rating the smart readiness of buildings:

2921

2922 “10. The Commission shall, by 31 December 2019, adopt a delegated act in accordance with
2923 Article 23, supplementing this Directive by establishing an optional common Union scheme for
2924 rating the smart readiness of buildings. The rating shall be based on an assessment of the
2925 capabilities of a building or building unit to adapt its operation to the needs of the occupant and
2926 the grid and to improve its energy efficiency and overall performance.

2927 In accordance with Annex Ia, the optional common Union scheme for rating the smart readiness
2928 of buildings shall:

2929

(a) establish the definition of the smart readiness indicator; and

2930

(b) establish a methodology by which it is to be calculated.

2931

2932 11. The Commission shall, by 31 December 2019, and after having consulted the relevant
2933 stakeholders, adopt an implementing act detailing the technical modalities for the effective
2934 implementation of the scheme referred to in paragraph 10 of this Article, including a timeline
2935 for a non-committal test-phase at national level, and clarifying the complementary relation of
2936 the scheme to the energy performance certificates referred to in Article 11.

2937

That implementing act shall be adopted in accordance with the examination procedure referred
2938 to in Article 26(3).”

2939

2940 And from Annex 1a:

2941

2942 “1. The Commission shall establish the definition of the smart readiness indicator and a
2943 methodology by which it is to be calculated, in order to assess the capabilities of a building or
2944 building unit to adapt its operation to the needs of the occupant and of the grid and to improve
2945 its energy efficiency and overall performance.

2946

The smart readiness indicator shall cover features for enhanced energy savings, benchmarking
2947 and flexibility, enhanced functionalities and capabilities resulting from more interconnected and
2948 intelligent devices.

2949

The methodology shall take into account features such as smart meters, building automation
2950 and control systems, self-regulating devices for the regulation of indoor air temperature, built-
2951 in home appliances, recharging points for electric vehicles, energy storage and detailed
2952 functionalities and the interoperability of those features, as well as benefits for the indoor
2953 climate condition, energy efficiency, performance levels and enabled flexibility.”

2954

2955 Thus in a formal sense the Delegated Act for the SRI to be prepared by the Commission will clarify
2956 the complementary relation of the SRI to the EPCs.

2957

2958 Without prejudice to the formal policymaking process a number of aspects would need to be taken
2959 into consideration, a non-exhaustive set of which includes:

2960

2961 Potential synergies between the SRI and the EPC including the possibility of a joint assessment
2962 process with the potential to considerably reduce overall assessment costs, a common logic with
2963 regard to the principal intervention moment with the greatest potential to stimulate upgrade in a

2964 building's capabilities (i.e. when changing ownership or occupancy), the potential to share a
2965 communication platform (e.g. potentially SRI information could be integrated into an EPC)
2966 Potential distinctions between the two including that: a) the voluntary nature of the SRI does not tie
2967 its assessment to a change in occupancy or ownership, b) upgrades in smart services may entail very
2968 minor physical interventions in a building and thus are less invasive/inconvenient to occupants than
2969 interventions to upgrade the physical fabric of a building, c) that SRI service offerings (perhaps
2970 provided by or supported by utilities or other service providers) may differ significantly from those
2971 related to the EPC and hence may have a different logic.

2972

2973 In addition to this one of the main issues is to determine the clarity of distinction and/or overlap
2974 between the SRI and the EPC. The SRI is also concerned with building energy performance:

2975

2976 "The rating shall be based on an assessment of the capabilities of a building or building unit to adapt
2977 its operation to the needs of the occupant and the grid and to improve its energy efficiency and
2978 overall performance"

2979

2980 The methodology advanced in this report acknowledges this by including an impact parameter of
2981 energy savings on site and applies this to the BACS related aspects of the TBSs. This is because the
2982 energy savings from smarter operation and control of TBSs are considerable and because many of
2983 the current EPC implementations do little to capture this contribution in a manner that highlights
2984 the potential for improvement. As the EPCs are implemented at MS and/or regional level and thus
2985 more than 28 manifestations are currently in place it is recommended that further work be done to
2986 identify the degree of overlap between the energy savings captured in the EPC methodology
2987 implemented in each MS and those addressed in the draft SRI methodology presented in this report.
2988 This could be a main focus of a follow-up investigation. Such an assessment could help determine
2989 the extent of overlap in: scope, methodology and richness of information, so that more informed
2990 decisions could be made about the potential to use SRI information as an input into an EPC, or EPC
2991 information as an input into the SRI and also about the potential to share common assessment
2992 processes and communication platforms.

2993

2994 **4.8.2. LINKAGE WITH BUILDING RENOVATION PASSPORTS**

2995 Some member states are currently trialling the rollout of building renovation passports that present
2996 a compilation of renovation activities conducted on a building and present owners and occupants
2997 with a continuous record of improvements that have been made. In theory the SRI could interface
2998 with this activity and potentially share some programmatic and content elements. Potentially for MS
2999 that are adopting such building renovation passports the SRI could be incorporated as an additional
3000 module within such documents, and/or the SRI and passports could share the same documentation
3001 process.

3002

3003 **4.8.3. LINKAGE WITH LEVELS**

3004 LEVEL(S) is a voluntary building environmental impact assessment calculator developed by DG
3005 Environment. It promotes a lifecycle analysis assessment of a buildings environmental impact. The
3006 methodology applied involves the following stepwise approach to performance assessment and
3007 reporting:

3008

Table 30 – LEVEL(S) stepwise approach to performance assessment and reporting

Step 1: Define the building to be reported on	✓ Part 3, section 1.1 should be followed in order to define the building, and the associated goal and scope of the performance assessment.
Step 2: Choose the level of performance assessment	✓ Based on the goal and scope of the performance assessment, the appropriate assessment level for the project should be selected from the three available options. ✓ Part 1, section 3.2 provides further guidance on the difference between the three levels.
Step 3: Follow the guidance and rules on how to carry out an assessment	✓ Part 2 provides a general introduction to each indicator. ✓ Part 3 should thereafter be consulted, where guidance is provided for each level on how to carry out a performance assessment. Rules are also laid down for reporting in the public domain. ✓ The Level 1 guidance forms the common basis for all assessments, and should be consulted before using Levels 2 and 3.
Step 4: Complete the reporting format	✓ In each set of technical guidance in Part 3, a format for reporting is provided.
Step 5: Determine the valuation influence and reliability of the assessment	✓ As an optional last step for each indicator, the potential influence on a property valuation and reliability of the data and calculation method may be rated and reported on. Part 3 provides a rating methodology for each indicator.

3009

3010

3011 Three levels of assessment (See Step 2) are possible:

- 3012 • Level 1 common performance assessment
- 3013 • Level 2 comparative performance assessment
- 3014 • Level 3 performance optimisation assessment

3015 The method further defines the following array of macro objectives to be assessed:

- 3016 • Macro-objective 1: Greenhouse gas emissions along a buildings life cycle
- 3017 • Macro-objective 2: Resource efficient and circular material life cycles
- 3018 • Macro-objective 3: Efficient use of water resources
- 3019 • Macro-objective 4: healthy and comfortable spaces
- 3020 • Macro-objective 5: Adaptation and resilience to climate change
- 3021 • Macro-objective 6: Optimised life cycle cost and value

3022 Conduct of the assessments entails evaluating the building's lifecycle impact against the macro-
3023 objectives selected.

3024

3025 In principle LEVEL(S) and the SRI may have some overlap in the degree to which they both entail
3026 assessment of the building energy performance (which contributes to the Macro-objective 1 for
3027 LEVELS) and the assessment of health/comfort (Macro-objective 4 for LEVELS).

3028

3029 For energy use LEVELS applies the following indicators expressed on a per m² of floor area basis:

- 3030 1.1.1 Primary energy demand
- 3031 1.1.2 Delivered energy demand (supporting indicator)

3032 Both are expressed in units of kilowatt hours per square metre per year (kWh/m² /year).

3033

3034 In the case of Health/Comfort LEVELS entails assessing:

3035 4.1 Indoor air quality

3036 - 4.1.1 Good quality indoor air: Parameters for ventilation, CO₂ and humidity

3037 - 4.1.2 Target list of pollutants: Emissions from construction products and external air intake.

3038 4.2 Time outside of thermal comfort range

3039 - % of the time out of range of defined maximum and minimum temperatures during the
3040 heating and cooling seasons

3041 In the case of energy for a common performance assessment, the following calculation methodology
3042 and reporting format shall be used. This requires reporting on the assessment type and the
3043 calculation method used, which shall be based on those required for building permitting and/or for
3044 issuing Energy Performance Certificates (EPCs) in each Member State in accordance with the
3045 Directive 2010/31/EU for the Energy Performance of Buildings (EPBD). Ostensibly LEVELS allows
3046 freedom for users to assess the building energy performance via either the method used in each
3047 national/local EPC implementation and/or via the method set out in the harmonised standards in
3048 support of the EPBD. This means that it has the same degree of overlap and distinction as the EPC
3049 methods do with the SRI with regards to energy performance.

3050

3051 In the case of comfort/health LEVELS entails an assessment of the IAQ. Even in the most basic Level
3052 1 approach it entails a much more in-depth assessment than is implied by the SRI as follows:

3053

3054 Design stage 1: Simulation of the ventilation strategy

3055 A design simulation of the building's ventilation strategy in accordance with EN 16798-7 shall
3056 be used to check the modelled performance of the ventilation rate, CO₂ levels and relative
3057 humidity levels.

3058

3059 Design stage 2: Use of product testing as a means of source control

3060 Test results showing the emissions after 28 days shall be reported for each material or finish
3061 to be installed that falls within the identified scope. The determination of emissions shall be
3062 in conformance with CEN/TS 16516. Test data is therefore required from
3063 manufacturers/suppliers of the selected building products, as defined in the scope. All
3064 testing shall be on the as-finished product.

3065

3066 Design stage 3: Risk assessment to prevent mould

3067 A risk assessment shall also be carried out on building designs. This shall focus on measures
3068 to control point sources of humidity and the avoidance of areas of cold bridging and air
3069 infiltration into the building envelope. The risk assessment shall be made in accordance with
3070 the following two standards:

3071 o ISO 6946 calculation method for the thermal resistance and transmittance of building
3072 materials.

3073 o ISO 13788 calculation method for the hydrothermal performance of building components
3074 and elements.

3075 Thus it is apparent that the LEVELS approach has a different focus to the SRI but also in the areas
3076 where there is some overlap entails a more involved assessment process. The two schemes also have
3077 a different legal foundation. Considering this, there may be a potential for data from a LEVEL(S)
3078 assessment to be used to supply calculation inputs to aspects of an SRI assessment but there is less
3079 scope for an SRI assessment to inform a LEVEL(S) assessment.

3080

3081 **4.9. OPTIONS FOR IMPLEMENTATION**

3082 In practice there are a variety of issues that the implementation of the SRI would need to be able to
3083 address. Some of the most important are considered below.

3084 **4.9.1. ACCOUNTING FOR SERVICES THAT ARE NOT PRESENT**

3085 There is a choice to be made when implementing the SRI as to how to address services which may
3086 not be present in a building but are included in the smart services catalogue. To decide on how to
3087 approach this the scheme needs to assess the service in question to consider the following:

- 3088
3089 a) could it be present? (if not then it should be excluded and the SRI re-normalised),
3090 b) is it relevant? (if not then it should be excluded and the SRI re-normalised),
3091 c) is it sufficiently important to justify the assessment effort?

3092
3093 If case a) applies, it is important that building SRI scores are not penalised when a smart service
3094 cannot reasonably be present e.g. for a building with no parking facilities it is not reasonable to
3095 expect these to be added to the building simply so smart EV charging can be included.
3096

3097 When considering case b) it is important that building SRI scores are not penalised for non inclusion
3098 of a service which is not relevant for that building. E.g. if a building doesn't have parking facilities
3099 (because, for example, it is an upper story apartment in a building with no surrounding parking space)
3100 then it is reasonable to exclude the Electric Vehicle domain services from the SRI calculation and
3101 renormalize the score. The same could apply for other service domains such as cooling (e.g. for a
3102 passively cooled building or for buildings with negligible cooling loads), and dynamic building
3103 envelope (if adequate passive shading features are present on the building or if the building is shaded
3104 by other buildings or natural features).
3105

3106 *Determining relevance at the domain level*

3107 It is less straightforward to decide how to treat a service that is not included in a building but that
3108 may be relevant. The logic to be applied to determine relevance is not always clear cut from a public
3109 policy perspective and nor is it always a straightforward technical judgement. A simple way to
3110 address the issue could be to base the implementation of the SRI on those *domains* that are present.
3111 Thus, if a whole domain is absent from a building then all its smart services would be ignored and
3112 the SRI renormalized following their exclusion. This approach might be deemed to be suitable for
3113 services such as HVAC which are dependent on climate and building design, but not for others where
3114 public policy seeks to promote the whole domain, such as DSM. This approach would essentially
3115 defer to the building owner's judgement as to whether a services domain provided enough value to
3116 merit being included in their building.
3117

3118 Some service domains such as lighting and monitoring and control are always needed so they would
3119 invariably be included in the SRI calculation. DHW will almost always be needed but if it does not
3120 include storage and/or is not provided by electrical or solar power then none of the smart services
3121 listed in the current smart services catalogue apply. In this case a judgement will have to be made
3122 about whether they consider it appropriate to exclude the DHW services and renormalize for
3123 buildings that have DHW systems which are incompatible with the smart services or whether they
3124 wish to use the SRI to promote DSM relevant DHW solutions to the extent that non-DSM compatible
3125 solutions are penalised in the SRI score (this is a policy determination issue). The energy generation
3126 domain is another where the SRI scoring may or may not be linked to its presence. If it is linked
3127 buildings with no energy generation capability would achieve lower aggregate scores (all other

3128 factors being equal) than those that do. If it is not linked then the smart services that pertain to
3129 energy generation would be excluded from a renormalized SRI calculation if the building did not have
3130 energy generating capability.

3131

3132 *Determining relevance at the sub-domain (i.e. services) level*

3133 If a domain is present it doesn't necessarily follow that a smart service applicable to that domain is
3134 always relevant. For example, heating will be present in most buildings but only a few will have
3135 thermo-active heating systems (TABs) and so the service Heating-1b is only relevant for those which
3136 do. This is a similar issue to the case of DHW i.e. the service should be excluded when TABs are not
3137 present and the SRI calculation renormalized accordingly unless decided otherwise. However, this is
3138 not the case if the service would provide additional benefit for the overall functionality of the domain
3139 it applies to. If this is true then the service should be retained in the normalisation calculation process
3140 unless it is not deemed to be sufficiently important to justify the assessment effort (see the
3141 discussion of the streamlined method in section 3.4).

3142

3143

4.9.2. SMART SERVICES PRESENT IN DIFFERENT PARTS OF THE BUILDING

3144 The impact of some smart services are sensitive to their spatial distribution within a building. This is
3145 the case for those smart services that apply to heat emission control, cooling emission control,
3146 ventilation zonal control, and lighting. It may also be the case for heating production, cooling
3147 production, DHW, ventilation control, and EV charging where different solutions are used in different
3148 parts of the building.

3149

3150 From a technical perspective the equitable approach to be applied to the SRI assessment process
3151 where spatially distinct solutions are applied in different parts of a building would be to apportion
3152 smart service scores on a pro rata basis of their delivery of the principal service. As a first order proxy
3153 floor area can be used to distinguish this. Thus if 60% of the building floor area is heated with a given
3154 solution and 40% with another then a pro-rata apportionment would be applied to the service
3155 assessment. This methodological approach is not new. Approaches which differentiate assessment
3156 as a function of building floor area served by a given service on are already adopted in many national
3157 building energy codes that, for example, set requirements for lighting levels and energy consumption
3158 or installed power differentiated by the type of function conducted in the various parts of a building.
3159 Many EPC calculation tools will also make such distinctions. However, bringing in distinctions by floor
3160 area will also complicate the assessment process and hence add to the assessment time and effort.
3161 Thus, there is a trade-off to be considered and managed.

3162

3163

4.9.3. COMPLEX (MULTI-MODE) BUILDINGS

3164 Complex buildings are those where there are quite distinct and divergent activities carried out in
3165 different parts of the building. For example, a building which is a hospital that includes shopping
3166 outlets, or a large multi-family residence building that includes floor area used for commercial
3167 activities etc. Complex buildings may also include multiple tenancy or lease arrangements that could
3168 share common facilities and hence some technical building systems/smart service domains.

3169

3170 The same issue applies to the SRI assessment of such buildings as it does for EPCs and other building
3171 performance assessment tools, of how to delineate the boundaries that the SRI applies to within a
3172 building. In this case it is probably most practical to follow the property boundary delineation

3173 practices used in EPC assessments to the extent possible. This may often entail treating the internal
3174 building boundaries of the complex building based on the lease or tenancy arrangement, which will
3175 often result in a reasonably homogeneous activity mode occurring within the boundary the SRI would
3176 apply to. However, in some cases it may not and in these instances, if more than one modal activity
3177 is occurring within the same SRI rating boundary and the technical building systems are
3178 differentiated by activity mode then it may be sensible to derive a pro-rata SRI for the distinct
3179 sections of the building.
3180

3181 **4.9.4. CLIMATIC ZONES**

3182 Differences in climate, as represented by distinct climatic zones, will have an impact on the relative
3183 prevalence and importance of HVAC related TBS (heating, cooling, ventilation) and to a much less
3184 extent hot water energy demand (due to variations in the feed-in cold water temperature and hence
3185 the magnitude of temperature lift needed). Climate also has an impact on the importance of the
3186 dynamic building envelope with regard to solar shading and on the magnitude of energy generated
3187 per unit area of solar collectors/panels or by wind generators.
3188

3189 The importance of this variation for the application of the SRI methodology is that the differences in
3190 climate can result in some TBS/domains not being very prevalent in some climate zones and/or
3191 having a lesser relevance when they are present (e.g. the energy use may be significantly lower than
3192 for an equivalent building in a different climate). As previously discussed in section 3.9.1 if a
3193 TBS/domain is not present because it is not needed it implies that the SRI calculation should generally
3194 omit that service and be renormalized accordingly. In some cases, it might also be relevant to apply
3195 a climate adjusted weighting to the TBS/domain and then apply a filter for impact benefit against
3196 assessment effort to determine whether the service has a sufficient impact to justify its inclusion in
3197 the streamlined scheme.
3198

3199 By way of illustration, one can consider the (provisional) ordinal impacts allocated against each
3200 service and impact parameter by the study team (see the services catalogue). For a building with
3201 heating, cooling, DHW, controlled ventilation, a dynamic building envelope and energy generation
3202 and a typical set of eligible (i.e. not mutually exclusive) smart-services the share of eligible points by
3203 domain as a proportion of the total eligible points across all of these services and impact parameters
3204 is as follows (assuming equal weighting by domain):

- 3205 • Heating = 25%
- 3206 • Cooling = 17%
- 3207 • DHW = 8%
- 3208 • Controlled ventilation = 19%
- 3209 • Dynamic building envelope = 9%
- 3210 • Energy generation = 23%

3211
3212 According to the analysis in the Task 5 impact assessment for an average European office the ratio
3213 of heating to cooling primary energy consumption as a function of main climatic region and the year
3214 considered is projected to be as follows:

- 3215 • Europe West = 10.3 in 2020; 4.8 in 2050
 - 3216 • Europe North = 7.5 in 2020; 2.6 in 2050
 - 3217 • Europe South = 1.6 in 2020; 1.0 in 2050
- 3218

3219 If the relative magnitude of energy is also taken to be a proxy for that for comfort and convenience
3220 then the relative importance of the heating and cooling domains could be weighted accordingly
3221 (there are much lesser contributions from these domains to the other impact parameters).
3222 The impact of climate on the relative importance of the other domains mentioned (DHW, controlled
3223 ventilation, DBE and energy generation) is less apparent and hence it might be practical not to adjust
3224 their weightings based on climatic differences unless detailed evidence becomes available to
3225 establish clear correlations.

3226
3227 Thus as a first order proxy weightings applied to the heating and cooling domain scores could reflect
3228 their expected importance for the type of building considered. In principle, if building energy
3229 calculations are available by domain, this information could be used to derive the weightings but if
3230 not then regionally average figures could be applied. The regional average approach might also be
3231 used to decide whether it is sensible to include the domain at all e.g. if cooling is almost never present
3232 in a given locale and building type then the SRI assessment could simply omit it; or if it is present but
3233 its impact is very modest it could also be omitted to economise on assessment effort.

3234 **4.9.5. SHOULD DIFFERENT CATEGORIES OF BUILDINGS BE TARGETED?**

3235 One issue to be considered is whether the SRI should apply to all buildings or certain categories of
3236 buildings? In principle, it can apply to all buildings and as the methodological examples illustrate the
3237 methodology can be adapted to differentiate according to the type and complexity of building
3238 considered (albeit drawing from the same technical foundations). However, from an implementation
3239 perspective there could be a rationale to implement it progressively differentiating by type of
3240 building. If the SRI is implemented in a voluntary manner then it will make most sense to initially
3241 target it to the building types whose owners are most likely to be interested in having the SRI.
3242 However, it is not clear at this stage whether there will be a difference in interest and hence SRI
3243 adoption rates as a function of the building type. On the one hand commercial buildings have higher
3244 energy use per unit area and are more prone to sick-building issues than domestic buildings and
3245 hence it is possible that owners will wish to use the SRI to illustrate that their buildings are smart and
3246 to use this as part of the rationale underpinning the rental value. On the other hand, many
3247 householders are also likely to be interested in an evaluation of how smart ready their building is;
3248 especially if it is complemented by advice on what other options there could be to make it smarter.

3249
3250 Within the spectrum of commercial buildings it may be that owners of so-called class A buildings (i.e.
3251 those with higher rental values) may tend to have a greater interest in using a voluntary indicator to
3252 differentiate the quality of their buildings than owners of lower rental value buildings, but this is
3253 supposition that would need to be tested in the market. Furthermore, assuming the object of
3254 targeting the most promising (from a readiness to adopt the SRI perspective) building types is to
3255 progressively roll-out the SRI and gain momentum and impact in the market, then it may be best to
3256 begin with a sector that is most receptive to government policy initiatives. In particular, public sector
3257 buildings might provide a basis to pilot the scheme prior to rolling it out on a broader base of
3258 buildings.

3259

3260 **4.9.6. BUILDING INFORMATION MODELLING**

3261 Building information modelling (BIM) is increasingly being used to share information between
3262 building professionals and their clients and to create an electronic log of the layout and systems
3263 installed in a building. It is used in the design stage to allow architects and building service engineers

3264 to agree on the functional arrangements so that an appropriate compromise between the different
 3265 design needs of the building and the actors charged with delivering them can be addressed. The
 3266 design BIM data can also help inform discussion and decisions between clients and building
 3267 professionals prior to a final design being settled. Once the building is constructed the data files and
 3268 software can be left with the client who can then request that future service providers also update
 3269 the information every time they make an amendment to the building or its technical building
 3270 systems. This has the potential to create a digital logbook for the building that tracks its initial
 3271 conception and all subsequent additions and amendments. When BIMs are in place they constitute
 3272 an obvious tool that could be used by an SRI assessor to help facilitate the SRI assessment. Should
 3273 standard BIM protocols become the norm then SRI assessors could even request access to the data
 3274 prior to a site visit and that way plan their inspection and/or pose pertinent questions ahead of the
 3275 site visit.

3276 **4.9.7. INTEROPERABILITY, BROADBAND AND SMART METERS**

3277 The degree of interoperability of smart systems and related technical building systems/domains is
 3278 likely to be a critical issue for the smooth operation of smart systems; however, it is also a very
 3279 challenging issue to address in practice and especially within the auspices of the SRI.

3280
 3281 The quality of broadband access will be critical for many smart systems to function smoothly and
 3282 especially those that require information exchange between systems within the building and agents
 3283 or systems which are off-site. Articles 8 and 9 of the Directive on *measures to reduce the cost of*
 3284 *deploying high-speed electronic communications networks* (2014/61/EU) ensure high-speed-ready,
 3285 accessible in-building physical infrastructure in all newly constructed and majorly renovated
 3286 buildings and introduce a voluntary *broadband ready* label at member state level. This could be
 3287 provided as an additional or complementary piece of information to the SRI.⁴⁵

3288
 3289 Smart meters have been or are being rolled-out across a large proportion of EU buildings, with
 3290 programmes being managed at the Member State or smaller regional level. Smart meters provide an
 3291 important source of real-time utility consumption (energy or water) information to building
 3292 occupants which can help them to optimise or adapt their usage to their needs and to variations in
 3293 the tariff. They can also facilitate DSM services and metering of on-site energy generation.
 3294 Consequently, smart metering related services are included in the smart readiness services
 3295 catalogue. In particular in the monitoring and control services 5 to 7, and 13.

3296
 3297 While these services provide functionalities which are an important enabler of DSM services and of
 3298 also feedback to users on their consumption/generation patterns, they are not a precondition to be
 3299 able to attain a SRI score as not all smart services are contingent on this capability. However, they
 3300 do feature prominently within the scoring system, and buildings with smart-meter related capacities
 3301 will have incrementally higher SRI scores than those without.

3302

3303 **4.9.8. INDUSTRY AND SECTOR SPECIFIC INDICATORS**

3304 Some industry and service sectors have developed or are in the process of developing smart service-
 3305 specific indicators that apply to specific technology and service offerings. It is an open question of
 3306 how these might work with the SRI. Potentially, these schemes could provide value to the SRI by:

⁴⁵ <https://ec.europa.eu/digital-single-market/en/building-infrastructure>

- 3307
- 3308
- 3309
- 3310
- 3311
- creating additional leverage and incentive for building owners to engage
 - adding additional sophistication to the depth and integrity of the assessment for the services they address
 - providing a common framework to assess a smart service that is not currently adequately covered within the SRI.

3312

3313 Nonetheless, a process would need to be determined to establish if and how they could be integrated within the SRI. Such a process would need to ensure they represent value for the public good and provide a level playing field for economic agents operating both within the service domain as well as in the other smart service domains. There are already a number of such industry or collaborative initiatives known to the study team which include at least the following:

3318

3319

3320

3321

3322

- the eu.bac labelling scheme for BACS and BAC components
- a Lighting Europe initiative for smart lighting systems which is under development
- an IEA Annex 67 Technology Collaboration Programme initiative to develop an indicator for DSM services.

3323

3324

3325

3326

3327

3328

3329

3330

The nature of these initiatives are quite varied and so there is no fixed approach that be proposed regarding how their interaction with the SRI could be considered. The eu.bac scheme has been operational for a few years and is implemented on a voluntary basis. Their BACS labelling scheme is based on doing detailed audits of buildings against the provisions of the EN 15232 standard, and hence shares many aspects with the smart service definitions and performance levels proposed in this study for use with the SRI. Eu.bac have developed their own assessment tools to support their assessors and potentially some aspects of these could be suited to some aspects of the SRI assessment process.

3331

4.9.9. DIFFERENTIATION AND COMMONS ASPECTS OF SRI IMPLEMENTATION

3332

3333

3334

3335

3336

3337

3338

3339

3340

3341

3342

3343

3344

3345

3346

3347

3348

The agreed text of the revised EPBD ensures that the Commission is responsible for developing a common methodology for the SRI which Member States may then implement on a voluntary basis. Clearly, this means that Member States should find the SRI an attractive proposition that provides value added to building owners/occupiers, product & service providers and aligns with public policy objectives. The methodology set forward in this report is fundamentally flexible to needs. It has also highlighted a number of instances where it may not always be appropriate to include, or conversely exclude, a service due to differences in local circumstances such as climate, common practice and local constraints. A measure of local flexibility is desirable to allow these distinctions to be taken into account. However, on the other hand the benefits of following a common and inclusive approach, wherever this is not inconsistent with specific local circumstances, should not be ignored. Building owners are likely to find value in receiving information on the full panoply of smart services outlined in this report and an overly narrow implementation that excludes many services is more likely to be challenged for being partial and selective, which may undermine its integrity among stakeholders. Furthermore, a common approach across the EU allows relevant product and service offerings to be rolled out more easily and hence adds greater value to the SRI. It also reduces the risk of confusion among users, if they see that the SRI in neighbouring countries is essentially the same as in theirs.

3349

4.10. APPLICATION OF THE STREAMLINED METHODOLOGY TO ACTUAL BUILDINGS

3350

3351

To test the streamlined methodology in reality it was field tested on two actual buildings. The first is a traditional single family house in the north of England and the second is a modern office in Flanders.

3352 **4.10.1. FIELD CASE STUDY – A TRADITIONAL SINGLE FAMILY HOUSE**3353 **Case study SFH: case study description**

3354 The house in question (Figure 16) is sited in Manchester (UK) and was built in 1902. It is a relatively
3355 large (~250 m² floor area), three story detached house with parking areas immediately adjacent to
3356 the property and with a garage that is used for storage rather than parking. While most of the
3357 property was from the original construction there were a number of parts which had been
3358 renovated. The back of property had a recently constructed conservatory/kitchen space and an
3359 adjacent office area (Figure 17). The walls had been insulated 15 years previously with insulation
3360 injected into the cavities between the interior and exterior brick layers, but more recently underfloor
3361 insulation had been added to the whole ground floor, and many rooms as well as all the top roof
3362 area of the house had had interior solid insulation applied. The windows were all renovated with
3363 modern double glazing made in keeping with the original window aesthetic. As a result the property
3364 is well insulated.
3365



3366

3367 *Figure 17 -Single family house assessed in field study – front view*

3368



3369

3370

Figure 18 -Single family house assessed in field study – rear view

3371

3372

3373

Case study SFH: Assessment process and findings

3374 The process followed was to make an appointment with the occupant to conduct the SRI assessment.
3375 Once the assessment began the assessor was invited into the kitchen/conservatory area to explain
3376 the purpose of the SRI and discuss the TBS and domains present in the building. The assessor was
3377 then invited to view all the rooms and to inspect the TBS's/domains at their leisure.

3378

3379 Following the introduction of the purpose of the SRI the assessor asked the occupant if they had any
3380 of all the domains treated under the SRI:

3381

- Heating

3382

- Cooling

3383

- Hot Water

3384

- Controlled ventilation

3385

- Lighting

3386

- Dynamic building envelope measures

3387

- Self generation

3388

- Demand Side Management

3389

- Electric vehicle charging

3390

- Monitoring and control

3391

3392 This served as a rapid triage process to establish which domains needed to be considered and which
3393 were absent. From the discussions which took about 5-7 minutes it quickly became clear that there
3394 was no cooling, self generation, or demand side management, but there was some doubt about the
3395 controlled ventilation and dynamic building envelope measures. As would be expected for any

3396 property in this region heating, hot water, lighting, and monitoring and control domains were all
3397 present. For electric vehicle charging it soon became apparent there was an option to provide the
3398 most basic dumb charging capability but nothing more.

3399
3400 The discussion of these domains with the occupant was mostly straightforward. In the case of cooling
3401 there was no benefit from cooling in the local climate and so none of the households in the area have
3402 it. For self generation, the owners had conducted an assessment with a mind to install it but had
3403 concluded that the only viable location for PV panels was on the garage roof because the main
3404 orientation of the house is east-west, the front (east side) of the property is overshadowed by a very
3405 large tree and the back has constrained roof spaces which are partially overshadowed by large
3406 chimneys. PV had not yet been installed on the exterior garage because the whole building is in need
3407 of renovation; but this is reported to be planned in the future.

3408
3409 Potentially the most challenging issue would be to establish if any DSM services are in use. The
3410 general public is not familiar with the terminology nor the concept of DSM and thus it has to be
3411 approached obliquely. In principle, DSM is a service option for households in the UK and some
3412 aggregator services exist to cluster sites in order to create sufficient demand to satisfy the minimum
3413 eligibility requirements to bid into the capacity markets; however, these services are still very rare,
3414 have only recently been proposed on the market and are initially focused on non-residential users –
3415 thus, it would be very unusual to find a property benefitting from DSM services currently. The
3416 approach taken by the assessor to probe this topic was to ask about the tariff applied on the
3417 property, whether there was any smart metering and to see if it was a conventional tariff or had time
3418 of use or other significant DSM relevant characteristics. Then, to validate the response, to ask if the
3419 electricity utility was offering any tariff incentives to be able to externally control electrical
3420 equipment to avoid it being used in time of peak demand unless the user chose to pay a higher tariff.
3421 From this it was rapidly established that the property was not currently using any DSM services. It
3422 was also apparent that the occupant had not been contacted by any provider of such services.
3423 Once this triage process was complete the assessor visited each of the rooms with the occupant and
3424 conducted a visual inspection of the TBS/domains.

3425
3426 From this it became clear that:

- 3427
- 3428 • There was no controlled ventilation as defined within the streamlined methodology. Rather,
3429 there were manually operated extractor fans in each of the bathroom and toilets and within
3430 the kitchen hood over the hob (see Figure 18).
 - 3431
 - 3432 • Solar control was provided by manually operated blinds, shutters and curtains – these were
3433 present in all relevant rooms and were certainly sufficient to address glare, thermal comfort
3434 and privacy needs (see Figure 19).
 - 3435
 - 3436 • Interestingly, the conservatory had an automatically dual sensor (interior temperature and
3437 external rain) controlled motorised top vent (Figure 20) that the user programmed to open
3438 as a function of the conservatory temperature (it shuts automatically if its rain). This is a
3439 smart ventilation/solar control technology, however, it does not feature in the streamlined
3440 methodology service list.
 - 3441
 - 3442 • The lighting (e.g. see Figure 21) was all manually controlled with either on-off switches or
3443 dimmer switches. The exception was one downstairs toilet that had a occupancy sensor
3444 which controlled the lighting (see Figure 22). The exterior of the property had motion sensor

3445 controlled security lighting with manual override. All the lighting in the property was energy
3446 efficient, with most being LED but a few fluorescent lights too.
3447

3448



3449


Figure 19 -Ventilation only via extractor fans

3450

3451

3452

3453



3454

3455

Figure 20 -Manual blinds/shutters for solar control and thermal comfort


3456



3457

Figure 20 -Automatic smart conservatory top vent

3458




3459

Figure 21 -Lighting – mostly LED and all manually controlled

3460

3461

3462



3463

3464

Figure 22 -Presence detection lighting via a motion sensor

3465

3466

3467

3468 The dominant source of energy consumption in the property are the heating and hot water domains.
3469 The heating was provided by two heat generators (one gas condensing combi-boiler and one gas
3470 system boiler) with the condensing boiler providing all the heating and hot water needs for the
3471 ground floor and one middle floor bathroom, and the system boiler providing the heating and hot
3472 water needs for the top floor and the rest of the middle floor.

3473

3474 On the ground floor the large kitchen/conservatory area (Figure 23) and the office are both heated
3475 by underfloor hydronic heating. The rest of the ground floor rooms (two reception rooms, a utility
3476 room, a toilet and hallway) and the middle floor bathroom are heated by radiators. Control of the
3477 heating is split into 3 zones (the kitchen/conservatory, office and rest of the ground floor) each with
3478 their own central thermostat and programming. The condensing boiler services these zones on
3479 separate hydronic loops, each operating at their own temperature and supplied through a manifold.
3480 The system boiler is sited in the roof eaves on the top floor and feeds a hot water storage tank and
3481 the upstairs heating circuit (Figure 24). In total it supplies heat to six bedrooms, two bathrooms and
3482 the stairwells and landings. All of the heating in these areas is via radiators.

3483

3484



Figure 23 -Kitchen/conservatory with underfloor heating

3485

3486

3487

3488

3489



Figure 24 -System boiler and hot water storage tank

3490

3491

3492

3493 *Degree of smartness in the space heating and hot water domains.*

3494 There are a number of smart features in the control and management of the heating and hot water
3495 in the property as follows (Figure 25).

3496

- 3497 • programmable temperatures scheduled by hour, day, and day of week/year in each of the 4
- 3498 control zones
- 3499 • weather compensation
- 3500 • self-learning optimum stop/start
- 3501 • TRVs on all emitters (excluding the underfloor heating)
- 3502 • VSD controlled distribution pumps
- 3503 • remote management of all heating and hot water via smart phone app
- 3504 • occupant (smart-phone) presence detection option
- 3505 • historical record and display of heating and hot-water consumption
- 3506

3507 The programmable temperature controls can be managed from either wall mounted control devices
 3508 or via the smartphone app and in the latter case can be managed at a distance and optionally set to
 3509 recognise when the occupants are not home (via smart home tracking) and hence switched to
 3510 unoccupied defaults. The display of the heating and hot water consumption enables the user to keep
 3511 track of their consumption and see the impact of technical or behavioural changes.


3512

3513 The TRVs on all the radiators ensure that the heat emitted from each emitter can be temperature
 3514 limited, although they are not remotely programmable and nor are they linked to room temperature
 3515 sensors or occupancy sensors. The VSD distribution pumps ensure the flow within each zone is fully
 3516 adjustable and that the pump energy consumption is optimised. The weather compensation
 3517 combined with the self-learning optimum start/stop functionality ensures that for each of the four
 3518 zones the heating energy is provided optimally based on the thermal response rate of the zone, the
 3519 dynamic interior-exterior temperature difference and the programmed set-points specified by the
 3520 user. Once the self-learning system has determined the thermal response rate of the room (by a
 3521 period of progressively more refined iterative heating to the set-point as a function of the interior to
 3522 exterior temperature difference) the system learns when the heating needs to be activated at what
 3523 temperature to achieve a given temperature lift within a given period. Critically, combined with the
 3524 weather compensation system linked to local weather forecasting, this allows the smart controls to
 3525 raise or decrease the temperature in an energetically optimal manner to meet the user comfort
 3526 needs, and thus saves significant amounts of energy while optimising comfort.

3527

3528

Figure 25 -Smart controls for the heating and hot water



3529

3530 **Case study SFH: Assessment time and scoring**

3531 Prior to this exercise it had been estimated that for an average single family house of say 100 to 120
 3532 m² a typical SRI assessment would take between 32 and 41 minutes depending on the degree of
 3533 documentation available. In fact this case study took 35 minutes to assess including the time spent
 3534 discussing with the occupant and a further 5 minutes for data entry into a spreadsheet tool used to
 3535 calculate the SRI score and sub-scores. As this is a large house – over 250 m², with six bedrooms,
 3536 three bathrooms, an office, utility room, toilet, open-plan kitchen/conservatory area and two living
 3537 rooms and one with comparatively complex TBSs (dual heat generators, multiple zones etc.) and a
 3538 moderate degree of smartness – it is likely that this is the upper bound of the time it would take to
 3539 conduct such surveys for more typical properties. However, for properties with all possible TBSs and
 3540 full smart functionality (which will be very rare in practice) the time required would be longer.

3541
 3542 Communicating the score to the occupant per impact field took about 5 minutes but explaining what
 3543 could be done to attain a better score would take additional time and this is not accounted for in the
 3544 assessment time presented above (in fact it was not possible to do in this case study as the occupant
 3545 had to leave for another engagement).

3546
 3547 Overall the property was given an SRI score of 45% under the streamlined methodology. However,
 3548 the results are also reported by domain and by impact parameter (Table 31).

3549 *Table 31 -SRI scores for the single family house field study*

	Energy	Flexibility	Self generation	Comfort	Convenience	Well-being and health	Maintenance & fault prediction	Information to occupants	SRI
Overall	71%	0%	0%	77%	33%	17%	20%	19%	45%
Heating	75%	0%	0%	85%	64%	0%	25%	75%	
DHW	100%	0%	0%	0%	0%	0%	50%	67%	
Cooling	0%	0%	0%	0%	0%	0%	0%	0%	
Ventilation	0%	0%	0%	0%	0%	0%	0%	0%	
Lighting	0%	0%	0%	0%	0%	0%	0%	0%	
Dynamic envelope	0%	0%	0%	0%	0%	0%	0%	0%	
Self generation	0%	0%	0%	0%	0%	0%	0%	0%	
DSM	0%	0%	0%	0%	0%	0%	0%	0%	
Electric Vehicles	0%	0%	0%	0%	20%	0%	0%	0%	
Monitoring & control	60%	100%	0%	67%	38%	33%	17%	14%	

3550
 3551
 3552 In terms of impact parameters the property scored most highly for Energy Savings on Site and
 3553 Comfort both of which were relatively well satisfied via a number of smart services of quite high
 3554 functionality. As heating and hot water dominate the energy consumption the weightings applied to
 3555 these services reflect this (in fact for simplicity the nominal EU building stock average values shown
 3556 in Table 21 were used for these weightings; however, in principle progressively more accurate
 3557 weightings could be used by applying UK average, local average, EPC calculated or actual measured
 3558 TBS values for this kind of/or actual property). As there was no DSM capability the property scored
 3559 0% for the flexibility impact parameter and similarly 0% for self-generation.

3560
 3561 At the domain level it scored 0% for the missing domains or the domains where there was no smart
 3562 functionality recognised within the streamlined methodology i.e. for cooling, ventilation, dynamic
 3563 building envelope, self generation, DSM, and electric vehicles.

3564
 3565 In this example, the domains highlighted in grey were excluded from the calculation of the overall
 3566 score for the reasons that: cooling offers no value in this location and building type; dynamic building
 3567 features are not needed (i.e. bring negligible benefit) for this kind of property in the location it is in
 3568 provided adequate manual shading systems are in place (which they were); similarly natural

3569 ventilation is adequate for such a property type; and self-generation was (for the reasons stated
3570 previously) not currently a viable option for the property concerned. All other domains did count
3571 towards the overall score. It should be noted that the methodology allows for the absent domains
3572 to be included or excluded from the overall score calculation as the governors of the scheme deem
3573 fit. Equally, in this example the absent domains of DSM and EV charging were included in the overall
3574 score as these are both central elements of the rationale for the SRI within the agreed EPBD text and
3575 it was deemed that these could be present and would bring benefits if they were. While the
3576 interpretation of what should or should not be included in the overall normalised score under what
3577 circumstances will doubtless require further discussion and refinement ahead of an SRI
3578 implementation, to ensure the right blend of consistency of approach and recognition of locally
3579 pertinent factors, it was interesting that this was very simple to communicate to the occupant,
3580 despite the occupant having no prior knowledge of the SRI. It was quickly explained that the greyed
3581 out domains did not contribute to the overall score and why, but also that the occupant/owners
3582 might still wish to add such services in the future. The matrix reporting approach with each sub-score
3583 seemed to assist considerably with the communication of the elements of the SRI and the domains
3584 and impacts which are being treated within it. The occupant seemed to understand and be
3585 comfortable with the summary provided when presented with this matrix. Thus, it would appear
3586 from this single case study that presenting the overall score and the sub-scores might greatly
3587 facilitate communication and avoid misunderstanding of the elements of the SRI. Further details of
3588 the calculation applied are presented in Annex M.
3589

3590 **4.10.2. FIELD CASE STUDY – A CONTEMPORARY OFFICE BUILDING**

3591 **Case study office building: case study description**

3592 The second case study building is a contemporary office building located in Genk; which is situated
3593 about 100 km east of Brussels in the Flemish region of Belgium. This ‘EnergyVille 1’ building was
3594 designed by Atelier Kempe Thill and inaugurated on 22 September 2016. It features offices, meeting
3595 rooms and laboratory facilities for 250 of the EnergyVille staff members. It is part of the ‘Thor’ science
3596 and business park⁴⁶ on a previously abandoned coal mine site.

3597 The building is constructed to high energy efficiency standards (e.g. well insulated building envelope
3598 with triple pane glazing). The energy performance label according to Flemish EPBD regulations is E-
3599 level 23, which is lower than the nearly-zero energy building (NZEB) standard of E-level 40 for offices.
3600 This corresponds to an estimated primary energy demand for heating, cooling, ventilation and
3601 lighting of 53 kWh/m²/yr. The building is aiming to achieve the BREEAM Post Construction
3602 “excellent” label.

3603
3604 Being conceptualised as a ‘living lab’, the buildings contains many innovative technologies such as
3605 test ground for demand response, seasonal thermal energy storage, battery storage, fourth
3606 generation district heating, DC grid (± 500 VDC, 35 kW), etc. More common TBS include ground
3607 sourced heat pumps and combustion boilers and a roof covered with 1070 photovoltaic panels.
3608 Throughout the building 350 sensors are installed to monitor comfort and meter the energy
3609 consumption.

3610
3611 By having such a wide array of TBS in this somewhat experimental building, the building is likely to
3612 have much more smart ready services to be assessed than more traditional office buildings.

⁴⁶ <http://www.thorpark.be/en>

3613
3614



3615

3616

3617

Figure 21 -EnergyVille office building assessed in field study – front view



3618
3619

3620

3621

Figure 22 -EnergyVille office building assessed in field study - interior view



3622

3623

Figure 23 -EnergyVille office building assessed in field study - rear view

3624

Case study office building: Assessment process and findings

3625

3626 Similar to the process described for the single family house, the inspection process starts with
3627 investigating which services are relevant for this particular building.

3628 The building is actively heated and cooled, has a limited domestic hot water production, is equipped
3629 with moveable sun shading and features EV charging poles and locally generated renewable energy.
3630 Furthermore, the presence of two complementary heating systems (both heat pumps and
3631 combustion boilers) adds to the fact that most of the smart services in the streamlined catalogue can
3632 be assessed in this building. Of the 51 smart ready services present in the streamlined methodology,
3633 the triage process resulted in 44 services to be assessed for the EnergyVille I building. The few
3634 services which are not relevant include for example the control of solar hot water boilers and TABS
3635 (thermally activated building systems such as concrete core activation), since none of these TBS are
3636 present in the building.

3637

3638 A particular point of attention is the DSM domain. DSM services are currently very rarely offered for
3639 TBS in Belgian buildings. The EnergyVille I building nevertheless has some DSM capabilities which are
3640 used for testing and demonstration purposes. In the assessment of the case study, the DSM
3641 capabilities were assessed as if they were operational under true market conditions.

3642

3643 The assessment took place in close consultation with the building's facility manager. The triage
3644 process took place at the desk of the facility manager, with the building's as-built plans and technical
3645 documentation within reach. For some of the services, additional look-ups were needed, e.g.
3646 regarding the presence of a bypass of the heat recovery unit in the ventilation system to prevent
3647 overheating. For most of the services, the assessment of the functionality levels could already
3648 tentatively take place while performing the initial screening.

3649

3650 After the initial assessment at the facility manager's desk, a walk-through of the building was
3651 organized to confirm the functionality levels of the various smart ready services.

3652 To save on inspection time, the walk-through was limited to the utility rooms and some
3653 representative rooms (e.g. an office space and a meeting room). If in these representative rooms a
3654 specific functionality was present, it was assumed this is the case for the whole building. For example,

3655 in both the office and meeting room, the service Lighting 2: “Control artificial lighting power based
3656 on daylight levels” was implemented with functionality level 3 = “automatic dimming”. It is thus
3657 assumed that this is true for the remainder of the building as well, which was also confirmed by the
3658 facility manager.

3659
3660 For some of the services, there was currently still a need for interpretation by the SRI assessor, e.g.
3661 to map the EV charging capacity indicated on the charging pole to the proposed functionality levels.
3662 Further substantiation of the method and the development of inspection protocols will reduce the
3663 need for interpretations and result in more uniform inspection results.

3664
3665





3666

3667

3668

Figure 24 -EnergyVille office building: EV charging equipment




3669
3670
3671
3672

Figure 25 -EnergyVille office building: heating and cooling ductwork, heat pump, combustion boiler, DHW storage vessel, presence and luminance detection, roof-mounted PV

3673 For many of the services, a visual inspection was sufficient to determine the functionality level. For
3674 some other services - especially those implemented at higher functionality levels - additional
3675 information was required. This was retrieved either by interviewing the facility manager, either by
3676 investigating the technical documentation of the installed equipment.

3677 For example, it was visually confirmed that both a combustion boiler and heat pump are present and
3678 thus service Heating 2c: "Sequencing of different heat generators" is of relevance for this building.
3679 The exact sequencing control can however not be visually assessed, especially because the
3680 inspection was carried out during a warm day during which the building did not require space
3681 heating. The facility manager confirmed that priority was given to the heat pump, which results in
3682 functionality level 2 for this particular service.

3683
3684



3685

3686 *Figure 26 -EnergyVille office building: building energy management system*

3687

3688 **Case study office building: Assessment time and scoring**

3689

3690 The overall inspection time for this building amounted to 65 minutes. The assistance of the facility
3691 manager greatly helped to confine the inspection time, since he could provide direct access to all
3692 technical facilities and was well aware of how the TBS were organized. Being a recently constructed
3693 building, most of the technical documentation was also readily available in the as-built archive.

3694

3695 Most of the assessment has been performed based on visual inspection and an interview with the
3696 facility manager. This implies that for many of the services no formal proof has been gathered, e.g.
3697 it was not attempted to retrieve written documentation on the exact control logic of the sequenced
3698 space heating generators. Furthermore, for many services the inspection was restricted to a few
3699 representative rooms. A complete walkthrough of the building, including inspection of each luminary
3700 or shading device, would have added significantly to the total inspection time.

3701

3702 It is noted again that this building features a large amount of smart services; an average office
3703 building will probably require less than 44 services to be assessed. Furthermore, an increased
3704 practical experience with SRI assessment and the availability of inspection protocols can also help to
3705 limit the inspection time.

3706

3707

3708

3709
3710
3711
3712

3713

Table 31 – SRI scores for the EnergyVille I office building field study

	Energy	Flexibility	Self-generation	Comfort	Convenience	Wellbeing and Health	Maintenance & fault prediction	Information to occupants
Ordinal impact score case study building	54	18	5	34	42	13	16	20
Maximum obtainable score for the case study building	73	25	5	45	61	19	23	30
Relative score	74%	72%	100%	76%	69%	68%	70%	67%

3714

3715

3716 Overall, the building achieved an SRI score of 77% under the streamlined methodology. This means
3717 that 77% of the (weighted) potential smartness impacts for this building can be achieved by the
3718 services present. Table 29 reports the scores by impact criterion.

3719

3720 For this field case study, different domain weightings were used than for the residential case study.
3721 These adapted figures reflect that domains such as cooling and lighting are relatively more important
3722 in office buildings than residential buildings. Furthermore, the weightings for the impact criterium
3723 ‘Energy savings on site’ were set in such a way that they represent the expected energy consumption
3724 breakdown of this specific building. These values thus differ from those used earlier in section 4.4.3
3725 on in the case study 2 office, which used more generic figures (presented in Table 26). This illustrates
3726 that the methodology could allow to finetune the domain weightings tailored to the energy profile
3727 of a specific building, or to define multiple classes (e.g. by building type and climatic zones). As was
3728 previously the case, the eight impact criteria were weighted equally. This implicitly gives all impact
3729 criteria equal importance in the overall SRI score, but from a methodological perspective it is also
3730 possible to alter these weightings to give more prominence to some of the eight impact criteria.

3731

3732

3733

Table 32 - Domain-level impact weightings used in the EnergyVille I field case study

Domain	Energy savings on site	Flexibility for the grid and storage	Self generation	Comfort	Convenience	Health and Wellbeing	maintenance & fault prediction	information to occupants
Heating	30%	2.5%	0%	40%	10%	10%	10%	7%
Domestic hot water	4%	2.5%	0%	10%	10%	10%	10%	7%
Cooling	30%	2.5%	0%	15%	10%	10%	10%	7%
Controlled ventilation	7%	2.5%	0%	10%	10%	10%	10%	7%
Lighting	15%	2.5%	0%	10%	10%	10%	10%	7%
Dynamic building envelope	6%	0.0%	0%	5%	10%	10%	10%	7%
Energy generation	0%	2.5%	80%	0%	10%	10%	10%	7%
Demand side management	0%	40%	10%	5%	10%	10%	10%	7%
Electric vehicle charging	0%	40%	10%	0%	10%	10%	10%	7%
Monitoring and control	8%	5%	0%	5%	10%	10%	10%	40%
Total	100%	100%	100%	100%	100%	100%	100%	100%

3734

3735

3736

3737

3738

3739

3740

3741

3742

3743

3744

3745

3746

3747

3748

3749

3750

3751

3752

3753

3754

3755

3756

3757

3758

3759

3760

3761

3762

3763

The building features a wide array of smart technologies and was thus initially expected to achieve a very high SRI score. The obtained score of 77% shows that there is nevertheless still some room for improvement for this building and also underpins that the methodology and service catalogue are forward-looking. To the facility manager, this assessment provided insights in future upgrade potential. Overall, the impact criterion 'information to occupants' had the lowest score for this case study building. The building is equipped with many sensors and currently provides a lot of information to the facility manager. To achieve a higher score on this criterion, information on energy use, energy generation and IAQ should also be presented to the other building occupants besides the facility manager. Based on the outcome of the assessment, the facility manager is investigating to implement this feature as a 'quick win' to improve the SRI score.

In general, it is expected that no building will realistically achieve the 100% smartness score, especially since the service catalogue will further evolve over time as new services become available. With a score of 77%, this case study building is probably one of the top performers concerning smart readiness. Many of the buildings in the existing building stock will likely have a much lower score with an order of magnitude of 0 to 20%. The SRI score should be communicated in such a way that it encourages the uptake of smart features in a building, but equally doesn't discourage well performing buildings to proudly display the SRI score. Instead of a score presented as a percentage, other representations such as star ratings or alphanumeric labels (A,B,C...) could also be suitable to present the SRI score of a building. In that case, the thresholds can be set in such a way that the highest scores are practically obtainable without implementing the highest possible functionality levels for all of the smart services in a building.

3764 4.11. PROVISIONAL CONCLUSIONS OF TASK 2

3765 The SRI methodology set out in Task 2 aims to address the key factors and principles to be considered
3766 as were articulated in Section 4.1. In addition, it aims to be as practical to implement as possible
3767 without jettisoning the features that give it value to end-users and that support the policy
3768 imperatives which underpin it. The resulting approach, as set out in the streamlined methodology
3769 and demonstrated via two in-field case studies, follows a simple checklist process that is
3770 straightforward and ready to implement currently.

3771

3772 The SRI methodology developed (especially the streamlined version) responds to all the imperatives
3773 with regard to:

3774

- 3775 • The audience for the SRI
- 3776 • The SRI value proposition
- 3777 • Policy objectives
- 3778 • The information to be conveyed
- 3779 • Communication of the information
- 3780 • The integrity of the SRI
- 3781 • The credibility of the SRI
- 3782 • The interpretation of smart ready versus smart now
- 3783 • Future proofing – allowing and encouraging innovation
- 3784 • Fairness and a level playing field for market actors
- 3785 • The potential usage of qualifying preconditions
- 3786 • Interaction with other policy instruments
- 3787 • Treatment of fixed (static) versus transportable (mobile) smartness features
- 3788 • The SRI assessment process and aides to assessment

3789

3790 The method is modular and can easily be tailored to specific needs and contexts. It is also as flexible
3791 as possible with regard to permitting innovative services to be included within it. For example, should
3792 a service provider develop an innovative offering that raises the maximum functionality level
3793 attainable within any give service then the innovative service offering could immediately be scored
3794 at a higher functionality level even without a formal renormalisation of the maximum denominator
3795 for that service. The benefit would still carry into the overall SRI score. Periodically the whole scheme
3796 could be recalibrated and the maximum denominators adjusted. Similarly, if an entirely new type of
3797 SR service is developed that could be recognised and incorporated within each periodic revision of
3798 the scheme.

3799

3800 The SRI methodology is flexible enough to allow the information to be reported in whatever type
3801 and level of aggregation is deemed to be most beneficial. The optimum choice can be informed by
3802 consumer and stakeholder research but may also be dependent on local context and hence need to
3803 be settled at a national or smaller level.

3804

3805 The streamlined SRI methodology is estimated to be assessable in timespans that are not dissimilar
3806 to those required e.g. for EPCs. The experience from the two field case studies suggest that this a
3807 reasonable assumption.

3808

3809 It has also been established that several of the Task 1 services are not sufficiently mature to be
3810 implemented or require too much time and efforts to allow for a practical assessment on-site. This
3811 is especially the case for some of the DSM and EV services. As a result, a set of actionable solutions
3812 have been proposed to address this in the streamlined methodology. Even in the case of the

3813 streamlined services some of the solutions proposed require further development to be
3814 unambiguous in their implementation.

3815
3816 The methodology chosen allows the impacts to be assessed and scored. At this stage of the indicator
3817 development process the policymaking community's views with regard to the most important
3818 impacts have been partially clarified via the agreed amendment to the EPBD; however, more
3819 guidance on policymaker's imperatives and priorities will be needed to fully crystallise the scoring.
3820 Nonetheless, the structure used in the methodology is completely adaptable to allow the
3821 policymaking process to establish a collective position on the final choice of impacts to be addressed
3822 and their relative importance. In recognition of locally specific contexts it is flexible enough to allow
3823 this process to be followed at the local level too and thereby allow local preferences regarding
3824 impacts, domains, services and reporting to be implemented within the same common framework.

3825
3826 Furthermore, and importantly, the proposed methodological framework is structured such that the
3827 current input driven ordinal ranking via manual on site assessment approach can evolve as and when
3828 cardinal information (from calculation or measurement) and appropriate methodologies become
3829 available to incorporate an evolution towards a more accurate, output based, dynamic evaluation
3830 that could potentially be done automatically or remotely.

3831
3832 These conclusions reflect the following observations:

- 3833 • Maturity is a precondition of being implementable, thus services whose functionality is not
3834 yet adequately defined or determinable to be included in the scheme will necessarily be
3835 excluded until these issues are addressed;
- 3836 • To be successful (i.e. if it is to be adopted in practice) it is necessary to structure the SRI so
3837 its value proposition to its target audience is of greater value than its cost of implementation;
- 3838 • To be relevant the SRI methodology has to be able to manage local and site-specific factors
3839 and thus needs to be sufficiently flexible to manage variations in such circumstances;
- 3840 • A common methodological template such as that described in this report allows
3841 maximisation of harmonisation while also being adaptable to implementation that fully
3842 respects this local context.

3843

CHAPTER 5 TASK 3: STAKEHOLDER CONSULTATION

3844 Interactions with stakeholders are an essential part of the process towards a SRI. At multiple
3845 occasions, stakeholders have had the opportunity to provide input to this study, thereby creating a
3846 transparent and open process. These interactions have supported the substantiation of the content
3847 in the technical tasks of this study, but were also beneficial to generate a broader awareness of the
3848 potential of an SRI as well as identify opportunities and challenges for the further steps towards
3849 implementation.

3850

3851 Several actions have been undertaken to strengthen the interaction with stakeholders, including the
3852 launch of a public website and three stakeholder meetings in Brussels with subsequent opportunities
3853 for written feedback.

3854

3855 Public website

3856 The project website <https://smartreadinessindicator.eu> aims at informing the general public on the
3857 goals of this study. Furthermore, visitors could register through the website to be added to the list
3858 of stakeholders. During the study, technical working documents and interim reports were available
3859 on the website for public consultation, together with a feedback form.

3860

3861 First stakeholder meeting and subsequent feedback

3862 A first stakeholder meeting took place on June 7th, 2017 in Brussels, dedicated to introducing the
3863 objectives and scope of the study, the work plan and the first findings. Several invited external
3864 speakers presented relevant other initiatives related to the themes of the SRI. More than 65
3865 representatives were present, from a broad variety of stakeholder organisations representing
3866 Member States, EPBD Concerted Action members, industry associations, research institutes, NGOs
3867 and individual companies. The meeting minutes are available on the project website
3868 <https://smartreadinessindicator.eu/>.

3869

3870 The feedback given by the initial and extended deadlines for commenting was consolidated by the
3871 team and stored in an Excel spreadsheet along the following categories:

3872

- 3873 • General remarks were consolidated and taken into account writing this report, focusing on
3874 wording, stakeholders, limitations as well as focal areas for the project.
- 3875 • The feedback from the questionnaire in relation to the Task 1 was taken into account, mostly
3876 dealing with the service catalogue and its content, structure and possible ways to assess the
3877 services.
- 3878 • New services (around 10) which were suggested were reviewed and added to the Service
3879 Catalogue and Excel spreadsheet.

3880

3881 On 12 September 2017, a progress report was shared with registered stakeholders comprising the
3882 next iteration of the report and the service catalogue, taking into account the feedback as well as
3883 further insights. Stakeholders were invited to provide feedback on the new version by mid-October.
3884 The consortium received more than 150 comments on the report, together with 70 comments on
3885 the service catalogue list. These were sent in by 21 industry associations, 2 Member States and 2
3886 NGOs.

3887

3888

3888 Second stakeholder meeting and subsequent feedback

3889 A second stakeholder meeting took place on 21st of December 2017, with an attendance of 88
3890 persons. During this meeting, the progress of the study as presented in the interim report was shared
3891 with the stakeholders. An overview was given of the comments received so far and how these have
3892 been taken into account in the drafting of the interim report.

3893

3894 From mid January to mid February 2018, stakeholders were invited to provide written feedback to
3895 the interim report of the SRI study and the service catalogue (shared with them on 16 January). The
3896 consortium received more than 260 comments on the interim report and more than 100 comments
3897 on the service list.

3898

3899 The comments provided consist of a mix of statements, questions and suggestions. The study team
3900 has assessed the relevance and applicability of all comments received, which led to significant
3901 adaptations of the service catalogue and proposed methodology. Furthermore, the report was
3902 expanded with additional sections, e.g. with regard to linkages to other assessment schemes for the
3903 building sector.

3904

3905 **Third stakeholder meeting**

3906 In consultation with DG Energy, it was decided to organise a third stakeholder meeting within the
3907 scope of this technical study. This meeting took place on May 28th 2018 in Brussels. At this meeting,
3908 71 stakeholders were present. Prior to this meeting a summarising report was sent out to inform
3909 stakeholders on the status of the project. During the meeting, the progress of the technical study
3910 and legal framework was discussed and feedback from stakeholders was collected. This was
3911 accompanied by the presentation of two practical case study examples. This second progress report
3912 is distributed for formal feedback after the stakeholder meeting.

3913

3914 **Other interactions with stakeholders**

3915 The study team and representatives of the EC's services have engaged in further bilateral discussions
3916 with specific groups of stakeholders. This includes email conversations, teleconferences, bilateral
3917 meetings and presentations at conferences or study days.

3918 On 25 October 2017 during the EPBD Concerted Action meeting in Bucharest, a double session took
3919 place with discussions about the features of smart buildings and other topics from this SRI study.

3920

3921

3922

3923

CHAPTER 6 TASK 4: IMPACT ASSESSMENT

3924 *Remark: The impact assessment is the last task within the overall project and currently under*
3925 *further development. Therefore, the content of this chapter is work in progress, more*
3926 *text work will be added toward the final version. Based on the feedback from the 3rd*
3927 *stakeholder meeting and subsequent written stakeholder consultation the task 4 work*
3928 *will be finalized.*

3929 6.1. SUMMARY

3930 The overall **goal** of the impact assessment is to analyse benefits and costs of implementing a Smart
3931 Readiness Indicator (SRI) in buildings, in relation to the uptake of smart ready technologies in the
3932 EU. It also aims to identify possible supporting policies to enhance the impact of the SRI and to
3933 understand their impact.

3934
3935 The **methodology** for the evaluation of impacts is split into two steps, see Figure 27. The *first part*
3936 *is the modelling of the baseline scenarios for the evolution of the EU building stock, taking into*
3937 *account the policy framework given by the revised EPBD – these baseline scenarios are called*
3938 *‘building sector pathways’ in what follows. They describe the general development of the building*
3939 *sector taking into account new buildings, demolition of buildings and retrofits that include energy*
3940 *efficiency measures that have an impact on building envelope and HVAC systems. These pathways*
3941 *are modelled with the Built-Environment-Analysis Model (BEAM)⁴⁷, a bottom-up building sector*
3942 *model used by Ecofys. The impact assessment relies on two building sector pathways: (i) The*
3943 *“Agreed Amendments” pathway, which corresponds to a scenario where the revision of the EPBD is*
3944 *implemented without additional measures and (ii) the “Agreed Amendments + Ambitious*
3945 *Implementation” pathway, which corresponds to a scenario where the revision of the EPBD is*
3946 *implemented in a more ambitious way.*

3947 In the *second part* the additional impacts (as compared to the baseline given by the building sector
3948 pathways) of an increased uptake of SRTs are modelled. Again, several scenarios for the uptake of
3949 SRTs are differentiated: (i) the *“SRT_BAU scenario”* corresponds to the case where the SRI is not
3950 introduced - only existing incentives for SRTs apply; (ii) the *“SRT_Moderate implementation scenario”*
3951 corresponds to the case where the SRI is introduced as a voluntary scheme, with limited supporting
3952 measures and limited implementation in MS; (iii) the *“SRT_High implementation scenario”*
3953 corresponds to the case where the SRI is introduced as a voluntary scheme, with strong supporting
3954 measures and ambitious implementation in MS.

3955
3956 This work is ongoing at the time this report is delivered and only partial conclusions are available.
3957 However, preliminary **results** can be highlighted:


- 3958 • In the *“Agreed Amendments”* building sector pathway, the final energy demand for heating
3959 without any effects of SRTs or the SRI in the EU building sector is reduced by approx. 50%
3960 from today until 2050, despite a slight increase in total building floor area. The main drivers
3961 are energy efficiency measures applied to the building envelope and the replacement of
3962 inefficient heating systems. The primary energy demand is reduced even more, since district
3963 heating and electricity are further decarbonized in the future. With regard to CO₂ emissions,

⁴⁷ See Annex A for a description of the BEAM-Model

3964
3965
3966
3967
3968
3969
3970
3971
3972
3973
3974
3975

a reduction of approx. 60% from today’s levels is attained by 2050 under this building sector pathway.

- The total effects of the uptake of SRTs on thermal energy savings in 2050 under the “SRT_BAU scenario” are about 153 TWh, which is approx. 10% of the final energy demand under the “Agreed Amendments” building sector pathway for heating in 2050.
- Based on the same effects, the cumulative electricity savings could be around 5 TWh up to 2050 and DSM in buildings (commercial and residential) could represent an overall load-shifting potential of about 150 GW by 2030 and even more by 2050. Heat pumps in buildings alone could account for 60 GW by 2050. If the 60 GW load shifting capacity would be used for an average of 1h per day, this would produce approx. 22 TWh of energy shifted in 2050.



3976
3977
3978
3979

Figure 27 Overview of scenario calculations

3980 6.2. SCOPE AND GOAL OF THE IMPACT ASSESSMENT

3981 The objective of the impact assessment is to analyse the benefits and costs of implementing a
3982 Smart Readiness Indicator (SRI) in buildings. It also aims to understand the impact of accompanying
3983 policies to enhance the impact of the SRI.

3984 The cost benefit analysis is carried out for snapshots at 2020, 2030, 2040 and 2050 and considers a
3985 range of benefits and effects, while concentrating on assessing the benefits in monetary, energy
3986 (final and primary) and emissions units on a cumulative and yearly basis, discriminating the impacts
3987 according to the segmentation of buildings. This cost-benefits analysis is based on the modelling of
3988 the effects of the uptake of smart ready technologies in the building stock and the impact the SRI
3989 can have on the latter. The impacts of the deployment of electromobility infrastructure in buildings
3990 equipped building stock is also part of the scope. These impacts cover the effects of electromobility
3991 on demand response together with a possible active participation of the user in the grid/energy
3992 markets.

3993

3994 The methodology for quantifying benefits and costs of smart ready technologies includes the
3995 following two steps.

3996 The first one is the calculation of **building sector pathways** within the framework of the revised
3997 EPBD . These pathways describe the general development of the building sector taking into account
3998 new buildings, demolition of buildings and retrofits regarding energy efficiency measures to the
3999 building shell and the HVAC systems. These pathways are modelled with the Built-Environment-
4000 Analysis Model⁴⁸ BEAM, a bottom-up building sector model by Ecofys. The modelling of long-term
4001 energy demand and CO₂-emissions with BEAM within the EU building sector is the basis for the
4002 determination of the effects of smart ready technologies in the second part.

4003 Based on the definition of reference buildings, the calculation of energy demands and the
4004 aggregation to the EU building stock, the following building sector pathways for the EU28 building
4005 sector are calculated in five geographic zones across the EU:

4006

- 4007 - “Agreed Amendments” pathway (AA): Baseline development considering the agreed
4008 amendments of the revised EPBD
- 4009 - “Agreed Amendments + Ambitious Implementation” pathway (AA+AI): Baseline
4010 development considering the agreed amendments of the revised EPBD, but with an
4011 ambitious implementation (i.e. additional supporting measures) on MS level

4012

4013 The parameters and assumptions for the building sector pathways are set based on the report and
4014 modelling work by Ecofys for the EC study *“Ex-ante evaluation and assessment of policy options for
4015 the EPBD”*⁴⁹ of April 2016. These are adjusted in accordance with agreed amendments under the
4016 revised EPBD (see ANNEX I – Building sector Scenarios – Assumptions and detailed results).

4017 The outputs of the building sector pathway calculation with the BEAM model are the floor area
4018 development per building type, final and primary energy demand, related CO₂-emissions and
4019 energy costs. The outputs are calculated for five geographical regions (EU-West, EU-North, EU-
4020 North-East, EU-South, EU-South-East).

4021

4022 The second step is the calculation of the effects of an **uptake of SRTs** on top of the building sector
4023 pathways described above. The analysis is based on three different packages, dependent on whether
4024 a building has heating systems, cooling systems or both in place. The following set of SRT scenarios
4025 are considered:

4026

⁴⁸ See Annex A for a description of the BEAM-Model

⁴⁹ Ecofys 2016: Ex-ante evaluation and assessment of policy options for the EPBD, Final report for EC DG-ENER

- 4027 - SRT BAU scenario: No SRI, only existing incentives for SRT;
4028 - SRT Moderate implementation scenario: SRI voluntary, moderate accompanying measures
4029 and moderate implementation in MS;
4030 - SRT High implementation scenario: SRI still voluntary, strong accompanying measures and
4031 considerable implementation in MS.
4032

4033 **6.3. FIRST RESULTS**

4034 This chapter gives an overview of the first results available, starting with the modelling of the
4035 building sector pathways and then outlining the first results on SRT scenarios.

4036 **6.3.1. UNDERLYING BUILDING SECTOR PATHWAYS**

4037 As described in the overall approach, the first part of the process for quantifying the benefits and
4038 costs of smart ready technologies and the Smart Readiness Indicator is the calculation of building
4039 sector pathways. They describe the general development of the building sector taking into account
4040 new buildings, demolition of buildings and retrofits regarding energy efficiency measures to the
4041 building shell and the HVAC systems. The following section gives an overview of the methodology,
4042 parameter sets and pathways considered.

4043


4044 Agreed Amendments pathway

4045 *Note: only the heating-related results are shown in this section. However, the domains of hot water,*
4046 *cooling, lighting and auxiliary energy are also covered by the model and their results are reported in*
4047 *the Annex I.*

4048

4049 Figure 28 shows the evolution of final energy demand for heating in the EU until 2050. The overall
4050 demand in 2020 of 3050 TWh/a is reduced by approx. 50% to 1450 TWh/a by 2050. The main drivers
4051 behind this development are energy efficiency measures applied to the building envelopes and the
4052 replacement of old heating systems across EU. At the same time the floor area is steadily increasing
4053 due to the construction of new buildings and extensions to existing buildings not being fully offset
4054 by the level of demolitions. The total floor area therefore increases by approx. 15% from 2020 until
4055 2050.

4056



4057

4058

Figure 28 EU total final heating energy consumption per type of heating system⁵⁰

4059

4060

4061

4062

4063

4064

4065

4066

4067

4068

In terms of primary energy, the reduction is even higher since fuel switching in the case of heating system replacement not only leads to efficiency improvements, but also to further decrease the consumption of primary energy. Where heat pumps are introduced, the higher efficiency of heat pumps leads to overall lower primary energy demands. In addition, the PEF for electricity and district heating improve over time.

Similar causes lead to a decrease of approx. 60% in CO₂-emissions for heating, as CO₂-factors are improving over time and a switch to less carbon-intensive energy carriers further supports the decarbonisation effect, see Figure 29.

⁵⁰ Abbreviations in the figures: VS: Ventilation system, HR: Heat recovery, c: condensing system, nc, non-condensing system, HP: Heat pump, DH: District heat, EL: Electricity.




Figure 29 Total EU CO₂ emissions from heating per reference building⁵¹

4069

4070

4071

4072 Finally, the energy costs for heating increase until 2030 (see Annex I). The main driver behind this
 4073 effect is increasing energy prices until 2030, while an assumed constant level of energy prices from
 4074 2030 onwards in combination with decreasing final energy demands leads to decreasing energy costs
 4075 from 2030 to 2050.

4076

4077

4078 Agreed Amendments + Ambitious Implementation pathway

4079 *The scenario "Agreed Amendments + Ambitious Implementation" will be addressed in the final report.*

4080

6.3.2. SRT SCENARIOS

4081 In the second step the effects for SRT uptake are modelled. This section summarizes the main results
 4082 for the "SRT_BAU" scenario and gives preliminary results for the "SRT_High implementation"
 4083 scenario.

4084

4085

SRT_BAU scenario

4087 The "SRT_BAU" scenario takes only existing incentives for the uptake of SRTs into account and
 4088 assumes that the SRI is not implemented, while the other two scenarios (SRT_Moderate
 4089 implementation and SRT_High implementation) assume a voluntary SRI is implemented with
 4090 medium or strong accompanying measures respectively at the MS level.

4091 The detailed inputs used in the scenarios per reference building and zone will be detailed in the final
 4092 report of the study.

4093

4094 *Table 33* gives an overview of the effects due to the introduction and uptake of SRTs for all building
 4095 types and all geographical regions for the "SRT_BAU" scenario.

⁵¹ Abbreviations in the figures: Office Building (OFB), Trade and Retail Building (TRB), Education Building (EDB), Touristic Buildings (TOB), Health Buildings (HEB), Other non-residential buildings (ONB).

4096 The numbers are cumulative, which means that the 2050 numbers represent all effects of the SRTs
 4097 and the SRI from 2020 to 2050 compared to today. All future effects are taken into account.

4098
 4099

Table 33: SRT effects for all building types in the “SRT-BAU” scenario⁵²

SCENARIO "SRT_BAU" (autonomous effects - without SRI)					
Summary	cumulated numbers	2020	2030	2040	2050
final energy savings p.a. [TWh/a]					
thermal		5.7	64.4	114.4	153.2
electrical		0.3	2.8	3.8	4.8
primary energy savings p.a. [TWh/a]		7.4	82.2	137.8	177.1
CO2 savings p.a. [Mt/a]		1.1	12.0	20.4	26.5
investment costs [Million €]		2,393	27,811	57,312	89,399

4100
 4101

4102 The total thermal energy savings in 2050 are about 153 TWh, which is approx. 10% of the final energy
 4103 demand by 2050 (see Figure 28). By this comparison the average additional saving per year would
 4104 be approx. 5 TWh/a.

4105

4106 The uptake of SRTs also impacts the Demand-Side-Management (DSM) potential. This potential has
 4107 been determined based on the results of recent studies.⁵³ The main opportunities for DSM impacts
 4108 are EV charging, heat pumps and direct electrical heating (also for hot water) as well as cooling and
 4109 ventilation in buildings, since they are responsible for the majority of electricity demand within
 4110 buildings.

4111 The starting point for assessing the DSM potential is an overview of the relevant electricity demand.
 4112 Table 34 summarizes the total electricity demand of the relevant domains from the building sector
 4113 pathways for the target years 2020, 2030, 2040 and 2050. As gas-condensing boilers are the main
 4114 heating systems for replacement in the “Agreed Amendments” building sector pathway, the
 4115 electricity demand for heating is significantly decreasing, while the electricity for hot water is stable
 4116 (due to increasing efficiencies of heating systems on the one hand side and at the same time
 4117 increasing floor areas in the building stock), and cooling and auxiliary electricity is increasing over
 4118 time. Due to more efficient lighting technologies, the electricity demand for lighting is slightly
 4119 decreasing over time.

4120

Table 34: Total Electricity demand (“Agreed Amendments” building sector pathway)

TWh/a	2020	2030	2040	2050
heating	233	191	140	88
hot water	47	47	46	44
cooling	38	43	45	47
Aux. El	76	92	96	101
Lighting n-res	258	201	211	221
sum	651	574	539	501

4121
 4122

4123 In the next step, this theoretical potential is then adjusted (downwards) by considering the findings
 4124 of studies that have analysed the available DSM potential.

4125 An Ecofys study on the “Role of energy efficient buildings in the EUs future power system”
 4126 determines the increased flexibility potential from using heat pumps in a high efficiency 2050 EU
 4127 building sector to be about 60 GW⁵⁴.

⁵² The cumulated effects of all additional SRTs from 2020 to 2050 are shown in this table.

⁵³ As a total for all buildings types.

⁵⁴ Ecofys study “The role of energy efficient buildings in the EUs future power system” for Eurima, 2015.

4128 Another study for DG ENER by COWI, Ecofys, VITO and Thema gives figures on demand side
 4129 management potential in all sectors across the EU (Industry, commercial and residential buildings).
 4130 By 2020 it estimates the total theoretical demand response potential across the EU is 120 GW. If this
 4131 potential could be fully used for 1h per day it would mean approx. 43 TWh/a of balancing potential,
 4132 which equates to 6.5% of all electricity demand in buildings by 2020. For 2030 the same study
 4133 estimates the theoretical potential to be 160GW, which is a factor 1.3 higher than for 2020. The
 4134 current baseline of DSM potential used is about 23 GW in 2020, which is about 19% of the theoretical
 4135 potential.

4136 The final DSM potential needs to be further elaborated towards the final report. The preliminary
 4137 numbers from above give a first orientation only.

4138
 4139 In addition to energy savings and DSM, the impact of the EV charging infrastructure within or
 4140 associated to buildings is an important part of the smart readiness of buildings. This impact will be
 4141 detailed in the final report of this study.

4142

4143

4144 **SRT Moderate implementation scenario**

4145 *The scenario "SRT_Moderate Implementation" will be addressed in the final report.*

4146 *The main difference between the "SRT_Moderate Implementation" scenario and the "SRT_BAU"*
 4147 *scenario is that the former takes the voluntary implementation of the SRI into account (which is not*
 4148 *the case for the "SRT_BAU" scenario) together with medium ambition accompanying measures at*
 4149 *the MS level.*

4150

4151

4152 **SRT High implementation scenario**

4153 *The scenario "SRT_High Implementation" will be addressed in the final report, but a first run of the*
 4154 *model indicates an order of magnitude: the scenario produces a total cumulative thermal energy*
 4155 *saving potential of approx. 428 TWh to 2050. In comparison to the final energy for heating in 2050*
 4156 *to total cumulated savings are about 30% of it. The cumulative electrical energy saving to 2050 is*
 4157 *about 13 TWh.*

4158 **6.3.3. SENSITIVITY ANALYSIS**

4159 *The sensitivity analysis will be addressed in the final report.*

4160

4161 *It is planned to investigate the following sensitivities:*

- 4162 - *Introduction of a mandatory SRI for buildings above a m2-threshold (i.e. only applied for*
 4163 *buildings which surface area is above 1.000 m²)*
- 4164 - *Introduction of a mandatory SRI for commercial buildings / units only*
- 4165 - *Introduction of a mandatory SRI for buildings which are subjected to mandatory inspections*
 4166 *under Art. 14-15 EPBD*
- 4167 - *Other sensitivities (such as higher/lower cost and/or benefits of SRTs) could also be*
 4168 *modelled*

4169

4170 **6.3.4. LIFE-CYCLE ASPECTS**

4171 Given the scope of the project and the stage of development of the SRI, this study concentrates on
4172 assessing the benefits in monetary, energy (final and primary) and emissions units on a cumulative
4173 and yearly basis; discriminating the impacts according to the segmentation of buildings. LCA aspects
4174 are not an integral part of this impact assessment modelling and detailed life cycle assessment
4175 calculations have not been conducted. A qualitative assessment of LCA aspects will be provided in
4176 the final report, drawing on available references.

4177 **6.3.5. POLICY MEASURES**

4178 Public policies, incentives and information campaigns can influence and promote the adoption of
4179 energy management and SRTs. The effect of policies could be both on the overall demand for SRTs
4180 and on the magnitude of energy savings per SRT adopted. The European legislation in place can
4181 already support the deployment of SRT. The effect of the current EU legislation is considered under
4182 the “business as usual (SRT-BAU)” scenario. Additionally, further measures and policies can play a
4183 leveraging role for increasing the uptake of SRTs. This second set of measures are considered under
4184 the “moderate” and “increased uptake” scenarios. The following sections give an overview of the
4185 existing policies that may influence the implementation of SRT today and also considers the potential
4186 future accompanying measures and policies that could increase demand for SRTs and the magnitude
4187 of energy savings per SRT adopted.
4188 For more information on the current and potential future policy measures refer to the Annex K.

4189 **6.4. METHODOLOGY AND APPROACH**

4190 **6.4.1. BUILDING SECTOR SCENARIOS METHODOLOGY**

4191 The building sector pathways are modelled with the Built-Environment-Analysis Model⁵⁵ BEAM, a
4192 bottom-up building sector model proprietary to Ecofys.

4193
4194 The first step for the building sector modelling process is the **definition of reference buildings**. A
4195 reference building is a building that represents a typical building (type, geometry, thermal quality,
4196 HVAC- and BAC-system) of the building stock. This enables the analysis of an entire building stock by
4197 analysing the stock from the bottom-up, based on a different set of reference buildings. Typical
4198 residential reference buildings are, e.g. detached or semi-detached single and multi-family houses
4199 of different sizes and/or age classes (construction phases). Typical non-residential building types are,
4200 e.g. office buildings, schools, hotels, hospitals, and retail facilities.

4201 In this study we define a single family (SFH), a small multi-family (SMFH) and a large multi-family
4202 (LMFH) as reference buildings for the residential building stock and an office building and retail⁵⁶
4203 building for non-residential buildings⁵⁷.

4204

4205 After having defined the adequate set of reference buildings, the next step is to **determine the**
4206 **energy demands** - and thereby the saving potentials of the reference buildings. Note that the
4207 building sector pathways do not take into account the additional savings from SRTs, which will be
4208 done in the SRT scenarios.

⁵⁵ See Annex A for a description of the BEAM-Model

⁵⁶ Office and retail buildings are considered as typical non-res buildings with the largest SRT saving potentials.

⁵⁷ According to the proposal.

4209

4210 The results of the determination of the energy demands and potentials of the reference building
 4211 variants are **aggregated to represent the EU building stock** and its future development (Activity 3).
 4212 For this step the EU28 building sector is split into five geographical zones (in compliance with the
 4213 approach followed for the EPBD impact assessment). The following two building sector pathways
 4214 are calculated: “Agreed Amendments” pathway: Baseline development considering the agreed
 4215 amendments of the revised EPBD and “Agreed Amendments + Ambitious Implementation”
 4216 pathway: Baseline development considering the agreed amendments of the revised EPBD, but with
 4217 a more ambitious implementation on MS level.
 4218

4219

4220 **The outputs** of the building sector pathway calculation with the BEAM model are the floor area
 4221 development per building type, final and primary energy demand, and related CO₂-emissions, and
 4222 energy costs, see the example for Single Family Houses (SFH) in Figure 30. For the target years 2020,
 4223 2030, 2040 and 2050 the outputs regarding floor area development – split up by retrofit level – final
 4224 energy demand by system as well as primary energy demand and CO₂-emissions are shown. The
 4225 overall floor area is increasing, while the energy demand is decreasing mainly due to the introduction
 4226 of energy efficiency measures on the building shells and the replacement of inefficient HVAC
 4227 systems.

4228 The outputs are calculated for five geographical regions (EU-West, EU-North, EU-North-East, EU-
 4229 South, EU-South-East).

4229

EU-West		2020	2030	2040	2050
Floor area [m ²]					
	not renovated	7.40E+09	5.29E+09	2.81E+09	2.05E+08
	already renovated	6.54E+09	6.54E+09	6.54E+09	6.54E+09
	retrofit (<=2025)	4.38E+08	1.31E+09	1.31E+09	1.31E+09
	retrofit (>2025)	0.00E+00	1.04E+09	3.32E+09	5.71E+09
	new (<=2025)	4.16E+08	9.18E+08	9.18E+08	9.18E+08
	new (>2025)	0.00E+00	4.78E+08	1.44E+09	2.44E+09
Final energy consumption [TWh/a]					
	<u>total</u>	<u>1437</u>	<u>1233</u>	<u>986</u>	<u>726</u>
thermal	heating	1206	991	728	454
thermal	hot water	212	220	233	244
electrical	cooling	0.3	0.3	0.4	0.4
electrical	lighting	0	0	0	0
electrical	auxiliary energy (el)	18	22	25	28
Primary energy consumption [TWh/a]					
	<u>total</u>	<u>1638</u>	<u>1333</u>	<u>1011</u>	<u>699</u>
	heating	1360	1063	745	439
	hot water	239	236	238	236
	cooling	1	1	0	0
	lighting	0	0	0	0
	auxiliary energy (el)	39	34	28	23
CO ₂ -Emissions [Mt/a]					
	<u>total</u>	<u>275</u>	<u>226</u>	<u>174</u>	<u>123</u>
	heating	231	182	130	79
	hot water	41	40	41	42
	cooling	0	0	0	0
	lighting	0	0	0	0
	auxiliary energy (el)	4	3	2	2
	average PE factor [-]	1.14	1.08	1.03	0.96
	average CO ₂ -factor [kg/kWh]	0.191	0.183	0.176	0.169

4230

4231 *Figure 30: Exemplary output of the building pathway calculation for single family houses (SFH) in the*
 4232 *geographical region EU-West*

4232

4233

4234 **6.4.2. SRT SCENARIOS METHODOLOGY**

4235 The smart ready technology (SRT) scenarios quantify the effects of the uptake of SRTs on top of the
 4236 building sector pathways from above. These effects are calculated with an Excel based model for the
 4237 following three scenarios: SRT BAU scenario: No SRI, only existing incentives for SRT; SRT Moderate
 4238 implementation scenario: SRI voluntary, moderate accompanying measures and moderate
 4239 implementation in MS; SRT High implementation scenario: SRI still voluntary, strong accompanying
 4240 measures and considerable implementation in MS.

4241 **Effects of Smart Ready Technologies uptake**

4242 The smart ready technologies scenarios are calculated based on the building sector pathways from
 4243 the step above. For each of the reference buildings the following three SRT packages are defined –
 4244 based on whether a heating system and/or cooling system is present:

- 4245 - Package 1: Buildings with heating only
- 4246 - Package 2: Buildings with heating and cooling
- 4247 - Package 3: Buildings with cooling only

4248
 4249 With these packages all buildings within the reference building types and geographical regions are
 4250 addressed. The building stock for each geographical region is assigned to these packages. The SRT
 4251 scenarios are calculated for three geographical regions. The regions EU-North-Eastern is merged into
 4252 EU-North and the region EU-South-Eastern into EU-South for the SRT scenarios⁵⁸.

4253
 4254 The deployment rates of smart ready technologies and the levels of SRT implementation can differ
 4255 from case to case, since each of the above described packages addresses all possible improvements
 4256 steps (i.e. SRI range I=>II, I=>III, I=>IV etc.) regarding SRTs and consists of detailed parameters and
 4257 assumptions on their future development. The split-up of the deployment rate in different
 4258 improvement steps can be found in the detailed tables in the following section.

4259
 4260 For the categorization of the Smart Readiness Indicator, the following **SRI ranges** are used in the
 4261 model. Each building is assigned to a range, depending on the current status in stock. If the building
 4262 undergoes improvement measures with regard to automation and control, DSM or EV-charging, then
 4263 it can move to a higher range.

- 4264 - SRI range I: SRI of 0% - 25%
- 4265 - SRI range II: SRI of 26% - 50%
- 4266 - SRI range III: SRI of 51% - 75%
- 4267 - SRI range IV: SRI of 76% to 100%

4268
 4269 For the **automation and control domains** such as heating, DHW, cooling, controlled ventilation,
 4270 lighting, dynamic building envelope, energy generation, and monitoring/control the SRI ranges I to
 4271 IV reflect the categorization A-D of the European BACS standard EN 15232. Hereby the BACS
 4272 category D relates to SRI range I and BACS category A to SRI range IV.

4273 The SRT Excel model includes the following improvement options for automation and control in case
 4274 of system upgrades:

- 4275 - buildings SRI range I -> II
- 4276 - buildings SRI range I -> III
- 4277 - buildings SRI range I -> IV

⁵⁸ As the parameter set of the EPBD Impact Assessment with its five geographical regions has been used as starting point, a calculation in five regions is more consistent.

- 4278 - buildings SRI range II -> III
- 4279 - buildings SRI range II -> IV
- 4280 - buildings SRI range III -> IV

4281

4282 If a building undergoes improvement steps as indicated above, the final energy savings – either
4283 thermal or electrical – can be realized due to the improved overall system performance. The
4284 assumptions on saving potential per improvement step will be further discussed in the final report.
4285 The final energy savings also lead to primary energy as well as CO₂-savings due to the improved
4286 energy efficiency of the buildings.

4287

4288 Besides BACS, the **Demand-Side-Management** (DSM) potential with regard to the electricity demand
4289 is determined⁵⁹. The main opportunities for DSM impacts are EV charging, heat pumps and direct
4290 electrical heating as well as cooling and ventilation in buildings, as they account for the largest share
4291 of electricity demand.

4292 In order to determine the DSM realistic potential that is incorporated in the building stock, in a first
4293 step the relevant electricity demand is considered as a theoretical maximum DSM potential. Based
4294 on additional data, the realistic balancing potential is determined in the second step.

4295

4296 Furthermore, the effects of the uptake of Electric Vehicle (**EV**) **charging infrastructure** need to be
4297 considered within the EPBD scope. However, the largest effect of the installation of EV charging
4298 infrastructure is clearly the “driver/enabler” function that is a prerequisite for the uptake of EVs in
4299 general. Without any charging infrastructure in the built environment, the attractiveness of EVs will be
4300 limited. Apart from this, EVs can provide storage and flexibility to the building in case of charging or
4301 discharging – in case the charger and the battery allow two-way charging. This flexibility and storage
4302 function of EVs is covered by the DSM domain and will be discussed more in detail in the final report.
4303 In order to show the possible impact of the EV charging infrastructure in general, possible EV-uptake
4304 scenarios (i.e. min and max) will be discussed qualitatively and also in a quantitative way (i.e. current
4305 and expected number and capacity of chargers).

4306

4307 The **approach** for quantifying the effects of smart ready technologies can be described as follows,
4308 see Table 35. For each of the above described three packages a yearly deployment rate is determined
4309 for the different automation and control domains as the main input. This rate is split into SRI-range
4310 improvement steps (i.e. I -> II or II -> IV). For each of the improvement steps the relative saving
4311 potential for thermal and electrical energy (in % of the actual energy demand) is given in the model
4312 as well as the investment costs per m² of floor area. The combination of deployment rate and
4313 improvement potential per SRI range gives the overall saving potential and investment costs (CAPEX)
4314 of the implementation of SRTs.

⁵⁹ As a total for all buildings types

4315
4316

Table 35: Exemplary input sheet for single family houses (SFH, without cooling) in the geographical region EU-West for the SRT_BAU scenario

PACKAGE 1	heating only:	97%	2020	2030	2040	2050
Buildings with heating only						
- BACS Domains (Heating, DHW, cooling, mechanical ventilation, lighting, dyn. Envelope, energy generation, monitoring and contro						
<u>implementation rate (p.a.)</u>			1.2%	1.2%	1.2%	1.2%
<u>split-up of implementation rate</u>						
buildings SRI range I -> II			0.49%	0.37%	0.29%	0.22%
buildings SRI range I -> III			-	-	-	-
buildings SRI range I -> IV			-	-	-	-
buildings SRI range II -> III			0.61%	0.66%	0.69%	0.69%
buildings SRI range II -> IV			-	-	-	-
buildings SRI range III -> IV			0.10%	0.16%	0.23%	0.29%
<u>status quo of BACS levels</u>						
SRI range I: 0%-25%			20%	15.1%	11.4%	8.5%
SRI range II: 25%-50%			70%	68.8%	65.9%	61.9%
SRI range III: 51%-75%			8%	13.1%	18.2%	22.7%
SRI range IV: 76%-100%			2%	3.0%	4.6%	6.9%
<u>savings thermal enregy (%)</u>						
buildings SRI range I -> II			10%	10%	10%	10%
buildings SRI range I -> III			22%	22%	22%	22%
buildings SRI range I -> IV			29%	29%	29%	29%
buildings SRI range II -> III			12%	12%	12%	12%
buildings SRI range II -> IV			19%	19%	19%	19%
buildings SRI range III -> IV			7%	7%	7%	7%
<u>savings electrical energy (%)</u>						
buildings SRI range I -> II			8%	8%	8%	8%
buildings SRI range I -> III			14%	14%	14%	14%
buildings SRI range I -> IV			16%	16%	16%	16%
buildings SRI range II -> III			6%	6%	6%	6%
buildings SRI range II -> IV			8%	8%	8%	8%
buildings SRI range III -> IV			2%	2%	2%	2%
<u>CAPEX (€/m2)</u>						
buildings SRI range I -> II			4.0	4.0	4.0	4.0
buildings SRI range I -> III			8.0	8.0	8.0	8.0
buildings SRI range I -> IV			14.0	14.0	14.0	14.0
buildings SRI range II -> III			5.5	5.5	5.5	5.5
buildings SRI range II -> IV			12.0	12.0	12.0	12.0
buildings SRI range III -> IV			8.0	8.0	8.0	8.0

4317
4318

4319

4320

4321

4322

4323

4324

4325

4326

4327

4328

4329

4330

4331

4332

4333

Combining the steps described above leads to the outputs shown in Table 36: Thermal and electrical energy savings, primary energy and CO₂-savings, energy cost savings and total investments per year. This output format is given for each of the above described packages per reference building type, SRT-scenario and geographical zone. The energy cost savings still need to be calculated for the final report of the study.

4334 Table 36: Exemplary output sheet for single family houses (SFH, without cooling) in the geographical region
 4335 EU-West for the SRT_BAU scenario

PACKAGE 1	heating only: 97%	2020	2030	2040	2050
Buildings with heating only					
CALCULATIONS					
<u>final energy savings p.a. [TWh/a]</u>					
thermal		1.8	1.5	1.2	0.9
% compared to yearly consumption		0.13%	0.12%	0.12%	0.12%
electrical		0.01	0.00	0.00	0.00
% compared to yearly consumption		0.07%	0.00%	0.00%	0.00%
<u>primary energy savings [TWh/a]</u>					
thermal		2.1	1.7	1.2	0.8
electrical		0.02	0.00	0.00	0.00
<u>CO2-emission savings [Mt/a]</u>					
thermal		0.4	0.3	0.2	0.1
electrical		0.00	0.00	0.00	0.00
<u>energy cost savings</u>					
		tbd			
<u>investment costs [Million €/a]</u>					
total		886	987	1082	1178

4337
4338


4339 Effects from the SRI

4340 Our working hypothesis is based on the following assumptions: the SRI will provide a common
 4341 classification system across Europe such that technology and smart services providers could position
 4342 their service offerings in terms of the SRI levels. This will create a common structure within which
 4343 smart services can compete and thus provide much needed transparency, leading to a lower risk and
 4344 a higher adoption/uptake of SRTs. This effect is not independent of the level of uptake of the SRI (a
 4345 very common usage of the SRI might lead to a clear positioning of the service providers regarding
 4346 the SRI), but a certain critical mass of SRIs will be needed until the above described process leads to
 4347 an uptake of SRTs. If the critical mass of the SRI in the building stock is attained, the uptake will most
 4348 likely not be a linear development, but could be described with an S-curve function and
 4349 adoption/implementation rates (saturation curve).

4350 The degree of MS-specific supporting policies of course will have an influence on the adoption rates.
 4351 Smart service adoption rates will also be strongly affected by the policy support measures which may
 4352 be directly targeted towards them too (i.e. policies could be designed to both create incentives to
 4353 have an SRI and also to adopt certain smart services). The impact of the SRI on driving
 4354 technology/service adoption will also be time dependent, such that the longer the SRI has been in
 4355 place the more impact it will have because market actors become familiar with it.

4356 Figure 31 gives an illustration of typical s-curves. A mandatory measure would be implemented more
 4357 like a vertical s-curve function, while a voluntary measure (such as the SRI, unless made mandatory
 4358 at MS level) would most likely follow a more horizontal pathway⁶⁰. For the voluntary implementation
 4359 an upper limit should also be considered, since the measure has no binding character.

⁶⁰ The upper limit for a voluntary SRI would be much lower than the upper limit for a mandatory SRI. Therefore the s-curve saturation rate needs to be combined with the max. upper limit.



4360

4361

Figure 31: Illustration of typical S-curves

4362 *Details on the parameter setting for the SRI effects – dependent on the supporting measures by the*
 4363 *member states (regulatory, financial, information) – still need to be discussed.*

4364 In addition, the rate of ownership transition could also be considered as an upper limit for the
 4365 deployment of the SRI. Each time a tenant or owner of a building changes, the incentive to issue an
 4366 SRI could be considered to be comparable with the incentive to issue an EPC. Therefore, the EPC
 4367 issuing rates could be considered as upper limit for the introduction of an SRI.

4368

4369 *Based on the detailed SRT-scenarios a **sensitivity analysis** will be conducted to address the*
 4370 *uncertainty of the input parameters. The sensitivity analysis is performed to (i) understand the*
 4371 *influence of different relevant parameters, which is necessary to detect the most critical ones and (ii)*
 4372 *get an impression of the uncertainties of the results of the previously determined scenarios.*

4373 *It is not yet conducted and not covered by this progress report.*

4374

4375 *It is planned to investigate the following sensitivities:*

- 4376 - *Introduction of a mandatory SRI for buildings above a m2-threshold (i.e. only applied for*
 4377 *buildings which surface area is above 1.000 m²)*
- 4378 - *Introduction of a mandatory SRI for commercial buildings / units only*
- 4379 - *Introduction of a mandatory SRI for buildings which are subjected to mandatory inspections*
 4380 *under Art. 14-15 EPBD*

4381 *Other sensitivities (such as higher/lower cost and/or benefits of SRTs) could also be modelled*

4382 **6.5. PROVISIONAL CONCLUSIONS OF THE IMPACT ASSESSMENT**

4383

4384 *Remark: The provisional conclusions cover only the results available so far. Additional impacts*
4385 *will be added in the additional remaining scenarios, especially the SRT_Medium*
4386 *Ambition and SRT_High Ambition scenario.*

4387
4388 This chapter established the main findings from the analysis of the EU building sector and highlighted
4389 the impact of SRTs in buildings and the additional effect of the SRI.

4390
4391 Regarding the underlying **EU building sector pathways** the final energy demand for heating – as the
4392 main indicator for the energy efficiency improvements on building shells and heating systems – is
4393 decreasing by approx. 50% by 2050 (without SRT/SRI effects). At the same time the primary energy
4394 demand reduction is even higher due to decreasing primary energy factors for electricity and district
4395 heat over time, while a drop of approx. 60% in CO₂-emissions by 2050 (agreed amendments pathway)
4396 is possible based on a decarbonization of electricity and district heat.

4397
4398 The effects of the uptake of SRTs for thermal energy savings for all buildings within the EU
4399 accumulated to 2050 for the “SRT_BAU” scenario in combination with the “Agreed Amendments”
4400 building sector pathway is about 153 TWh/year, which equals approx. 10% of the final energy for
4401 heating in 2050. The savings in electricity are much lower with 5 TWh/year savings in 2050. In terms
4402 of CO₂-emissions, 26.1 Mt/a can be saved in 2050 on thermal energy and electricity.

4403 For DSM measures the effect in the market is derived from other studies. The increased flexibility
4404 potential of running heat pumps in a high efficiency 2050 EU building sector is estimated to be about
4405 60 GW⁶¹, while another study⁶² estimates the total theoretical demand response potential in 2020
4406 (including buildings and industry) to be 120 GW. If this potential could be fully used for 1h per day it
4407 would mean approx. 43 TWh/a balancing potential, which equates to 6.5% of all electricity demand
4408 in buildings in 2020. For 2030 the same study estimates the theoretical potential at 160GW, which is
4409 a factor of 1.3 higher than for 2020.

4410
4411 More detailed conclusions will follow with the draft final report.

4412
4413

⁶¹ Ecofys study “The role of energy efficient buildings in the EUs future power system” for Eurima, 2015.

⁶² Table 5-1 from “IMPACT ASSESSMENT STUDY ON DOWNSTREAM FLEXIBILITY, PRICE FLEXIBILITY, DEMAND RESPONSE & SMART METERING, EC DG-ENER July 2016

4414

CHAPTER 7 CONCLUSIONS AND NEXT STEPS

4415

4416 This second progress report provides an overview of the work carried out in the project that supports
4417 EC DG Energy in setting up a Smart Readiness Indicator for buildings.

4418

4419 **Task 1** has provided definitions and a taxonomy to define smart ready services and their impacts.
4420 This led to the development of a catalogue of smart ready services for buildings. These services are
4421 focusing on optimization, interaction with occupants and interoperability and interaction with the
4422 energy grid. In the taxonomy, the services are grouped into 11 main domains. The identified domains
4423 cover Heating, Cooling, Domestic Hot Water, Mechanical Ventilation, Lighting, Dynamic Building
4424 Envelope, Local Energy Generation, Demand Side Management, Electric Vehicle Charging,
4425 Monitoring and Control, and Various.

4426 For each of the services in the catalogue, one or more functionality levels are defined and an
4427 indicative assessment of their impacts have been made. The impacts that are assessed cover energy
4428 savings on site, flexibility for the energy grid and storage, self-generation of energy, comfort,
4429 convenience, well-being and health, maintenance and fault prediction, and information provided to
4430 the occupant. The indicative impacts of each of the functionality levels of the smart ready services
4431 are assessed on a seven-level scale, based on either information from standards, stakeholders and
4432 market knowledge. The catalogue has been developed in an interactive way and was updated for this
4433 progress report to reflect comments from stakeholders and evolving insights.

4434

4435 **Task 2** has developed a harmonized methodology to calculate the smart readiness indicator. The
4436 generic methodology is found to work well on a theoretical level and to meet all the requirements
4437 for the methodology. However, using the full Task 1 catalogue of services would require too many
4438 services to be assessed to be viable in practice and many services are both challenging to assess and
4439 would have low credibility. Therefore, options to streamline the methodology by rationalising the
4440 services have been examined. This leads to the derivation of a streamlined SRI methodology that
4441 uses a consolidated set of 52 services which are actionable now and are have reasonable confidence
4442 in their ability to be assessed and their attribution of impacts to functional levels. This streamlined
4443 methodology is tested against two building cases studies – a single family home and an office.

4444 The time taken to conduct assessments using the streamlined method is found to be similar to the
4445 time it takes to conduct EPC assessments in many countries. The methodology is modular and flexible
4446 which means it can be tailored to local and building specific contexts. It can also be used in ways that
4447 accommodate innovation in service offerings and functionalities. The method is informed by many
4448 considerations including the target audience and the information to be reported and is shown to be
4449 able to reflect their priorities and needs. The flexibility of the methodology permits variation in
4450 implementation according to the local needs and circumstances; however, it still applies a
4451 harmonised framework.

4452

4453

4454 **Task 3** deals with the interaction with stakeholders. A public website and various meetings have been
4455 set up to provide information and source valuable feedback. This feedback has fed the development
4456 of the other tasks in this project.

4457

4458

4459 The overall goal of the **task 4** impact assessment is to analyse benefits and costs of implementing a
4460 Smart Readiness Indicator (SRI) in buildings to support an increased uptake of Smart Ready
4461 Technologies (SRTs) in buildings in the EU. It also aims to understand the impact of accompanying
4462 policies to enhance the impact of the SRI. The methodology in the framework of this study is split
4463 into two steps. The first part focuses on the modelling of the evolution of the EU building stock
4464 within the framework of the revised EPBD: the 'building sector pathways'. In the second part the
4465 effects of an uptake of smart Ready Technologies (SRTs) and the SRI are modelled.
4466 As preliminary conclusions the final energy demand for heating can be reduced by approx. 50% by
4467 2050 in the baseline building sector pathway and the primary energy demand can be reduced even
4468 more, since the decarbonization of district heating and electricity is further ongoing. Regarding CO₂-
4469 emissions, a reduction of approx. 60% until 2050 can be reached. Total effect of thermal energy
4470 saving by 2050 in the baseline is about 153 TWh per year, which is approx. 10% of the final energy
4471 demand for heating in 2050. DSM in buildings (commercial and residential) could show a load-
4472 shifting potential of about 150 GW by 2030 and eventually even more by 2050. Heat pumps in
4473 buildings alone could account for 60 GW by 2050. If the 60 GW load shifting capacity would be used
4474 for 1h per day in average, this would result in approx. 22 TWh of energy shifted in 2050.

4475

4476 **Next steps towards the finalization of the study**

4477 This progress report is an intermediate deliverable of the study. Stakeholders will have the
4478 opportunity to provide feedback on the report and technical annexes through a structured form. An
4479 updated and expanded report will be provided at the end of the study, scheduled for August 2018.

4480

4481

4482

4483

4484

4485

4486

CHAPTER 8 ANNEXES

- 4487 • Annex A: Smart Ready Services catalogue (Excel file)
- 4488 • Annex B: Glossary
- 4489 • Annex C: Interoperability of smart ready technologies
- 4490 • Annex D: Standardisation related to smart buildings
- 4491 • Annex E: Hype Cycles to assess maturity of services
- 4492 • Annex F: Review of applicability of services for inclusion in SRI
- 4493 • Annex G: An Actionable Subset of Smart Readiness Elements (Excel file)
- 4494 • Annex H: The built-environment-analysis-model BEAM²
- 4495 • Annex I: Building sector scenarios – assumptions and detailed results
- 4496 • Annex J: SRT Scenarios – Detailed Assumptions (TO BE COMPLETED)
- 4497 • Annex K: Current and additional accompanying policies
- 4498 • Annex L: Multi criteria decision making METHODS
- 4499 • Annex M: Calculation process details for the in-field Single Family Home case study
- 4500 • Annex N: Reference list

4501

ANNEX A - THE SMART READY SERVICES CATALOGUE

4502 For reasons of readability as well as complexity, the service catalogue is distributed as accompanying
 4503 Excel spreadsheet.

4504

4505 The table below provides an excerpt of the smart ready services catalogue with the domains, service
 4506 coding and names and indication whether the services are part of the proposed simplified SRI
 4507 methodology.
 4508

4509

Table 37 - excerpt of the smart ready services catalogue

Domain	Code	Smart ready service	part of the proposed simplified indicator
Heating	Heating-1a	Heat emission control	yes
Heating	Heating-1b	Emission control for TABS (heating mode)	yes
Heating	Heating-1c	Control of distribution fluid temperature (supply or return air flow or water flow) - Similar function can be applied to the control of direct electric heating networks	yes
Heating	Heating-1d	Control of distribution pumps in networks	yes
Heating	Heating-1e	Intermittent control of emission and/or distribution - One controller can control different rooms/zones having same occupancy patterns	yes
Heating	Heating-1f	Thermal Energy Storage (TES) for building heating (excluding TABS)	yes
Heating	Heating-1g	Building preheating control	yes
Heating	Heating-2a	Heat generator control (for combustion and district heating)	yes
Heating	Heating-2b	Heat generator control (for heat pumps)	yes
Heating	Heating-2c	Sequencing of different heat generators	yes
Heating	Heating-2d	Heat system control according to external signal (e.g. electricity tariff, gas pricing, load shedding signal etc.)	no
Heating	Heating-2e	Control of on-site waste heat recovery fed into the heating system (e.g. excess heat from data centers)	no
Heating	Heating-3	Report information regarding HEATING system performance	yes
Domestic hot water	DHW-1a	Control of DHW storage charging (with direct electric heating or integrated electric heat pump)	yes
Domestic hot water	DHW-1b	Control of DHW storage charging (using hot water generation)	yes
Domestic hot water	DHW-1c	Control of DHW storage temperature, varying seasonally: with heat generation or integrated electric heating	no
Domestic hot water	DHW-1d	Control of DHW storage charging (with solar collector and supplementary heat generation)	yes

Domestic hot water	DHW-2	Control of DHW circulation pump	no
Domestic hot water	DHW-3	Report information regarding domestic hot water performance	yes
Cooling	Cooling-1a	Cooling emission control	yes
Cooling	Cooling-1b	Emission control for TABS (cooling mode)	yes
Cooling	Cooling-1c	Control of distribution network chilled water temperature (supply or return)	yes
Cooling	Cooling-1d	Control of distribution pumps in networks	yes
Cooling	Cooling-1e	Intermittent control of emission and/or distribution	yes
Cooling	Cooling-1f	Interlock between heating and cooling control of emission and/or distribution	yes
Cooling	Cooling-1g	Control of Thermal Energy Storage (TES) operation	yes
Cooling	Cooling-2a	Generator control for cooling	yes
Cooling	Cooling-2b	Sequencing of different cooling generators	yes
Cooling	Cooling-3	Report information regarding cooling system performance	Yes
Controlled ventilation	Ventilation-1a	Supply air flow control at the room level	yes
Controlled ventilation	Ventilation-1b	Adjust the outdoor air flow rate	yes
Controlled ventilation	Ventilation-1c	Air flow or pressure control at the air handler level	yes
Controlled ventilation	Ventilation-2a	Room air temp. control (all-air systems)	yes
Controlled ventilation	Ventilation-2b	Room air temp. control (Combined air-water systems)	no
Controlled ventilation	Ventilation-2c	Heat recovery control: prevention of overheating	yes
Controlled ventilation	Ventilation-2d	Supply air temperature control	yes
Controlled ventilation	Ventilation-3	Free cooling with mechanical ventilation system	yes
Controlled ventilation	Ventilation-4	Heat recovery control: icing protection	no
Controlled ventilation	Ventilation-5	Humidity control	no
Controlled ventilation	Ventilation-6	Reporting information regarding IAQ	yes
Lighting	Lighting-1a	Occupancy control for indoor lighting	yes
Lighting	Lighting-1b	Mood and time based control of lighting in buildings	no
Lighting	Lighting-2	Control artificial lighting power based on daylight levels	yes
Dynamic building envelope	DE-1	Window solar shading control	yes
Dynamic building envelope	DE-2	Window open/closed control, combined with HVAC system	yes
Dynamic building envelope	DE-3	Changing window spectral properties	no
Energy generation	EG-1	Amount of on-site renewable energy generation	no
Energy generation	EG-2	Reporting information regarding energy generation	yes
Energy generation	EG-3	Storage of locally generated energy	yes
Energy generation	EG-4	Optimizing self-consumption of locally generated energy	yes
Energy generation	EG-5	CHP control	yes

Demand side management	DSM-1	Services for integration of renewables into the building energy portfolio	no
Demand side management	DSM-2	Services for integrating battery storage systems into energy portfolio	no
Demand side management	DSM-3	Support of microgrid operation modes	no
Demand side management	DSM-4	Integration of smart appliances	no
Demand side management	DSM-5	Power flows measurement and communications	no
Demand side management	DSM-6	Energy delivery KPI tracking and calculation	no
Demand side management	DSM-7	Fault location and detection	no
Demand side management	DSM-8	Fault prevention and risk assessment	no
Demand side management	DSM-9	Fraud detection and losses calculation	no
Demand side management	DSM-10	Neighbourhood energy efficiency calculation	no
Demand side management	DSM-11	Demand prediction	no
Demand side management	DSM-12	Information exchange on renewables generation prediction	no
Demand side management	DSM-13	Heat management for a multi-tenant house by aggregator	no
Demand side management	DSM-14	Flexible start and switch off of home appliances	no
Demand side management	DSM-15	DSM control of a device by an aggregator	no
Demand side management	DSM-17	Energy storage penetration prediction	no
Demand side management	DSM-18	Smart Grid Integration	yes
Demand side management	DSM-19	DSM control of equipment	yes
Demand side management	DSM-20	Connecting PV to DSO grid	no
Demand side management	DSM-21	Reporting information regarding DSM	yes
Demand side management	DSM-22	Override of DSM control	yes
Electric vehicle charging	EV-1	Charging whenever needed at the charging pole of the building ("dumb charging service")	no
Electric vehicle charging	EV-3	Charging with local, building system based control (price signal based charging)	no
Electric vehicle charging	EV-4	Charging with aggregated control (EV responsible party as VPP balancing responsible party)	no
Electric vehicle charging	EV-5	Charging with aggregated control (EV responsible party under a balance responsible party)	no
Electric vehicle charging	EV-7	Grid connected heating for EV in winter time	no
Electric vehicle charging	EV-8	Providing system services to DSO operations	no
Electric vehicle charging	EV-9	Charging for optimisation of the EV battery life-cycle	no

Electric vehicle charging	EV-10	Charging at a commercial building site - roaming	no
Electric vehicle charging	EV-11	Charging based on DSO price tags - " local wind storage"	no
Electric vehicle charging	EV-12	Providing the state-of-charge to home display	no
Electric vehicle charging	EV-13	Fast charging services - mode 4	no
Electric vehicle charging	EV-14	Vehicle to grid operation and control	no
Electric vehicle charging	EV-15	EV Charging Capacity	yes
Electric vehicle charging	EV-16	EV Charging Grid balancing	yes
Electric vehicle charging	EV-17	EV charging information and connectivity	yes
Monitoring and control	MC-1	Heating and cooling set point management	no
Monitoring and control	MC-2	Control of thermal exchanges	no
Monitoring and control	MC-3	Run time management of HVAC systems	yes
Monitoring and control	MC-4	Detecting faults of technical building systems and providing support to the diagnosis of these faults	yes
Monitoring and control	MC-5	Reporting information regarding current energy consumption	no
Monitoring and control	MC-6	Reporting information regarding historical energy consumption	no
Monitoring and control	MC-7	Reporting information regarding predicted energy consumption	no
Monitoring and control	MC-9	Occupancy detection: connected services	yes
Monitoring and control	MC-10	Occupancy detection: space and activity	no
Monitoring and control	MC-11	Remote surveillance of building behaviour	no
Monitoring and control	MC-12	Central off-switch for appliances at home	no
Monitoring and control	MC-13	Central reporting of TBS performance and energy use	yes
Various	VA-1	Coming home - leaving home functions	no
Various	VA-2	Inactivity recognition services	no
Various	VA-3	Multi-tenant access control for buildings without keys	no
Various	VA-4	Occupants Wellbeing and health status monitoring services	no
Various	VA-5	Dementia monitoring	no
Various	VA-8	Rain water Collection	no
Various	VA-9	Smoke detection	no
Various	VA-10	Water leakage detection	no
Various	VA-11	Carbon Monoxide detection	no
Various	VA-12	Emergency notification services	no
Various	VA-13	Smart testing of emergency lighting	no
Various	VA-14	Intelligent alerting on building events	no
Various	VA-18	Energy Cost Allocation for heating, cooling and water	no

4510
4511
4512
4513
4514
4515

4516

ANNEX B – GLOSSARY

4517 **Attribute:** An attribute of a service is a variable (typically a piece of data) which may take different
4518 values, thereby influencing the state of the service. A basic switch of a heating system would for
4519 instance take a binary value (on or off), while more complex control devices could take discrete or
4520 continuous control values.

4521
4522 **Building user** is defined as a stakeholder of the building, who can have different roles, e.g. the owner
4523 of the building or the occupant. The building user interacts with the services provided by the building,
4524 therefore, his or her viewpoints are of highest interest in assessing the perceived smartness of
4525 individual technologies in the building and the overall perceived smartness of the building. In
4526 addition, the building user can interact with the grid, providing his building to the grid as an asset for
4527 flexibility, generation or storage of energy.

4528
4529 **(Service) Catalogue:** A service catalog (or catalogue), is an organized and curated collection of
4530 technology-related services. Each service within such a service catalogue is usually repeatable and is
4531 associated to well-defined inputs, processes, and outputs.

4532
4533 In the scope of this study, we define a smart service catalogue for a building technology as the
4534 overview of the services provided by a smart building.

4535
4536 **Domain:** Within this project, domains are high-level viewpoints used to structure the smart services
4537 models. Each domain focuses on a key aspect of the building Climate, heating, lighting, DSM, DER
4538 etc., are domains of services which are provided by the building.

4539
4540 **Enabling technologies:** some technologies do not provide smart services themselves, but are
4541 providing infrastructure provision to the higher level operations. As an example, a fieldbus or bus
4542 system in a house would be an enabling (interoperability) technology. The same way, the broadband
4543 connection to a household itself is an enabler to let the building communicate with other buildings
4544 in order to, e.g. create a swarm or sensor community.

4545
4546 **End user** is defined as a building user who always interacts directly with the services provided by the
4547 building. The end user is typically providing the trigger event to start a service and use it. In the case
4548 of a building this can be an occupant, or a technical facilities manager.

4549
4550 **Function:** A function represents an interaction between a building user and a building system. In
4551 comparison to a service, a function is more basic (in particular with regard to the number of inputs
4552 and outputs involved). Functions can be combined into services.

4553
4554 A typical function would be a state change based on a trigger event, e.g. change of state of a switch.

4555
4556 **Readiness:** refers to the capability of a technology, a system or a building to implement smart
4557 functions and services. This capability is based on the corresponding technology is enabled and the
4558 related function is invoked.

4559 For instance, a system can be smart-ready (e.g. a controllable heat pump) but not smart (the
4560 controllable heat pump is not connected to a controller and / or has no configuration interface).

4561

4562 **Smartness** refers to the capability of a building or its systems to sense, interpret, communicate and
4563 actively respond in an efficient manner to the changing conditions, which are introduced by demands
4564 of the building occupant, the operation of technical building systems or the external environment
4565 (including energy grids).

4566

4567 **Smart ready technologies** are the foundation for the services to be implemented on. Services use
4568 those technologies like e.g. bus systems, communication protocols or building automation systems.
4569 Regarding the term smart, we consider certain capabilities as smart – focusing on optimization,
4570 interaction with occupants and being interoperable and adaptive.

4571

4572 **Service:** a service is a function or an aggregation of functions delivered by one or more technical
4573 components or systems. Services are invoked in order to serve a (business) purpose of a stakeholder
4574 and can range from simple (micro services) to complex. In this study, a Smart service makes use of
4575 Smart ready technologies and orchestrates them to higher level functions.

4576

4577 An example would be the following: Using an application, e.g. on a mobile phone, the user invokes
4578 the activation of a wireless protocol-based controlled light-bulb as a comfort function. This is either
4579 a micro service or a single function. In order to activate one or more light bulbs when arriving at
4580 home, the user can use the mobile in order to get the perimeter trigger of e.g. the front door, which
4581 then activates the predefined light scene. This can be considered a service since it is based on
4582 individual, more atomic functions which are composed to a service which provides more added
4583 value.

4584

4585 Another example dealing with the EV Charger at a home would be a service dealing with the charging
4586 of a car. The user needs to go 20 km to work the next day starting at 6AM and arrive at home at 7PM
4587 and connects the car to the charging station. The service calculates the optimum charging process,
4588 schedule and pricing and charges the vehicle according to the boundary conditions set by the user.

4589

4590 **Taxonomy:** In the scope of the project, a taxonomy is the result of the practice and science of
4591 classification of things or concepts, including the principles that underlie such classification. Within
4592 this context, the aim is to classify certain attributes of building technologies and link to their
4593 characteristics in order to find functionality levels.

4594

4595 **Technology:** Technology is the collection of techniques, skills, methods and processes used in the
4596 production of goods or services or in the accomplishment of objectives.

4597 Within this project, we consider technology as enabler of functions and services or even readiness.

4598

4599 **Technical building system:** In the EPBD under Article 2(3), a ‘technical building system’ is defined as
4600 a technical equipment for the heating, cooling, ventilation, hot water, lighting or for a combination
4601 thereof, of a building or building unit. In the proposal for amending the EPBD, this definition is
4602 extended to building automation and control, on-site electricity generation and on-site
4603 infrastructure for electro-mobility. In this study this definition is extended to a broader scope, taking
4604 the connection of the building to the other infrastructures like electricity, water, waste water, etc.
4605 more into account.

4606

4607 **Viewpoint** is a modeling concept. Modeling has the purpose of reducing the complexity of a given
4608 system in order to focus on particular aspects, which are particularly relevant to one or more
4609 stakeholders. Viewpoints generally differ from one stakeholder to the other (e.g. for a building, the
4610 architect viewpoint will differ from the facility manager or aggregator viewpoint). In modeling, one
4611 key objective is to agree on harmonized and complementary viewpoints.

4612

4613

ANNEX C – INTEROPERABILITY OF SMART READY TECHNOLOGIES

4614 As discussed in section 3.4.3, interoperability of smart ready technologies is crucial for many of the
4615 smart services in a building and to prevent vendor-lock-in effects. Interoperability requires the
4616 establishment of a common shared information model that is to be used throughout many
4617 applications and systems.

4618
4619 Typically, one has to distinguish between various levels of interoperability which will be discussed in
4620 the next paragraphs. Assessing interoperability by metrics is not completely new in the context of
4621 the Smart Readiness Indicator. As early as in the 1980s, this has been defined as a problem by the
4622 EC⁶³. First, this was only treated as a problem from the perspective of team working on code for a
4623 common software or system towards a common goal (e.g. shared functionality). The focus was on
4624 easily integrating parts and components. Later, it became apparent that systems from various
4625 vendors with no common development unit would have to interact [2]. Typically, interoperability is
4626 defined as the ability of one or more systems or elements to exchange information and to use the
4627 information that has been exchanged. One has typically to distinguish between four high level
4628 requirements for interoperability:

- 4629 • Technical interoperability
- 4630 • Syntactic interoperability
- 4631 • Semantic interoperability
- 4632 • Organizational interoperability

4633
4634 **Technical interoperability** in the context of the SRI would focus on the hardware as well as software,
4635 plug-ins being compatible, the same protocols being used, platforms for M2M communications with
4636 back-end systems.

4637 As the system on a building is assessed at run-time this can typically be taken as given, since the
4638 system is operational at that time being. Nevertheless, technical interoperability might still be critical
4639 if the TBS are to be expanded, especially in case this is done with components from another vendor.

4640
4641 **Syntactic interoperability** focuses on the data formats, while CSV based or XML based data still has
4642 the same format, parts may be missing in a payload or be optional. For the SRI, there might be
4643 information missing on some aspects of controls to be deployed. This shall not occur for a given,
4644 running system but the extension this will be a problem.

4645
4646 The dimension of **semantic interoperability** focuses on the interpretation of the data, meaning the
4647 same signal triggers a correct event or the data is interpreted the same by systems from different
4648 vendors. A common understanding is needed, therefore, it is hard to actually assess this at the SRI
4649 inspection time. However, this aspect was taken into account when creating the basic structure of
4650 the service catalogue. The service catalogue is based to large parts on harmonized, existing
4651 taxonomies as already presented in the task 1 section. One specific taxonomy, which was taken into
4652 account, was SAREF. The SAREF ontology presents a controlled vocabulary and concepts, which
4653 define semantics. For this study, we have taken into account the main SAREF ontology as well as the
4654 Smart Appliances and SEP2 ontology⁶⁴.

4655

⁶³ https://ec.europa.eu/isa2/eif_en, [4]

⁶⁴ <https://sites.google.com/site/smartappliancesproject/ontologies/reference-ontology>

4656

4657 The last dimension, **organizational interoperability** deals cross company, cross region and culture
4658 interpretation of the data, mostly, e.g. in the same context. Given the time before the GDPR,
4659 different organizations had different right and laws to treat personal data (e.g. with a data center in
4660 the US). This harmonization of the system context leads to a better organizational interoperability in
4661 long term [Rezaei et al., 2013].

4662

4663

4664 In the scope of SRI, many of these factors are too hard to be measured at inspection time by a non-
4665 system savvy technician from a third party. If interoperability metrics were to be introduced in SRI,
4666 a focus should therefore primarily be on the dimensions of technical and syntactical interoperability.
4667 A hypothetical analysis of such interoperability would require investigating multiple factors, such as:
4668 [Kasuni, 2001]:

4669

- Standards explicitness

4670

- Standards maturity

4671

- Standards vendors supporting

4672

- Standards feature coverage

4673

- Standards profiles implemented

4674

- Profile explicitness

4675

- Profile coverage

4676

- Profile extensions

4677

- Profile documentation

4678

- Products available supporting

4679

- Product performance

4680

- Supported platforms

4681

- Conformance testing in place

4682

- Product -2- Product Interoperability tests

4683

4684 As it is obvious from the extensive list presented here, assessing the interoperability of systems in a
4685 building environment requires an elaborate assessment procedure in itself. Typically, we assume this
4686 was done at engineering or construction time of a building, taking into account most factors from
4687 the previous list. After all, this contributes to a maintainable technical solution with better lifecycle
4688 costs.

4689 For a very quick assessment at inspection time, the focus should be on long-term support and
4690 standardization, thus, the factors:

4691

- Standards explicitness

4692

- Standards maturity

4693

- Profile extensions

4694

- Products available supporting

4695

- Conformance testing

4696

4697 Those five categories could be a base for a (very simple) interoperability indicator to assess solutions
4698 in the context of the Smart readiness indicator. In the context of the European Interoperability
4699 Framework (EIF) which deals with government to government and government to citizen data
4700 interoperability, the very same categories were taken into account by the European commission
4701 [Section 3.3 to 3.6, European Interoperability Framework EIF, 2017]. Nevertheless, even such
4702 simplified interoperability indicator would require significant time and effort, especially in existing
4703 buildings with poorly documented TBS. Therefore, it was opted to not explicitly assess the
4704 interoperability of smart ready technologies, but rather take this into account in some specific
services of the proposed SRI (see section 3.4.3 of this report).

4705

ANNEX D – STANDARDISATION RELATED TO SMART BUILDINGS

4706 **D.1. THE ENERGY PERFORMANCE OF BUILDINGS DIRECTIVE (EPBD), THE CONSTRUCTION PRODUCTS REGULATION** 4707 **(CPR) AND ITS RELATIONSHIP TO STANDARDISATION AND MANDATE (M/480)**

4708 It is worth noting that the EPBD is an EU directive, which transposition and enforcement are under
4709 the responsibility of the Member States and which allows for some flexibility at National and local
4710 levels.

4711 This is illustrated by the variety of standards and regulations that co-exist in the EU. At the time that
4712 this report was first written (July 2017), 35 different national and regional methodologies to calculate
4713 the energy performance of buildings were available. In order to support a reliable comparison of
4714 calculation methods across the EU, and with the aim to support National Authorities in the effective
4715 implementation of the EPBD, the European Commission issued mandate M/480 to CEN, CENELEC
4716 and ETSI for the elaboration and adoption of standards for a methodology calculating the integrated
4717 energy performance of buildings and promoting the energy efficiency of buildings, in accordance
4718 with the terms set in the recast of the Directive on the energy performance of buildings.
4719

4720
4721 **The new/reviewed EPBD standards within M/480 became available recently (July 2017),**
4722 **complementary to these standards is an online tool that guides the user through the set of**
4723 **standards (CEN, 2017).** For the reader it is also important to understand that a modular EPBD EN
4724 standard system has been introduced and some EN standards were renumbered at ISO level, as a
4725 consequence some EN standards may have new references as of 2017 and not necessarily all possible
4726 modules are already covered by a standard. Also EN EPBD standards use numbers 15xxx and ISO
4727 52xxx. For example, former standard EN 13790-1:2003 is replaced by EN ISO 52016-1.

4728
4729 Complementary to this, the European Commission adopted the Construction Products Regulation
4730 (CPR) that lays down harmonized rules for the marketing of construction products in the EU, i.e.
4731 Regulation (EU) No 305/2011. Note that CPR is EU Regulation and not a Directive, therefore there is
4732 no need additional step for transposition in local requirements neither standardization. The
4733 regulation is embedded in the goal of creating a single market ("Article 95") for construction products
4734 through the use of CE Marking. It outlines basic requirements for construction works (as the sum of
4735 its components) that are the basis for the development of the standardization mandates and
4736 technical specifications i.e. harmonised product standards and European Assessment Documents
4737 (EADs). The basic idea is to harmonise the way the performance of a construction product is
4738 determined and declared in levels or classes while each Member State may have individual
4739 requirements regarding the required minimum level or class for a given use.

4740
4741 At the current state of the project it is not decided to what extent the SRI will be making a connection
4742 to the EPBD, and especially EPCs (Energy Performance Certificates). If such a connection is deemed
4743 relevant, several approaches can be envisioned to deal with this current diversity amongst member
4744 states. This will be further explored as part of the work undertaken in Task 2 of this project.

4745 **D.2. INTERACTION WITH THE ELECTRICAL GRID AND THE SMART GRID STANDARDIZATION MANDATE (M/490)**

4746 The M/490 Smart grid mandate was issued to the three large standardisation bodies CEN, CENELEC
4747 and ETSI in order to consolidate the standardization landscape for smart grids. In order to ensure

4748 interoperability for the heterogeneous systems at infrastructure level, standards had to be either
4749 found or defined in later stages. The working groups within the mandate created a process for
4750 governance of smart grid standardization, created an overview and mapping of existing standards
4751 taking into account the various viewpoints from the stakeholders involved and did a gap analysis for
4752 the standardization bodies in order to find gaps for new working item proposals for those bodies and
4753 their working groups. In the second stage of the four year term of the mandate, security and
4754 interoperability testing were the focus. In addition, the results from both the metering mandate as
4755 well as the electric vehicles mandate were harmonized and taken into account, making the overview
4756 of smart grid as an infrastructure, smart metering as well as electric vehicles seamless. Currently, the
4757 platform of ETIP SNET⁶⁵ will build upon those results.

4758 **D.3. INTERACTION WITH ECODESIGN PRODUCT REGULATION AND STANDARDISATION MANDATE (M/495)**

4759 The request from the Commission (EC mandate M/495) is a horizontal mandate covering more than
4760 25 different types of products that use energy or have an impact on the use of energy. Types of
4761 products covered by this mandate include: air conditioning and ventilation systems, boilers, coffee
4762 machines, refrigeration units, ovens, hobs and grills, lamps and luminaries, tumble dryers, heating
4763 products, computers and monitors, washing machines, dryers and dishwashers, sound and imaging
4764 equipment and water heaters, etc.

4765 **D.4. BACKGROUND INFORMATION ON EUROPEAN AND INTERNATIONAL STANDARDIZATION BODIES**

4766 In the European Union, only standards developed by CEN, CENELEC and ETSI are recognized as
4767 European standards.

4768

4769 **CEN is the European Committee for Standardization.**

4770 Within CEN Standards are prepared by Technical Committees (TCs). They do not deal with electrical
4771 equipment neither telecommunication which is within the scope of CENELEC and ETSI.

4772 Within CEN TC 371 is the Program Committee on EPB standards. This TC 371 organizes this central
4773 coordination team in cooperation with the other relevant CEN TC's:

4774 • CEN TC 89, Thermal performance of buildings and building components

4775 • CEN TC 228, Heating systems in buildings

4776 • CEN TC 156, Ventilation for buildings

4777 • CEN TC 247, Controls for mechanical building services (EN 15232)

4778 • CEN TC 169, Light and lighting (EN 15193, prEN 17037)

4779

4780 **CENELEC is the European Committee for Electrotechnical Standardization** and is responsible for
4781 standardization in the electro-technical engineering field. It cooperates in International level with
4782 IEC, hence within CENELEC are often mirror committees to what is developed within IEC and
4783 therefore often the relevant TC's with work in progress can be found at IEC level.

4784 Relevant CENELEC TC's are:

4785 • CLC/TC 20 is responsible for Home and Building Electronic Systems (HBES)

4786 • Much are mirror committees of IEC, therefore see also IEC operating at international level.

4787

⁶⁵ <http://www.etip-snet.eu/>

4788 **ETSI, the European Telecommunications Standards Institute**, produces standards for Information
4789 and Communications Technologies (ICT), including fixed, mobile, radio, converged, broadcast and
4790 internet technologies.

4791 An overview of important smart grid and building communication and interoperability standards can
4792 be found on their website⁶⁶.

4793

4794 **A European Standard (EN)** is a standard that has been adopted by at least one of the three
4795 recognized European Standardisation Organisations (ESOs): CEN, CENELEC or ETSI.

4796

4797 An overview of relevant Technical Committees within CEN, CENELEC and ETSI is included in TBD.

4798 **A National Standard at Member State level, A DIN-EN or AFNOR-EN, etc. is a national standard. It
4799 is published as each country in Europe adopts the EN document.**

4800

4801 **Beyond Europe is also the International Organization for Standardization (ISO)** for non electro-
4802 technical standards.

4803 When an ISO document is released, countries have the right to republish the standard as a national
4804 adoption. When CEN adopts an ISO standard its reference becomes, e.g. EN-ISO-52000-1, and later
4805 on when a Member State adopts this e.g. DIN-EN-ISO. In the context of the ongoing review of EPB
4806 standards, many are expected to be published as EN & EN-ISO standards. This means that the old
4807 numbering system of 2007 in an EN 15000 series of standards is not necessarily maintained and
4808 sometimes replace by the ISO 52000 series of standards.

4809 Relevant ISO TC's are:

- 4810 • ISO/TC 163 is responsible for Thermal performance and energy use in the built environment
4811 and part of the EPBD related standards.
- 4812 • ISO/TC 205 is responsible for Building environment design, a.o. is responsible for ISO 16484
4813 on BACS.

4814

4815 At international level **the International Electrotechnical Commission (IEC)** is the overarching
4816 organization of CENELEC.

4817 Within IEC the most relevant TCs from our view are:

- 4818 • IEC TC 8 is responsible for Systems aspects for electrical energy supply
- 4819 • IEC TC 64 is responsible for IEC 60364-8-1 ED2 on Energy Efficiency and IEC 60364-8-1 ED2
4820 on Smart Low-Voltage Electrical Installations
- 4821 • IEC TC 69 is responsible for Electric road vehicles and electric industrial trucks, amongst they
4822 take care of EV chargers.
- 4823 • IEC TC 57 covers the Smart grid related connections of a building

4824 **D.5. A SELECTION OF THE MOST RELEVANT STANDARDS FOR SRI**

4825 **D.5.1. At European Level (EN) related to EPBD calculation methods**

4826 The standards from Mandate M/480 consist in general of two parts, where the first part is a
4827 normative part (for example with the template) and the second part is an informative part (for
4828 example containing proposals for default data). Hereafter is a short description of the main
4829 standards. Also, according to The Detailed Technical Rules, and in agreement with the mandate
4830 M/480 for each EPB-standard containing calculation procedures an accompanying spreadsheet has

⁶⁶ <http://www.etsi.org/technologies-clusters/technologies/575-smart-grids>

4831 been prepared to test and validate the calculation procedure. The spreadsheet also includes a
4832 tabulated overview of all output quantities (with references to the EPB module where it is intended
4833 to be used as input), all input quantities (with references to the EPB module or other source from
4834 where the data are available) and a fully worked example of the application (the calculation method
4835 between the set of input and output quantities) for validation and demonstration⁶⁷.

4836

4837 **EN-ISO 52000-1:2017 Energy performance of buildings — Overarching EPB assessment – Part 1:**
4838 **General framework and procedures**

4839

4840 The main output of this standard is the overall energy performance of a building or building part (e.g.
4841 building unit). In addition: breakdown in partial energy performance, e.g. per energy service (heating,
4842 lighting, etc.), per building unit, per time interval (hour, month, etc.) and breakdown in energy flows
4843 at different perimeters and e.g. delivered versus exported energy.

4844 Depending on the application, all or some of the other standards related to the energy performance
4845 of buildings that cover other parts of the modular structure are needed (EPB standards). It introduces
4846 a modular structure to cover all aspects of the building energy balance and its subsystems, see Table
4847 D1.

4848

⁶⁷ <https://isolutions.iso.org/ecom/public/nen/Livelink/open/35102456>

Overarching		Building (as such)		Technical Building Systems										
Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot water	Lighting	Building automation & control	Electricity production	
sub 1	M1	sub 1	M2	sub1	M3	M4	M5	M6	M7	M8	M9	M10	M11	
1	General	1	General	1	General									
2	Common terms and definitions; symbols, units and subscripts	2	Building Energy Needs	2	Needs									
3	Applications	3	(Free) Indoor Conditions without Systems	3	Maximum Load and Power									
4	Ways to Express Energy Performance	4	Ways to Express Energy Performance	4	Ways to Express Energy Performance									
5	Building Functions and Building Boundaries	5	Heat Transfer by Transmission	5	Emission & control									
6	Building Occupancy and Operating Conditions	6	Heat Transfer by Infiltration and Ventilation	6	Distribution & control									
7	Aggregation of Energy Services and Energy Carriers	7	Internal Heat Gains	7	Storage & control									
8	Building Zoning	8	Solar Heat Gains	8	Generation & control									
9	Calculated Energy Performance	9	Building Dynamics (thermal mass)	9	Load dispatching and operating conditions									
10	Measured Energy Performance	10	Measured Energy Performance	10	Measured Energy Performance									
11	Inspection	11	Inspection	11	Inspection									
12	Ways to Express Indoor Comfort			12	BMS									
13	External Environment Conditions													
14	Economic Calculation													

4849

4850

Table D1 - Summary of the main modular structure of the EPB Standards

4851 In general it is important to note that the standard defines system boundaries (the concept of
 4852 concept of perimeters and assessment boundary, zoning,) and amongst others also defines a
 4853 Renewable Energy Ratio (RER).

4854 The contribution of building automation and control (BAC) including technical building management
 4855 (TBM) to the building energy performance is considered in the calculation procedure as the impact
 4856 of all installed building automation and control functions (BAC functions) on the building energy
 4857 performance.

4858 It deals with three characteristics:


- 4859 • Control Accuracy (mainly used in emission and control modules M3-5, M3-4, M3-5)
- 4860 • BAC Functions (mainly used in modules M3-5, M3-9, M9-5, M9-9)
- 4861 • BAC Strategies (mainly used for M10-12)

4862 The contribution of one such BAC function is taken into account by one of the following five
 4863 approaches: time approach, set-point approach, direct approach, operating mode approach and
 4864 correction coefficient approach. The application of one of the first two approaches – the time
 4865 approach or the set-point approach - leads in general to a modification of the time programs and

4866 set-points, both coming from the module which defines the user profile (M1-6 Building Occupancy
 4867 and operating conditions). Which approach is applied and how it is exactly done, is described in the
 4868 EPB standard which is devoted to the module which treats the BAC function (M10). For BAC functions
 4869 which are treated in one of the EPB standards for modules M3-5, M3-9, M9-5, M9-9, M10-5, M10-9,
 4870 all five approaches are possible, for BAC functions which are treated in M10-12 the first two
 4871 approaches are applied.

4872

4873 Directly related to EPB there are about 52 EN and/or ISO standards to define the calculation method
 4874 (see Figure D1 for an overview). It can already be concluded that this update consists of a complex
 4875 set of interrelated standards for which the application of the proposed version is still in its infancy
 4876 and it will need to be judged in how far the data contained herein can be applied for the SRI indicator.
 4877



4878

4879

Figure D1 - Overview of applicable standards in the ongoing review of EPB (Jaap, 2016)

4880 **EN 15232-1:2017 is the standard 'Energy performance of buildings - Impact of Building**
 4881 **Automation, Controls and Building Management.'** (Module M10)

4882 This European Standard specifies:

- 4883
- 4884 • a structured list of Building Automation and Control System (BACS) and Technical Building Management (TBM) functions which have an impact on the energy performance of buildings;
 - 4885 • a method to define minimum requirements regarding BACS and TBM functions to be implemented in buildings of different complexities;
 - 4886 • a factor based method to get a first estimation of the impact of these functions on typical buildings;
 - 4887 • detailed methods to assess the impact of these functions on a given building. These methods enable the impact of these functions in the calculations of energy performance ratings and indicators calculated by the relevant standards to be introduced.

4892

4893 The standard defines the following control functions:

4894 For heating control:

- 4895 • 'Emission control', e.g. individual room temperature control with BACS including schedulers and presence detection can lower the general heat demand.
- 4896

- 4897
- 4898
- 4899
- 4900
- 4901
- 4902
- 4903
- 4904
- 4905
- 4906
- ‘Control of distribution pumps in networks’, e.g. switching off circulation pumps when not required.
 - ‘Heat generator control for combustion and district heating’, e.g. reducing the return temperature based on load forecasting to increase boiler efficiency by condensation.
 - ‘Heat generator control for heat pump’, e.g. controlling the exit temperature base on load forecasting.
 - ‘Heat pump control system’, e.g. inverter driven variable frequency compressor depending on the load.
 - Other functions are ‘Sequencing of different heat generators’, ‘Thermal Energy Storage’ or ‘control of Thermo Active Building Systems(TABS)’.
- 4907 For domestic hot water(DHW) supply:
- 4908
- 4909
- 4910
- Reduce stand by losses in hot water storage tank (if any) with automatic on/off control based on forecasted demand.
 - Control of DHW pump (if any).
- 4911 For cooling control:
- 4912
- 4913
- Many of those functions are similar to heating (see EN 15232-1:2017).
 - ‘Interlock between heating and cooling’ to avoid simultaneous heating and cooling.
- 4914 For air supply or ventilation (if any):
- 4915
- 4916
- 4917
- 4918
- 4919
- Demand driver variable outside air supply;
 - Heat recovery unit, icing protection;
 - Free air night time cooling mechanical by automatic opening windows and/or operating the ventilation unit
 - Humidity controls (if any)
- 4920 Lighting controls; they can increase the building cooling demand or decrease the heating demand.
- 4921 Blind control; there are two requirements which are prevent overheating and reduce glare and therefore controls can be combined with HVAC and lighting.
- 4922
- 4923 Technical Building Management (TBM) system, the aim is to adapt easily to the user needs and therefore it shall be checked frequently. TBM functions are (see also EN 16947 with more details):
- 4924
- 4925
- 4926
- 4927
- 4928
- 4929
- 4930
- 4931
- 4932
- 4933
- 4934
- 4935
- 4936
- 4937
- 4938
- 4939
- 4940
- 4941
- 4942
- 4943
- 4944
- 4945
- 4946
- Set point management, e.g. web operated heating/cooling temperature set points (20°C/26°C) with frequent resetting to default values where relevant.
 - Run time management, e.g. predefined schedule (e.g. a night time set back temperature) with variable preconditions (e.g. no presence in the room).
 - Manage local renewable sources or CHP to optimize own consumption and use of renewables.
 - Control of Thermal Energy Storage of heat recovery (if available).
 - Smart Grid integration.
 - Detect faults in the Technical Building System (TBS), for example:
 - Read out alarms from the heat pump, gas boiler, .. and provide understandable building owner feedback and alarm logging
 - Continuous monitoring of SCOP (Seasonal Coefficient Of Performance) or SEER (Seasonal Energy Efficiency Ratio) of a heat pump to verify maintenance needs (e.g. clogged heat exchanger, cooling fluid leakage, ..)
 - Regular checking sequence to verify the maximum power output of a heat pump or gas boiler to verify maintenance needs (e.g. contaminated gas burner, dirt on heat exchanger, valve errors, damage on pipe insulation, installation errors such as reverse connection of heat exchangers, correct control logic and set point of circulation pumps).
 - Check the power consumption of the Air Handling Unit (e.g. increased power consumption due to clogged filter or air inlet/outlet, leakages in or clogged ventilation duct work, broken air dampers/fans)

- 4947 • Reporting regarding energy consumption relative to indoor conditions:
 4948 ○ Show actual values and logged trends
 4949

4950 The standard also defines four classes that poses specific requirements on the previous control
 4951 functions. It contains a simplified calculation method based on BAC efficiency factors, for lighting
 4952 reference is made to EN 15193.

4953 The 4 classes of Building Automation Systems are:

- 4954 • Class A: High energy performance building automation and control system (BACS) and
 4955 technical building management (TBM);
 4956 • Class B: Advanced BACS and TBM;
 4957 • Class C: Standard BACS;
 4958 • Class D: Non energy efficient BACS;

4959 For each class minimum control system requirements are defined.

Table 1 — (concluded)

		Definition of classes							
		Residential				Non residential			
		D	C	B	A	D	C	B	A
LIGHTING CONTROL									
Occupancy control									
0	Manual on/off switch	■	■			■	■		
1	Manual on/off switch + additional sweeping extinction signal	■	■			■	■		
2	Automatic detection Auto On / Dimmed	■	■			■	■		
3	Automatic detection Auto On / Auto Off	■	■			■	■		
4	Automatic detection Manual On / Dimmed	■	■			■	■		
5	Automatic detection Manual On / Auto Off	■	■			■	■		
Daylight control									
0	Manual	■	■			■	■		
1	Automatic	■	■			■	■		

4960

4961

Figure E2 - Table 1 on lighting controls defined in EN 15232

4962 Afterwards the simple method in the standard defines relations between building energy systems
 4963 and so-called BAC efficiency factors for different types of energy use, including lighting, see figure D-
 4964 3. These factors enable savings to be estimated. For a detailed calculation on the impact the
 4965 individual standards should be considered and therefore references to these related standards are
 4966 included (e.g. EN 15193 for lighting).

4967 Also, according to The Detailed Technical Rules, and in agreement with the mandate M/480 [2], for
 4968 each EPB-standard containing calculation procedures an accompanying spreadsheet has been
 4969 prepared to test and validate the calculation procedure. The spreadsheet also includes a tabulated
 4970 overview of all output quantities (with references to the EPB module where it is intended to be used
 4971 as input), all input quantities (with references to the EPB module or other source from where the
 4972 data are available) and a fully worked example of the application (the calculation method between
 4973 the set of input and output quantities) for validation and demonstration⁶⁸.

4974

4975 **EN 16947-1:2017 Building Management System - Module M10-12**

4976 This is a new European Standard to address the TBM/BMS functions. This new standard covers
 4977 several functions of the application of the Building management system. Each function is
 4978 represented by at least one calculation method. The functions are as follow:

- 4979 • Function 1 – set points is meant for set point definition and set back.
 4980 • Function 2 – run time is intended for estimating run times.

⁶⁸ <https://isolutions.iso.org/ecom/public/nen/Livelihood/open/35102456>

- 4981
- 4982
- 4983
- 4984
- 4985
- 4986
- 4987
- 4988
- Function 3 – sequencing of generators is intended for estimating the sequential arrangement of different functions to be performed
 - Function 4 – local energy production and renewable energies is intended for managing local renewable energy sources and other local energy productions as CHP.
 - Function 5 – heat recovery and heat shifting is intended for shifting thermal energy inside the building.
 - Function 6 – smart grid is meant for interactions between building and any smart grid.

4989 **EN ISO 52016-1:2017 Energy performance of buildings -- Energy needs for heating and cooling, internal temperatures and sensible and latent heat loads -- Part 1: Calculation procedures.**

4990 This standard defines the building latent heat load using an hourly calculation interval. It describes an important parameter for modelling the impact of for example the BACS night time set back temperature function (EN or thermal storage in smart grids is the building time constant (τ)[hours]. It also contains a parameter to model the impact of the temperature control system ($\Delta\theta_{ctr}$), which is 0 for a perfect control system.

4997 **EN 15193-1: 2017 Energy performance of buildings - Energy requirements for lighting - Part 1: Specifications, Module M9**

4998 This standard deals with energy requirements for lighting and defines different lighting control systems (e.g. occupancy control type, type of daylight control, type of blinds control) and their impact on energy savings (e.g. occupancy factor (F_o), daylight factor (F_d)). It calculates the Lighting Energy Numeric Indicator for a building (LENI) in kWh/m²/y based on assumption for occupants' schedules (EN ISO 17772-1:2017). Background information to this standard is documented in CEN/TR 15193-2: Energy performance of buildings — Energy requirements for lighting; Part 2: Explanation and justification of EN 15193-1, Module M9.

5007 **prCEN/TS 17165 “Lighting System Design Process”**

5008 This document is developed in the frame of ENER Lot 37 and describes the key design considerations in the process for good quality, energy efficient and effective lighting systems in the tertiary sector.

5012 **ISO 17772-1:2017 Energy performance of buildings -- Indoor environmental quality -- Part 1: Indoor environmental input parameters for the design and assessment of energy performance of buildings.**


5015 The standard contains indoor environmental input parameters for the design and assessment of energy performance of buildings. It deals also with occupants' schedules for energy calculations which can have important impact on energy calculations. Of course, apart from the assumptions, the real occupant behaviour will have similar impact. Advanced Building Automation and Control Systems (BACS) (EN 15232-1:2017) can include set point management which means that set points (e.g. illumination levels, comfort temperature, air quality, ..) can be redefined over the life time of the building when the task area, zone requirements or real user needs change. Usually however EPBD calculations [kWh/y/m²] are based on predefined occupants' schedules and comfort requirements and therefore they do not model properly the impact from set point management that adapt to changes in the user needs over its life time. Nevertheless, an SRI could consider this and attempt to model impact based on sensitivity analysis on these user parameters, *but up to our knowledge a data set for this is not available.*

5027 D.5.2. Examples of implementation of EPBD calculation methods at Member State level

5028 As mentioned before, the implementation of EPBD calculation methods is still very different per
 5029 Member State, more information can be found in the Book (EPBD, 2016) on ‘Implementing the
 5030 Energy Performance of Buildings Directive (EPBD) – Featuring Country Reports’. It reported that the
 5031 German transposition of the EPBD resulted in an exemplary all-in-one calculation method based on
 5032 a local standard series DIN V 18599, see figure D-4. DIN V 18599 has been an important source of
 5033 information for the development of European Standards.

5034
 5035 It should also be noted that not all Member States used a local standard to implement the calculation
 5036 methods. For example in France (RT2012, 2012), the EPBD is regulated within local decrees and limits
 5037 the maximum primary energy per year and m² together with a combination of other minimum
 5038 performance requirements to be calculated. Calculation software to prove compliance needs to be
 5039 purchased. This software needs to be validated before it is commercialised.

5040
 5041 Belgium, e.g. follows the same approach but the software is harmonized and openly available (PEB,
 5042 2011). These EPBD calculation methods already validate in some extend smart building controls; for
 5043 example in Flanders automatic solar shading, presence detection for lighting, demand controlled
 5044 ventilation, temperature control per room, etc.



5045

5046 *Figure E3 - Structure of German EPBD calculation standard DIN V 18599 Important EN product and/or smart*
 5047 *building system standards*

5048 D.5.3. Standards related to electrical installation

5049

5050 IEC 60364-8-1 ED2 Low-voltage electrical installations - Part 8-1: Energy efficiency

5051

5052 This standard introduces requirements and advices for the design or refurbishing of an electrical
 5053 installation with regards to electrical energy efficiency. It proposes a number of various
 5054 electrical energy efficiency measures in all low voltage electrical installations as given in the
 5055 scope of IEC 60364 from the origin of the installation including power supply, up to and
 5056 including current-using-equipment. Amongst others it describes methods to decrease losses in
 5057 electrical cables and transformers.

5058

5059

5060 **IEC 60364-8-2 ED2 Low-voltage electrical installations - Part 8-2: Prosumer Low-Voltage Electrical**
 5061 **Installations**

5062

5063 This standard is still under development. The standard provides additional requirements, measures
 5064 and recommendations for design, erection and verification of low voltage installations that include
 5065 local production and storage. The standard defines therefore how electrical installation
 5066 requirements should be conceived to be future proof, without infrastructure lock-in effects, could
 5067 be useful for an SRI to check preconditions for local production and storage (however to be
 5068 confirmed when the standard becomes available).

5069 **IEC PT 60364-8-3 Low-voltage electrical installation - Part 8-3: Evolutions of Electrical Installations**

5070

5071 This standard is still under development. This standard provides requirements and recommendations
 5072 to users and facility managers or similar of low-voltage electrical installations to operate their
 5073 electrical installations as Prosumer's Electrical Installation. These requirements and
 5074 recommendations cover safety and proper functioning.

5075

5076 **IEC TS 62950 ED1 "Household and similar electrical appliances - Specifying smart capabilities of**
 5077 **appliances and devices - General aspects"**

5078 This new standard is intended to develop the common architecture which applies widely to different
 5079 use cases and appliance types, and the principles of measuring smart performance within the context
 5080 of the common architecture. The standard is in the Draft Technical Specification (DTS) stage and is
 5081 expected to be published in September 2017. The focus of the standard is in smart capabilities for
 5082 interoperability with Smart Grids.

5083

5084 **IEC TS 62898-1:2017 on "Microgrids - Part 1: Guidelines for microgrid projects planning and**
 5085 **specification"**

5086 provides guidelines for microgrid projects planning and specification. Microgrids considered in this
 5087 document are alternating current (AC) electrical systems. This document covers the following
 5088 areas:

- 5089 - microgrid application, resource analysis, generation forecast, and load forecast;
- 5090 - DER planning and microgrid power system planning;
- 5091 - high level technical requirements for DER in microgrids, for microgrid connection to the
 5092 distribution system, and for control, protection and communication systems;
- 5093 - evaluation of microgrid projects.

5094

5095 **IEC 61727 Photovoltaic (PV) systems – Characteristics of the utility interface**

5096 This standard applies to utility-interconnected photovoltaic (PV) power systems operating in parallel
 5097 with the utility and utilizing static (solid-state) non-islanding inverters for the conversion of DC to AC.
 5098 This document describes specific recommendations for systems rated at 10 kVA or less, such as may
 5099 be utilized on individual residences single or three phases. This standard applies to interconnection
 5100 with the low-voltage utility distribution system.

5101

5102 **IEC 60364-7-712 Low-voltage electrical installations - Part 7-712: Requirements for special**
 5103 **installations or locations - Solar photovoltaic (PV) power supply systems.**

5104 This part of IEC 60364 applies to the electrical installation of PV systems intended to supply all or
 5105 part of an installation.

5106

5107 **IEC 61851-1:2017 on "Electric vehicle conductive charging system - Part 1: General requirements"**

5108 The aspects covered in this standard include:

- 5109 - the characteristics and operating conditions of the EV supply equipment;
5110 - the specification of the connection between the EV supply equipment and the EV;
5111 - the requirements for electrical safety for the EV supply equipment.

5112

5113 **IEC 60364-7-722:2015 on “Requirements for special installations or locations - Supplies for electric**
5114 **vehicles”**

5115 The standard applies to circuits intended to supply energy to electric vehicles,

5116 Amongst others it put additional requirements that has an impact in the electrical distribution board,
5117 protection devices and cabling within buildings to supply electrical vehicles. For example which and
5118 how Residual Current Devices that are needed.

5119

5120 **IEC 62933-1 Electrical Energy Storage (EES) systems - Part 3-1: Planning and installation- General**
5121 **specifications**

5122 This standard is still under development. This part of IEC 62933 is applicable to EES systems designed
5123 for grid connected indoor or outdoor installation and operation at a.c. or d.c. irrespective of voltage.

5124

D.5.4. Standards related to SRI equipment

5125 **EN ISO 16484 is a series of 5 standards related to Building automation and control systems (BACS)**

5126 The standard is regarding Building automation and control systems (BACS). It consists of 5 parts. ISO
5127 16484-1:2010 specifies guiding principles for project design and implementation and for the
5128 integration of other systems into the building automation and control systems (BACS). ISO 16484-
5129 2:2004 specifies the requirements for the hardware to perform the tasks within a building
5130 automation and control system (BACS). It provides the terms, definitions and abbreviations for the
5131 understanding of ISO 16484-2 and ISO 16484-3. ISO 16484-2:2004 relates only to physical
5132 items/devices, i.e. devices for management functions, operator stations and other human system
5133 interface devices; controllers, automation stations and application specific controllers; field devices
5134 and their interfaces; cabling and interconnection of devices; engineering and commissioning tools.
5135 ISO 16484-3:2005 specifies the requirements for the overall functionality and engineering services
5136 to achieve building automation and control systems. It defines terms, which shall be used for
5137 specifications and it gives guidelines for the functional documentation of project/application specific
5138 systems. It provides a sample template for documentation of plant/application specific functions,
5139 called BACS points list. ISO 16484-5:2007 defines data communication services and protocols for
5140 computer equipment used for monitoring and control of heating, ventilation, air-conditioning and
5141 refrigeration (HVAC&R) and other building systems. It defines, in addition, an abstract, object-
5142 oriented representation of information communicated between such equipment, thereby facilitating
5143 the application and use of digital control technology in buildings. ISO 16484-6:2009 defines a
5144 standard method for verifying that an implementation of the BACnet protocol provides each
5145 capability claimed in its Protocol Implementation Conformance Statement (PICS) in conformance
5146 with the BACnet standard.

5147

5148 **EN 12098** (parts 1, 3, 5) prepared under CEN/TC247/WG6 committee describe ability of devices and
5149 integrated functions to control heating systems. Associated draft Technical Reports CEN/TR 12098
5150 (parts 6, 7, 8) summarise some recommendations for how to design, how to use these functions for
5151 energy efficiency of heating systems. Energy impact of these control functions are detailed in EN
5152 15232-1.

5153 **D.5.5. CEN/TS 15810 (Technical Specification) specifies graphical symbols for use on integrated**
5154 **building automation equipment. At European Level (EN) related to construction works and products**
5155 **that bear the CE Marking**

5156 These are the so-called 'EN Eurocodes' which are a series of 10 European Standards, EN 1990 - EN
5157 1999, providing a common approach for the design of buildings and other civil engineering works
5158 and construction products. This standards might be relevant to check that the construction stability
5159 and fire safety preconditions to install photovoltaics, thermal or electrical storage to increase self-
5160 consumption of renewables. For example to install photovoltaics in a flat roof it needs to be able to
5161 withstand the additional loading, batteries might need fire safe building compartments, etc. .. and
5162 those standards could provide approaches to assess those capabilities. Of course, here again also
5163 local national standards can apply.

5164

ANNEX E – HYPE CYCLES TO ASSESS MATURITY OF SERVICES

5165 In order to choose the initial domains for integration in the catalogue and assess the maturity (TRL)
 5166 of the service levels, the latest versions of the Gartner Hype Cycles 2017 were taken into account.
 5167 Those hype cycles analyze form a view of the markets the expectations and shares of a technology
 5168 and highlight their future market share and define uncertainties. The hype cycle from Gartner is a
 5169 branded graphical presentation developed and used by the American research, advisory and
 5170 information technology firm Gartner, for representing the maturity, adoption and social application
 5171 of specific technologies. The hype cycle provides a graphical and conceptual presentation of the
 5172 maturity of emerging technologies through five phases. The phases are usually defined as follows:

5173 Each hype cycle drills down into the five key phases of a technology's life cycle.

No.	Phase	Description
1	Technology Trigger	A potential technology breakthrough kicks things off. Early proof-of-concept stories and media interest trigger significant publicity. Often no usable products exist and commercial viability is unproven. (TRL 1 and 2)
2	Peak of Inflated Expectations	Early publicity produces a number of success stories—often accompanied by scores of failures. Some companies take action; most don't. (TRL 3 to 5)
3	Trough of Disillusionment	Interest wanes as experiments and implementations fail to deliver. Producers of the technology shake out or fail. Investment continues only if the surviving providers improve their products to the satisfaction of early adopters. (TRL 6)
4	Slope of Enlightenment	More instances of how the technology can benefit the enterprise start to crystallize and become more widely understood. Second- and third-generation products appear from technology providers. More enterprises fund pilots; conservative companies remain cautious. (TRL 7)
5	Plateau of Productivity	Mainstream adoption starts to take off. Criteria for assessing provider viability are more clearly defined. The technology's broad market applicability and relevance are clearly paying off. (TRL 8)

5174

5175 A mapping onto the TRL levels, like they are used in the H2020 program, e.g. by the commission, is
 5176 possible:

Technology Readiness Level	Description
TRL 1.	basic principles observed
TRL 2.	technology concept formulated
TRL 3.	experimental proof of concept
TRL 4.	technology validated in lab
TRL 5.	technology validated in relevant environment (industrially relevant environment in the case of key enabling technologies)
TRL 6.	technology demonstrated in relevant environment (industrially relevant environment in the case of key enabling technologies)
TRL 7.	system prototype demonstration in operational environment

TRL 8.	system complete and qualified
TRL 9.	actual system proven in operational environment (competitive manufacturing in the case of key enabling technologies; or in space)

5177

5178

5179

5180

5181

5182

5183

5184

5185

5186

5187

As Gartner has a very wide and broad coverage of technologies for their individual hype cycles, we chose to use the following three current version to assess the future uptake and shares of technologies to the services. It has to be kept in mind that the hype cycles sometimes cover basic technologies and services build upon those technologies. This has been taken into account in the assessment.

The following three studies have been taken as basic assessment material according to the five phases of the hype cycle:

- Hype Cycle for Smart City Technologies and Solutions, 2017
- Hype Cycle for Internet of Things, 2017
- Hype Cycle for Connected Home, 2017

5188

5189

5190

5191

5192

5193

5194

5195

5196

5197

5198

5199

5200

5201

5202

5203

5204

5205

In addition, we addressed the suitability of this approach by looking into the individual dimensions and definitions of the terms covered in the hype cycle. It has to be kept in mind that the hype cycle does not perfectly fit to the concept of TRL (technology readiness level).

Technology readiness levels (TRL) are a method of estimating technology maturity of Critical Technology Elements (CTE) of a program during the acquisition process. They are determined during a Technology Readiness Assessment (TRA) that examines program concepts, technology requirements, and demonstrated technology capabilities. TRL are based on a scale from 1 to 9 with 9 being the most mature technology.

However, as during this task 1 phase a lot of technologies had to be assessed based on service and not technology level, the approach to take into account products like Gartner is proposing proved useful as it covered a broad variety of services in scope of this project.

According to Gartner, a connected home is networked to enable the interconnection and interoperability of multiple devices, services and apps, ranging from communications and entertainment to healthcare, security and home automation. These services and apps are delivered over multiple interlinked and integrated devices, sensors, tools and platforms. Connected, real-time, smart and contextual experiences are provided for the household inhabitants, and individuals are enabled to control and monitor the home remotely as well as within it.

5206

5207

5208

5209

5210

5211

5212

5213

5214

5215

5216

5217

5218

5219

5220

5221

The technologies behind the connected home can be grouped in the following categories according to Gartner (Source Gartner IT definitions) :

Networking: Familiar home networking technologies (high bandwidth/high power consumption), such as Multimedia over Coax Alliance (MoCA), Ethernet, Wi-Fi, Bluetooth, as well as 3G and Long Term Evolution (LTE), are complemented with low-power consumption networking standards for devices and sensors that require low bandwidth and consume very little power, such as thermostats.

Media and Entertainment: This category, which covers integrated entertainment systems within the household and includes accessing and sharing digital content across different devices, has proved to be the most prolific and contains some of the most mature technologies in the connected home.

Home Security/Monitoring and Home Automation: The technologies in this category cover a variety of services that focus on monitoring and protecting the home as well as the remote and automated control of doors, windows, blinds and locks, heating/air conditioning, lighting and home appliances, and more.

Energy Management: This category is tightly linked to smart cities and government initiatives, yet consumer services and devices/apps are being introduced at mass-market prices that allow people to track, control and monitor their gas/electricity consumption.

5222 **Healthcare, Fitness and Wellness:** Solutions and services around healthcare have proven slow to
5223 take off, because they have to be positioned within a health plan and sold to hospitals and health
5224 insurance companies. The fitness and wellness segment has strong and quickly developed
5225 ecosystems that range from devices to sports wares to apps, which integrate seamlessly with each
5226 other to create a strong customer experience.

5227

5228 The Gartner Hype Cycle for Smart City Technologies has the following Structure and classification for
5229 the year 2017:

5230

5231 On the Rise

- 5232 • Data Marketplace
- 5233 • City Operations Center
- 5234 • Civic and Community Development
- 5235 • Digital Ethics

5236 At the Peak

- 5237 • Digital Security
- 5238 • Sustainability and COP21
- 5239 • **Smart Monitoring for Public Infrastructures**
- 5240 • Greenfield Smart City Framework
- 5241 • **IoT Platform**
- 5242 • Blockchain in Government
- 5243 • Smart Parking Strategies
- 5244 • **Connected Home**
- 5245 • **Internet of Things**
- 5246 • LPWA
- 5247 • Smart City Framework
- 5248 • **Smart Transportation**

5249 Sliding Into the Trough

- 5250 • Water Management
- 5251 • Car-Sharing Services
- 5252 • **Building Controls and Management**
- 5253 • **Microgrids**
- 5254 • Vehicle-to-Vehicle Communications
- 5255 • **Distributed Generation**
- 5256 • **Smart Lighting**
- 5257 • Intelligent Lamppost
- 5258 • Big Data
- 5259 • **Health Information Exchange**

5260 In addition to this Hype Cycle on Smart Cities which already covered a lot of classifications relevant
5261 to this study (in **bold**), the sub study on Smart Home is of interest. When reading, it is obvious that
5262 connected home is, from the perspective of smart city, itself a topic and can be dealt with in more
5263 detail. Thus, this hype cycle covers much more variety in terms of basic services and technologies as
5264 well as phases.

5265

5266 On the Rise

- 5267 • Smart Dust
- 5268 • Microsupercapacitor Batteries
- 5269 • Midrange Wireless Power Charging
- 5270 • Smart Mirrors
- 5271 • **802.11ax**
- 5272 • Bluetooth 5
- 5273 • Chatbots
- 5274 • Pet Monitors
- 5275 • Bots
- 5276 • Robotic Vacuum Cleaner
- 5277 • **VPA-Enabled Wireless Speakers**

5278 At the Peak

- 5279 • Smart Robots
- 5280 • Gesture Control Devices
- 5281 • Virtual Assistants in Utilities
- 5282 • **Virtual Assistants**
- 5283 • **Connected Home**
- 5284 • **Home Automation**
- 5285 • LPWA
- 5286 • Personal Health-Tracking Devices
- 5287 • **Predictive Analytics**

5288 Sliding Into the Trough

- 5289 • **Home Energy Management**
- 5290 • **802.11ad**
- 5291 • **Consumer Smart Appliances**
- 5292 • 802.11ac Wave 2
- 5293 • Wearables
- 5294 • Customer Gateways
- 5295 • **Smart Locks**
- 5296 • **Smart Thermostats**
- 5297 • **Smart Lighting**
- 5298 • **Remote Medical Monitoring**

5299 Climbing the Slope

- 5300 • Home Wireless Music Systems
- 5301 • Personal Cloud
- 5302 • 802.15.4
- 5303 • **ZigBee**
- 5304 • **TV Companion Screen Apps**

5305 Entering the Plateau

- 5306 • **Connected TVs**

- 5307 • **OTT STBs**
- 5308 • Internet Video

5309 In addition, the aspect of IoT devices is of higher importance to the CRE buildings (commercial real
5310 estate). Therefore, the hype cycle for IoT has been used for the overall assessment process but has
5311 less importance to the SRI study than the other two which focus on the core technologies in the
5312 context of ICT in buildings.

5313

5314 On the Rise

- 5315 • Licensing and Entitlement Management
- 5316 • **IoT-Enabled Product as a Service**
- 5317 • **Infonomics**
- 5318 • Hardware Security
- 5319 • Digital Twin
- 5320 • **Managed IoT Services**
- 5321 • IoT Business Solutions
- 5322 • IoT Edge Analytics
- 5323 • Digital Ethics
- 5324 • IoT-Enabled ERP

5325 At the Peak

- 5326 • **IoT Security**
- 5327 • IoT Platform
- 5328 • IoT Services
- 5329 • IoT Edge Architecture
- 5330 • **Machine Learning**
- 5331 • Autonomous Vehicles
- 5332 • Event Stream Processing
- 5333 • Connected Car Platforms
- 5334 • **Internet of Things**
- 5335 • LPWA
- 5336 • Enterprise Information Management Programs

5337 Sliding Into the Trough

- 5338 • Low-Cost Development Boards
- 5339 • **Intelligent Building Automation Systems**
- 5340 • IoT Integration
- 5341 • **IT/OT Alignment**
- 5342 • **Managed Machine-to-Machine Services**
- 5343 • **Asset Performance Management**
- 5344 • **Smart Lighting**

5345 Climbing the Slope

- 5346 • **Cloud MOM Services (momPaaS)**
- 5347 • Message Queue Telemetry Transport
- 5348 • MDM of Product Data

5349 Based on those studies, expert consultation as well as the expertise of the team, the initial service
5350 catalogue was created and further refined during the process and stakeholder consultations.

5351

5352

5353

ANNEX F – REVIEW OF APPLICABILITY OF SERVICES FOR INCLUSION IN SRI

5354 This annex reviews the services and functionality levels in the Task 1 report and considers their ability
5355 to be applied in an operational SRI currently. For each service this considers:

- 5356 • the degree to which the functionality of the service is described and defined in standards,
5357 or is still nebulous and in need of definition
- 5358 • the basis by which the impacts associated with the functionality can be determined
- 5359 • the degree by which the impact can be ascribed to the functionality
- 5360 • the degree to which the functionality can be determined by inspection.

5361 The text below summarises the findings but the detailed service by service assessment is delivered
5362 in the form of an Excel table which accompanies this report.

5363 F.1. SERVICES WITHIN THE HEATING DOMAIN

5364

5365 The remaining Task 1 heating services are all specified in the standard EN15232:2017 with the
5366 exception of the services:

5367

- 5368 • Heating 1g – *Building preheating control*
- 5369 • Heating 2d - *Heat system control according to external signal (e.g. electricity tariff, gas*
5370 *pricing, load shedding signal etc.)*
- 5371 • Heating 2e - *Control of on-site waste heat recovery fed into the heating system (e.g. excess*
5372 *heat from data centers)*
- 5373 • Heating 3 - *Report information regarding heating system performance*

5374

5375 For all the services listed in EN15232 their functionality is clearly related to average impacts (for on-
5376 site energy consumption) based on numerous TRNSYS simulations and expressed via the BACS
5377 factors cited in the standard. Other impacts are based on the consortium team’s judgement and are
5378 not corroborated through standards.

5379

5380 All the remaining services have a high or medium impact on on-site energy use (reflecting significant
5381 savings opportunities associated with smart control) and the dominance of heating in most EU
5382 buildings (this observation is clearly climate sensitive).

5383

5384 An initial screening assessment process will be appropriate to determine which services might be
5385 eligible for inclusion and which dropped. If the dropped services do not bring specific smart benefits
5386 that the retained services cannot provide then this should certainly lead to their exclusion from any
5387 normalisation process; however, in some cases this may require some judgment by the scheme
5388 organisers. For example, use of heat pumps, if integrated into smart grid control, would bring grid-
5389 flexibility advantages compared to alternative heat sources but does this mean they should score
5390 better under an SRI than a building using non-electric based heating?

5391

5392 Some services such as Thermo-Active Building Systems (TABS) and Thermal Energy Storage (TES) are
5393 rare and hence will not currently feature in the vast majority of the building stock. Also sequencing

5394 of heat sources only becomes a control issue when more than one heat source is available. This is
 5395 usually only the case in large buildings and hence can be screened out of most assessments.

5396
 5397 The “inspectability” of the services varies with the lower level (less smart) services being more
 5398 straightforward to assess visually than some of the higher level services, which can be sensitive to
 5399 the nature of the control algorithms applied. A general observation, stretching across all the smart
 5400 readiness domains, is that when smartness depends on the capability associated with a control
 5401 algorithm that it will not be straightforward to assess. As a result many of the capabilities defined
 5402 here will need classification and indication, or some smart signalling and reading device, to enable
 5403 an inspector to assess their capability. Inspection can take place at the plant room except for the
 5404 heat emission inspection which requires a walk-through the building to be verified, however, as this
 5405 is one of the major potential sources of energy savings it is likely worth the effort.

5406 **F.2. SERVICES WITHIN THE DHW DOMAIN**

5407 All the DHW services except:

5408
 5409 *DHW-1c Control of DHW storage temperature, varying seasonally: with heat generation or integrated*
 5410 *electric heating*

5411
 5412 *DHW-3 Report information regarding domestic hot water performance*
 5413

5414 are supported by European standards. DHW 1c is not assessable through any standard. DHW 1a to
 5415 1d only pertain to storage water heater systems and hence are not applicable to combi-systems and
 5416 other instantaneous heating systems. It is a debatable point as to whether having storage capability
 5417 (which takes space and is associated with losses) should be advantaged within an SRI due to having
 5418 the potential for DSM storage or smart-charging control, or should be penalised due to the storage
 5419 losses (note the balance of distribution losses should also be factored into any holistic assessment).

5420
 5421 For all the services listed in EN15232 their functionality is clearly related to average impacts (for on-
 5422 site energy consumption) based on numerous TRNSYS simulations and expressed via the BACS
 5423 factors cited in the standard. Other impacts are based on the consortium team’s judgement and are
 5424 not corroborated through standards.

5425
 5426 Potentially the biggest DHW impact is associated with flexibility but this is addressed elsewhere.

5427
 5428 As is the case for heating many of the DHW smartness capabilities depend on the capabilities
 5429 associated with a control algorithm that it is not straightforward to assess. As a result many of the
 5430 capabilities defined here will need classification and indication, or some kind of smart signalling and
 5431 reading device, to enable an inspector to assess their capability.

5432
 5433 Inspection can take place at the plant room (or where the storage water heater and pumps are).

5434 **F.3. SERVICES WITHIN THE COOLING DOMAIN**

5435 The Cooling 1 and 2 services listed in the Task 1 catalogue presented in the first progress report are
 5436 not real services but are summaries of the sub-services listed under them. They can therefore be
 5437 ignored.

5438

5439 The remaining Task 1 cooling services are all specified in the standard EN15232:2017 except the
5440 newly introduced:

5441

5442 *Cooling-3 Report information regarding cooling system performance*

5443

5444 For all the services listed in EN15232 their functionality is clearly related to average impacts (for on-
5445 site energy consumption) based on numerous TRNSYS simulations and expressed via the BACS
5446 factors cited in the standard. Other impacts are based on the consortium team's judgement and are
5447 not corroborated through standards.

5448

5449 All the remaining services have a high or medium impact on on-site energy use (reflecting significant
5450 savings opportunities associated with smart control) and the dominance of heating in most EU
5451 buildings (this observation is clearly climate sensitive).

5452

5453 An initial screening assessment process will be appropriate to determine which services might be
5454 eligible for inclusion and which dropped. If the dropped services do not bring specific smart benefits
5455 that the retained services cannot provide then this should certainly lead to their exclusion from any
5456 normalisation process; however, in some cases this may require some judgment by the scheme
5457 organisers. For example, use of control of distribution network chilled water temperature (supply or
5458 return) (supplied by a central chiller(s)) and control of distribution pumps is one cooling strategy, but
5459 is not inherently smarter than using individual heat pumps, chilled beams or air-based central cooling
5460 systems; thus, non-relevant options need to be dropped from the assessment on a non-prejudicial
5461 basis.

5462

5463 Some services such as Thermo-Active Building Systems (TABS) and Thermal Energy Storage (TES) are
5464 rare and hence will not currently feature in the vast majority of the building stock. Also sequencing
5465 of different cooling generators only becomes an issue when more than one generator is available
5466 and operational within a centrally managed cooling system. This is usually only the case in some large
5467 buildings and hence can be screened out of most assessments.

5468

5469 The "inspectability" of the services varies with the lower level (less smart) services being more
5470 straightforward to assess visually than some of the higher level services, which can be sensitive to
5471 the nature of the control algorithms applied. A general observation, stretching across all the smart
5472 readiness domains, is that when smartness depends on the capability associated with a control
5473 algorithm that it will not be straightforward to assess. As a result many of the capabilities defined
5474 here will need classification and indication, or some smart signalling and reading device, to enable
5475 an inspector to assess their capability.

5476

5477 Inspection can take place at the plant room except for the heat emission inspection which requires
5478 a walk-through the building to be verified, however, as this is one of the major potential sources of
5479 energy savings it is likely worth the effort.

5480 **F.4. SERVICES WITHIN THE VENTILATION DOMAIN**

5481 The ventilation services in Task 1 are all based on EN15232 with the exception of the newly
5482 introduced service:

5483

5484 *Ventilation-6 Reporting information regarding IAQ*

5485

5486 For all the services listed in EN15232 their functionality is clearly related to average impacts (for on-
 5487 site energy consumption) based on numerous TRNSYS simulations and expressed via the BACS
 5488 factors cited in the standard. Other impacts are based on the consortium team's judgement and are
 5489 not corroborated through standards.

5490
 5491 The "inspectability" of the services varies with the lower level (less smart) services being more
 5492 straightforward to assess visually than some of the higher level services, which can be sensitive to
 5493 the nature of the control algorithms applied. A general observation, stretching across all the smart
 5494 readiness domains, is that when smartness depends on the capability associated with a control
 5495 algorithm that it will not be straightforward to assess. As a result many of the capabilities defined
 5496 here will need classification and indication, or some smart signalling and reading device, to enable
 5497 an inspector to assess their capability.

5498
 5499 Inspection can take place at the plant room for all centralised cooling systems.

5500 **F.5. SERVICES WITHIN THE LIGHTING DOMAIN**

5501 The lighting services in Task 1 are all based on EN15232 with the exception of Lighting 1b *Mood and*
 5502 *time based control of lighting in buildings* which is now revised to be based upon elements within EN
 5503 15393, CEN-TR 16791 and EN 12464.

5504
 5505 For all the services listed in EN15232 their functionality is clearly related to average impacts (for on-
 5506 site energy consumption) based on numerous TRNSYS simulations and expressed via the BACS
 5507 factors cited in the standard and this is the advantage of using the EN15232 simplified method in
 5508 place of the more accurate but much more time consuming assessment that would be possible via
 5509 EN15193 *Energy performance of buildings. Energy requirements for lighting*. Other impacts are based
 5510 on the consortium team's judgement and are not corroborated through standards.

5511
 5512 The "inspectability" of the services varies with the lower level (less smart) services being more
 5513 straightforward to assess than the higher level services, which can be sensitive to the nature of the
 5514 control algorithms applied. A general observation, stretching across all the smart readiness domains,
 5515 is that when smartness depends on the capability associated with a control algorithm that it will not
 5516 be straightforward to assess. As a result many of the capabilities defined here will need classification
 5517 and indication, or some smart signalling and reading device, to enable an inspector to assess their
 5518 capability.

5519
 5520 Inspection requires a walk through the building and in principle should apply some space-function
 5521 weighted process (i.e. to take account of the prevalence of different lighting solutions by room/floor-
 5522 area) to be verified; however, in the case of lighting this walk-through should provide an
 5523 unambiguous appraisal.

5524 **F.6. SERVICES WITHIN THE DYNAMIC BUILDING ENVELOPE DOMAIN**

5525 Of the three dynamic building envelope services cited in Task 1 only DE-1 *window solar shading*
 5526 *control* is based on an existing standard (EN15232) but even then it includes an additional
 5527 functionality level (*predictive blind control*). The other two services (*Window open/closed control,*
 5528 *combined with HVAC system* and *Changing window spectral properties*) are not supported by
 5529 standards. As a result only the DE-1 service has impacts that can be clearly attributed to functionality
 5530 levels whereas the remainder are unsubstantiated (though likely to be relevant in principle). This

5531 means they are less actionable currently. Nonetheless, DE-2 Window open/closed control, combined
5532 with HVAC system is important and probably more straightforward to inspect than the spectral
5533 properties service.

5534

5535 As with other services, blinds and hence dynamic blind control, are not present in all buildings. It is
5536 thus a moot point whether buildings without blinds should be considered less smart for not having
5537 an option to manage the blind control.

5538

5539 Inspection (at least for verification) requires a walk through the building and in principle should apply
5540 some space-function weighted process (i.e. to take account of the prevalence of different lighting
5541 solutions by room/floor-area) to be verified; however, this walk-through should provide an
5542 unambiguous appraisal.

5543 **F.7. SERVICES WITHIN THE ENERGY GENERATION DOMAIN**

5544 None of the five energy generation services cited in Task 1 are based on an existing standard or
5545 protocol and thus their functional levels are rather subjective and the relation between their
5546 functional levels and the impacts reported are unsubstantiated. Nonetheless, this is an important
5547 domain and thus it is necessary to identify relevant services to the extent they are actionable in
5548 practice.

5549

5550 It could be argued the first service EG-1 *On site renewable energy generation* is a simple
5551 quantification of the amount of RES available (or produced) and as such is not really “smart” at all.
5552 For that reason it is currently not included in the streamlined SRI method. From a policy perspective
5553 there might be a desire to encourage on site renewable energy generation, and therefore include
5554 this service nonetheless.

5555 Services EG-3 to EG-5 dealing with storage, optimisation and CHP control are also somewhat
5556 arbitrary and weakly attributed. It therefore seems evident that clearer standardisation is needed to
5557 support smart serviced classification in this domain. Nonetheless, the newly proposed EG-2 service
5558 on *Reporting information regarding energy generation*, while not being defined within any standard,
5559 would appear to be self-evident, highly relevant and follow a logical impact attribution.

5560

5561 As with many other services, RES is not present in all buildings and it is a moot point whether
5562 buildings without RES should be considered to be less smart for not having an option to manage RES.

5563

5564 Visual inspection is partly possible (e.g. presence of RES or storage) but quantification and
5565 assessment of control/communication/magnitude related capability may require additional support
5566 and facilitation.

5567 **F.8. SERVICES WITHIN THE DEMAND SIDE MANAGEMENT DOMAIN**

5568 None of the DSM services cited in Task 1 are based on an existing standard, except DSM-18 *Smart*
5569 *Grid Integration* and thus their functionality and functional levels are subjective while the relation
5570 between their functional levels and the impacts reported are unsubstantiated.

5571

5572 Grid flexibility is the principal benefit of DSM and the main reason why it would be/is encouraged
5573 and incentivised; however, not all buildings are equally equipped to provide flexibility due to the
5574 nature of the technical building systems they use (which may or may not be inherently controllable
5575 and utilisable for DSM-grid balancing purposes). It is thus a moot point whether a building that is less

5576 inherently able to store electrical energy is less “smart” than one that has higher inherent storage
5577 capability. What is less contestable is the degree to which the inherent storage capacity is “smart”
5578 enough to be able to provide DSM capability.

5579
5580 Most of services cited refer fully or in part to grid-balancing relevant capabilities, some focus on
5581 storage, some on communication and control, some on the level or scale of the service.

5582
5583 The lack of maturity in DSM service classification within Task 1 reflects the current absence of
5584 standards and common agreement on how to classify and attribute DSM capability. Nonetheless, the
5585 importance of the topic is such that 4 DSM services are proposed within the streamlined
5586 methodology with the expectation that they are actionable, even though they are not currently
5587 defined in standards or assessment protocols.

5588
5589 Visual inspection is only of limited value to verify DSM capability so quantification and assessment
5590 of control/communication/magnitude related capability will require additional support and
5591 facilitation.

5592 **F.9. SERVICES WITHIN THE ELECTRIC VEHICLE CHARGING DOMAIN**

5593 None of the fourteen EV services cited in Task 1 are directly based on an existing standard although
5594 many have some aspects of their functionality defined within either IEC 61851-1-2017 *Electric vehicle*
5595 *conductive charging system – Part 1: General requirements* (which has a simple but only partially
5596 applicable classification of EV charging-point modes) or ISO/IEC/DIS 15118E *Road vehicles – Vehicle*
5597 *to grid communication interface – Part 1: General information and use-case definition* (which
5598 addresses communication and control issues). However, as these standards are not really established
5599 to support smart charging and the services cited in Task 1 only partially relate to these then their
5600 functionality and functional levels are subjective while the relation between their functional levels
5601 and the impacts reported are unsubstantiated.

5602
5603 The principal benefits of smart e-mobility services are ease and speed of charging (which facilitates
5604 adoption of EVs in place of hydrocarbon vehicles and thereby saves energy – albeit not really on-site
5605 - GHG emissions and local air pollution emissions) and the extra-grid flexibility that EVs can offer
5606 (especially if charging off peak or if equipped with the ability to sell electricity back to the grid on
5607 peak). It is not evident that the catalogue of services cited in Task 1 capture these capabilities in a
5608 clear manner with the exception of the newly introduced EV-15, 16 and 17 services, which while in
5609 need of further work (e.g. to define what is meant by low, medium and high charging capacity) are
5610 otherwise relatively self-evident.

5611
5612 The lack of maturity in EV smart service classification within Task 1 reflects the current absence of
5613 standards and common agreement on how to classify and attribute this capability. The development
5614 of such standards should therefore be examined as a priority.

5615
5616 Visual inspection is only of limited value to verify EV smart service capability so quantification and
5617 assessment of control/communication/magnitude related capability will require additional support
5618 and facilitation. Many of the capabilities defined here would need classification and indication,
5619 perhaps complemented by some smart signalling and reading device, to enable an inspector to
5620 assess their capability.

5621 **F.10. SERVICES WITHIN THE MONITORING AND CONTROL DOMAIN**

5622 Several of the Task 1 monitoring and control domain services are specified in the standard
5623 EN15232:2017 and thus their impacts with regard to on-site energy use are readily attributable via
5624 the BACS factor methodology derived from extensive building simulation results.

5625

5626 The exceptions to this are:

5627

5628 *MC-2 Control of thermal exchanges*

5629 *MC-6 Reporting information regarding historical energy consumption*

5630 *MC-7 Reporting information regarding predicted energy consumption*

5631 *MC-9 Occupancy detection: connected services*

5632 *MC-10 Occupancy detection: space and activity*

5633 *MC-11 Remote surveillance of building behaviour*

5634 *MC-12 Central off-switch for appliances at home*

5635 *MC-13 Central reporting of TBS performance and energy use*

5636

5637 The impact of these other services are based on the consortium team's judgement and are not
5638 corroborated through standards. Monitoring and control smart services have a significant user
5639 information impact and can all be assessed at the central control point or points within a building or
5640 on associated mobile devices. Screening for which services are present and which not is often not
5641 possible by a quick visual scan but requires working with the control devices (especially the display
5642 devices) and associated documentation/facilitating information.

5643

5644 As a result many of the capabilities defined here would need classification and indication, or some
5645 smart signalling and reading capability, to enable an inspector to make an assessment.

5646

5647

ANNEX G - AN ACTIONABLE SUBSET OF SMART READINESS ELEMENTS

5648 This annex provides an extract from the Task 1 smart ready services catalogue which is currently
 5649 deemed actionable for inclusion in the SRI methodology.

5650

5651

5652

Table 38 - Excerpt of the smart ready services catalogue

Domain	Code	Smart ready service
Heating	Heating-1a	Heat control - demand side
Heating	Heating-1b	Heat control - demand side
Heating	Heating-1c	Heat control - demand side
Heating	Heating-1d	Heat control - demand side
Heating	Heating-1e	Heat control - demand side
Heating	Heating-1f	Heat control - demand side
Heating	Heating-1g	Heat control - demand side
Heating	Heating-2a	Control heat production facilities
Heating	Heating-2b	Control heat production facilities
Heating	Heating-2c	Control heat production facilities
Heating	Heating-3	Information to occupants and facility managers
Domestic hot water	DHW-1a	Control DHW production facilities
Domestic hot water	DHW-1b	Control DHW production facilities
Domestic hot water	DHW-1d	Control DHW production facilities
Domestic hot water	DHW-3	Information to occupants and facility managers
Cooling	Cooling-1a	Cooling control - demand side
Cooling	Cooling-1b	Cooling control - demand side
Cooling	Cooling-1c	Cooling control - demand side
Cooling	Cooling-1d	Cooling control - demand side
Cooling	Cooling-1e	Cooling control - demand side
Cooling	Cooling-1f	Cooling control - demand side
Cooling	Cooling-1g	Cooling control - demand side
Cooling	Cooling-2a	Control cooling production facilities
Cooling	Cooling-2b	Control cooling production facilities
Cooling	Cooling-3	Information to occupants and facility managers
Controlled ventilation	Ventilation-1a	Air flow control
Controlled ventilation	Ventilation-1b	Air flow control
Controlled ventilation	Ventilation-1c	Air flow control
Controlled ventilation	Ventilation-2a	Air temperature control
Controlled ventilation	Ventilation-2c	Air temperature control
Controlled ventilation	Ventilation-2d	Air temperature control
Controlled ventilation	Ventilation-3	Free cooling

Controlled ventilation	Ventilation-6	Feedback - Reporting information
Lighting	Lighting-1a	Artificial lighting control
Lighting	Lighting-2	Control artificial lighting power based on daylight levels
Dynamic building envelope	DE-1	Window control
Dynamic building envelope	DE-2	Window control
Energy generation	EG-2	Feedback - Reporting information
Energy generation	EG-3	DER - Storage
Energy generation	EG-4	DER- Optimization
Energy generation	EG-5	DER - Generation Control
Demand side management	DSM-18	Smart Grid Integration
Demand side management	DSM-19	DSM control of equipment
Demand side management	DSM-21	Feedback - Reporting information
Demand side management	DSM-22	Override control
Electric vehicle charging	EV-15	EV Charging
Electric vehicle charging	EV-16	EV Charging - Grid
Electric vehicle charging	EV-17	EV Charging - connectivity
Monitoring and control	MC-3	HVAC interaction control
Monitoring and control	MC-4	Fault detection
Monitoring and control	MC-9	TBS interaction control
Monitoring and control	MC-13	Feedback - Reporting information

5653

5654

5655

ANNEX H - THE BUILT-ENVIRONMENT-ANALYSIS-MODEL BEAM²

5656 This section gives an overview on the methodology used for the ex-ante assessment of policy option,
5657 which is the BEAM² model.

5658 H.1. TERMS AND DEFINITIONS

5659 As the **Built Environment Analysis Model BEAM²** model is set up in the framework of the European
5660 Energy Performance of Buildings Directive (EPBD), the general terms and definitions are aligned with
5661 it. The relevant document in that context is the umbrella document for all European standards within
5662 the EPBD, which is the Technical Report (TR): Explanation of the general relationship between various
5663 CEN standards and the Energy Performance of Buildings Directive (EPBD), see (CEN/TR 15615)⁶⁹. They
5664 are also valid for the energy demand calculations for space heating and cooling from (DIN EN ISO
5665 13790)⁷⁰, which are also referred to.
5666

5667 H.2. SCOPE

5668 The scope of the model is described in this section. General references for the energy-related
5669 calculations are (CEN/TR 15615) and report by Boermans et al.⁷¹.

5670
5671 The calculation methodology follows the framework set out in the Annex to the EPBD. For useful
5672 heating and cooling demand calculations the methodology in EN ISO 13790 (DIN EN ISO 13790)
5673 allows a simplified monthly calculation based on building characteristics. It is not dependent on
5674 heating and cooling equipment (except heat recovery) and results in the heating energy that is
5675 required to maintain the temperature level of the building. It can either be provided by the
5676 heating/cooling system or be recovered from the exhaust air stream. The calculations are based on
5677 specified boundary conditions of indoor climate and external climate, which are also given on
5678 monthly basis. Furthermore information on the internal and solar heat gains as well as transmission
5679 and ventilation heat losses are required. Based that energy demand the delivered energy (final
5680 energy) for heating, cooling, hot water, ventilation and lighting if applicable are calculated per fuel
5681 type. It takes account of heat emission, distribution, storage and generation and includes the
5682 auxiliary energy demand from building-related components like fans and pumps.
5683


5684 In a last step the overall energy performance in terms of primary energy and CO₂ emissions is
5685 calculated. An overview of the calculation process is given in Figure 32, based on the umbrella
5686 document (CEN/TR 15615). It involves following the energy flows from the left to the right.
5687

⁶⁹ CEN/TR 15615. Technical Report - Explanation of the general relationship between various European standards and the Energy Performance of Buildings Directive (EPBD) - Umbrella Document, CEN April 2008 (English).

⁷⁰ DIN EN ISO 13790. Energy performance of buildings - Calculation of energy use for space heating and cooling (ISO 13790:2008), Beuth Verlag Berlin 1999 (German version EN ISO 13790:2008).

⁷¹ Boermans, Thomas, Kjell Bettgenhäuser, Andreas Hermelink, and Sven Schimschar. May 2011. Cost optimal building performance requirements - Calculation methodology for reporting on national energy performance requirements on the basis of cost optimality within the framework of the EPBD, Final Report, European Council for an Energy Efficient Economy eceee, Stockholm (English).

5688 The three steps of the energy performance calculation are always done for reference buildings for a
 5689 sector, age group, retrofit level and HVAC systems. Subsequently the energy costs per year and the
 5690 investment costs in case of a new buildings or retrofit are calculated.
 5691



5692

5693 *Figure 32: Schematic Illustration of the scope for the newly developed Built-Environment-Analysis-Model*
 5694 *BEAM2, Source:(CEN/TR 15615)⁷²*

5695 **Key for Figure 32**

- 5696 (1) represents the energy needed to fulfil the users requirements for heating, cooling, lighting etc, according to levels that are
 5697 specified for the purposes of the calculation.
 5698 (2) represents the "natural" energy gains - passive solar heating, passive cooling, natural ventilation, daylighting "U together with
 5699 internal gains (occupants, lighting, electrical equipment, etc)
 5700 (3) represents the building's energy needs, obtained from (1) and (2) along with the characteristics of the building itself.
 5701 (4) represents the delivered energy, recorded separately for each energy carrier and inclusive of auxiliary energy, used by space
 5702 heating, cooling, ventilation, domestic hot water and lighting systems, taking into account renewable energy sources and co-
 5703 generation. This may be expressed in energy units or in units of the energy ware (kg, m3, kWh, etc).
 5704 (5) represents renewable energy produced on the building premises.
 5705 (6) represents generated energy, produced on the premises and exported to the market; this can include part of (5).
 5706 (7) represents the primary energy usage or the CO2 emissions associated with the building.
 5707
 5708
 5709

⁷² The figure is a schematic illustration and is not intended to cover all possible combinations of energy supply, on-site energy production and energy use. For example, a ground-source heat pump uses both electricity and renewable energy from the ground; and electricity generated on site by photovoltaic could be used entirely within the building, or it could be exported entirely, or a combination of the two. Renewable energy wares like biomass are included in [7], but are distinguished from non-renewable energy wares by low CO2 emissions. In the case of cooling, the direction of energy flow is from the building to the system.

5710 H.3. STRUCTURE AND METHODOLOGY

5711 The basic model setup and calculation process is shown in Figure 33. It is based on the energy
5712 demand calculations for space heating and cooling from the ISO Standard 13790:2008 (DIN EN ISO
5713 13790). As all calculations are executed for a highly disaggregated building stock with all its
5714 characteristics, the following description of the methodology and calculation process applies for all
5715 sub-segments of the building sector within the model.

5716
5717 Basic input to the model are data on the building stock such as building types, floor area, age groups,
5718 retrofit levels, HVAC systems in stock and population. Furthermore the climate data such as
5719 temperature and irradiation is required. Based on this data a status-quo inventory of the building
5720 stock can be constructed.

5721
5722 For the scenario analysis as central part of the model, additional input data with respect to
5723 population forecast, GDP development, new building, demolition and retrofit activities, thermal
5724 insulation standards, heating, ventilation and air conditioning equipment, renewable energy systems
5725 and energy efficiency measures is required. Furthermore energy costs, cost for energy efficiency
5726 measures at the building envelope and costs for heating, cooling and ventilation systems and
5727 renewable energy systems together with increase rates and discount rates are processed. With
5728 respect to the overall energy performance the greenhouse gas emissions factors and primary energy
5729 factors are required per fuel type and embodied energy and GHG emissions for energy efficiency and
5730 HVAC systems.

5731
5732 The calculation process over the scenario time frame is organized as follows. Based on the initial
5733 floor area distribution along the reference buildings (RB), age groups (AG), retrofit levels (RL), heating
5734 systems (HS)⁷³, hot water systems (DHW)⁷⁴ and cooling systems (CS) a forecast for the floor area is
5735 done taking into account new building, demolition and retrofit programs for all or parts of these
5736 combinations.

5737
5738 All activities in year i have an effect starting in year $i+1$.
5739 The useful energy demand for heating and cooling is derived from an integrated calculation
5740 algorithm based on (DIN EN ISO 13790). The energy demands for hot water, auxiliary energy and
5741 electrical appliances if applicable are also derived. The final energy is calculated based on the
5742 parameters of the HVAC systems⁷⁵. The aggregated final energy for heating can be compared to top-
5743 down data. In this case a calibration factor is calculated, which can be applied to the final energy for
5744 heating.


5745
5746 The delivered energy together with the primary energy and GHG emission factors are combined to
5747 the overall primary energy and GHG emissions. For the economic assessment heating and cooling
5748 loads per single building type are derived, which are relevant to the systems sizes and investment
5749 costs. The economic evaluation takes beside the investment costs also the energy costs into
5750 consideration. In addition to the above described output the embodied energy and primary energy
5751 for all energy-related components (efficiency and HVAC systems) are quantified in the model based
5752 on the total volumes of insulation, area of windows and number and power of HVAC equipment.

5753

⁷³ Heating systems (HS) also include ventilation systems (VS) and solar thermal systems (STS) for HS support if applicable.

⁷⁴ Hot water systems (DHW) also include solar thermal systems (STS) for hot water if applicable.

⁷⁵ The final energy is equal to the delivered energy plus energy produced in or on the building by solar or wind systems.



5754

5755

Figure 33: General Structure of the Built-Environment-Analysis-Model BEAM

5756
5757

5758 **H.4. SCENARIO RESULTS**

5759 Main outputs of the model are the floor area developments for RB, AG, RL, HS, DHW and CS in the
5760 first place. Next step is the calculation of the useful energy demands for heating, cooling and hot
5761 water. From this the final energy/ delivered energy for heating, cooling, hot water, ventilation and
5762 auxiliary energy is derived. For the overall energy performance the greenhouse gas emissions and
5763 primary energy is being calculated. Furthermore the embodied primary energy and greenhouse gas
5764 emissions of the energy related components for new buildings and retrofits are considered.

5765
5766 For the economic evaluation energy costs per year are provided as well as investment costs in new
5767 buildings and retrofits. In order to compare yearly costs the investments are broken down along the
5768 lifetime of components to yearly costs by use of annuities.

5769 All results are given in specific units (e.g. per m²) and for the overall building stock in the respective
5770 scenario.

5771 **H.5. INPUT DATA**

5772 Input data to the model describes the current building stock as status-quo. This is e.g. the floor area
5773 distribution and the definition and specifications of reference buildings (RB), age groups (AG), retrofit
5774 levels (RL) and HVAC systems such as heating (HS), hot water (DHW), solar thermal systems (STS),
5775 ventilation systems (VS) and cooling systems (CS).

5776
5777 A more detailed description of the BEAM² model is available in the dissertation by Bettgenhaeuser⁷⁶.

⁷⁶ Bettgenhäuser, K. (2013). Integrated Assessment Modelling for Building Stocks - A Technical, Economical and Ecological Analysis. Dissertation TU Darmstadt D17, Ingenieurwissenschaftlicher Verlag 2013.

5778 ANNEX I – BUILDING SECTOR SCENARIOS – ASSUMPTIONS AND DETAILED RESULTS

5779 I.1. PATHWAY DEFINITIONS AND PARAMETERS

5780 This section describes the main set of parameters for the underlying building sector scenarios. As
 5781 described above, the values are derived from a comparison of the set of parameters that has been
 5782 used for the EPBD Impact Assessment. Details and more parameters are shown in ANNEX I – Building
 5783 sector Scenarios – Assumptions and detailed results.

5784
 5785

5786 I.1.1. BUILDING SECTOR SCENARIO PARAMETERS - AGREED AMENDMENTS PATHWAY

5787 Based on the EPBD IA parameter dataset and the adaptations, the following main parameters are
 5788 defined:

5789

- 5790 • Thermal qualities
 - 5791 ○ New buildings:
 - 5792 ▪ 2017-2020: Cost optimal U-values according to MS reports
 - 5793 ▪ 2021-2025: introduction of NZEBs (approx. 12.5 % improvement)
 - 5794 ▪ 2026-2030: 7.5% improvement due to new cost optimality values
 - 5795 ○ Existing buildings that undergo thermal renovation:
 - 5796 ▪ 2018-2025: Cost optimal U-values from MS reports
 - 5797 ▪ 2023-2027: 5 % improvement⁷⁷ compared to 2018-2022
 - 5798 ▪ 2028-2030: 5 % improvement⁷⁸ compared to 2023-2027
- 5799 • Retrofit rates (equivalent full thermal renovation rate⁷⁹)
 - 5800 ○ Residential:
 - 5801 ▪ Up to 2025: 0.56-1.22%
 - 5802 ▪ 2026-2050: 1.29-1.4%
 - 5803 ○ Non-residential:
 - 5804 ▪ Up to 2025: 0.65-1.32%
 - 5805 ▪ 2026-2050: 1.36-1.50%
- 5806 • New Building rates

5807

5808

5809

5810

5811

⁷⁷ update cost optimality calculations, average improvement 2020-2030

⁷⁸ update cost optimality calculations, average improvement 2020-2030

⁷⁹ The full thermal renovation rate reflects the amount of buildings that undergo a renovation and upgrade of the total building envelope (roof, external walls, windows and ground floor) developed as an equivalent rate of renovations that include all or only parts of these different components. The full thermal renovation rate is therefore an indicator that describes the number and scope of renovations of the building envelope, while not describing the ambition level (e.g. thickness of insulation) of the single measures.

5812

Table 39: New building rates in the "Agreed Amendments" pathway

5813

Sector	Period	North	West	North-East	South	South-East
Residential	Up to	1.02-	0.66-	1.01-	0.69-	0.39-0.33%
	2025	1.06%	0.59%	0.62%	0.57%	
	2026-2050	1.07-	0.58-	0.57-	0.56-	0.33-0.30%
		1.09%	0.54%	0.38%	0.50%	
Non-Residential	Up to	1.23-	0.90-	1.44-	0.97-	0.74-0.68%
	2025	1.29%	0.80%	1.02%	0.85%	
	2026-2050	1.30-	0.79-	0.96-	0.83-	0.67-0.64%
		1.33%	0.75%	0.75%	0.78%	

5814

5815

- Demolition rates

5816

- Residential: 0.1%

5817

- Non-Residential: 0.2%

5818

1.1.2. 1.1.2 BUILDING SECTOR SCENARIO PARAMETERS – AGREED AMENDMENTS + AMBITIOUS IMPLEMENTATION PATHWAY

5819

Scenario "Agreed Amendments + Ambitious Implementation" will follow later, but will be part of the presentation during the stakeholder meeting.

5820

5821

The main difference to the above described "Agreed Amendments" pathway is in average an earlier adaption of high energy efficiency standards for the building shells, especially for the renovation of buildings and higher shares of renewable heating systems.

5822

5823

5824

5825

5826

1.2. DETAILED MODEL INPUTS

5827

5828

1.2.1. AGREED AMENDMENTS TO THE EPBD

5829

The following Table 40 gives an overview of the agreed amendments to the EPBD, based on the communication of 2018-01-25.

5830

5831

5832

Table 40: Overview of Agreed Amendments of the EPBD Trialogue Process

EPBD Amendments (2018-01-25)	
Art.	Content
2	Clarification on Definitions
2A	NEW: Long-term renovation strategy (from EED) <ul style="list-style-type: none"> - Roadmap with policies and actions - Mobilization of investments - Public consultation
6	New Buildings <ul style="list-style-type: none"> - List with high efficient alternative systems (to be considered) removed

7	Existing Buildings <ul style="list-style-type: none"> - Minor additions (health and indoor climate)
8	Technical Building systems <ul style="list-style-type: none"> - Minor additions (self-regulating devices) - EV charging points (at least one in five) for more than 10 parking spaces (if car park in the building or physically adjacent) for N-RES and ducting infrastructure only for RES buildings <ul style="list-style-type: none"> o Not mandatory for small/ medium enterprises o limiting factors (i.e. costs) - EPCs: Energy performance need to be assessed when technical building systems are installed/replaced - SRI: Optimal EU-wide scheme for rating the smart readiness of buildings => NEW Annex Ia
10	Financial Incentives <ul style="list-style-type: none"> - More details on how financial incentives shall be linked to energy performance improvements - EPCs database shall gather data
14	Inspection of Heating systems <ul style="list-style-type: none"> - Threshold for regular inspections moved from 20kW to 70 kW - Alternative measures with equivalent impact still allowed - N-RES: BACS mandatory from systems >290kW from 2025 onwards - RES: Voluntary introduction of electronic monitoring
15	Inspection of AirCon systems <ul style="list-style-type: none"> - Threshold for regular inspections moved from 12kW to 70 kW - Alternative measures with equivalent impact still allowed - N-RES: BACS mandatory from systems >290kW from 2025 onwards - RES: Voluntary introduction of electronic monitoring
19	Review <ul style="list-style-type: none"> - District: Spatial context instead of single building introduced
20	Information <ul style="list-style-type: none"> - MS duty to information owners and tenants rephrased
23-26	Admin
Annex I	Calculation of energy performance <ul style="list-style-type: none"> - The “energy performance” indicator has been removed (addressing the efficiency of the building shell), on Primary Energy required
Annex Ia	NEW: Smart Readiness of buildings <ul style="list-style-type: none"> - The EC shall develop a methodology for the SRI that takes the following points into account: <ul style="list-style-type: none"> o Maintain energy efficiency performance o Adapt to the needs of the occupant o Flexibility in relation to the grid

5833

5834 1.2.2. ADJUSTMENTS TO THE EPBD IA PARAMETERS

5835 Based on the list of agreed amendments to the EPBD from above, this section gives an overview of
5836 how the new policy setup in the EPBD would correlate with the “*Option II: Enhanced implementation,*
5837 *including targeted amendments for strengthening of current provisions*” scenario from the EPBD
5838 Impact Assessment and how the underlying parameter dataset needs to be adapted.
5839

5840 We propose to take the “*Option II: Enhanced implementation, including targeted amendments for*
 5841 *strengthening of current provisions*” as a starting parameter set for the BAU building sector scenarios,
 5842 as it is to a large extent in line with the agreed amendments of the EPBD from the Trialogue Process.
 5843 To fully align the scenario assumptions with the agreed amendments, we propose to adjust the
 5844 following parameters:

- 5845 - Renovation quality (building shell)
- 5846 - Renovation rate
- 5847 - Improvement/ replacement rates of TBS (heating, cooling)
- 5848 - Heating system implementation mix

5849
 5850 The following four scenarios were defined in the framework of the EPBD-IA, see Table 41.
 5851
 5852

5853 *Table 41: Overview of NEW policy options and corresponding measures⁸⁰*

Option 0: No-change option	
0B.	Continuation of the energy efficiency obligation scheme after 2020
0C.	Project development assistance
0D.	Continuation of the cohesion policy funds post-2020 (Baseline)
0F.	Building related products under eco-design and energy labelling
0G.	Horizon 2020 post 2020
Option I: Enhanced implementation and soft law, including clarification and simplification of the current Directive	
6A	Guidance on EED Article 4
3A	Guidance for clarification of the current provisions on calculation methodologies
5A	Additional supporting guidance on implementation of cost-optimal levels of minimum performance requirements
Option II: Enhanced implementation, including targeted amendments for strengthening of current provisions	
6B	Long term target set by Member states
3B	Increase the transparency and comparability of energy performance calculation methodologies
4A	Improved EPC quality and data availability
2A	Initial commissioning of new/upgraded technical buildings systems
2B	Continuous commissioning of technical building systems in non-residential buildings
2C	Continuous commissioning of technical building systems in apartment buildings with central heating and/or air conditioning systems
8A	Long term renovation plans
8B	Link between public financing and renovation depth
8C	Disclosure of actual energy consumptions
Option III: Enhanced implementation and increased harmonization, while introducing substantial changes	
3C	Full harmonisation of energy performance calculation methodologies
5B	Include the co-benefits that flow from improved energy performance in the cost-optimal framework methodology
7C	Beyond nearly zero-energy buildings
4B	Self-pre-assessment platform for residential building units
Additional measure	
0E.	Reinforced policy funds post-2020

⁸⁰ Source: “Ex-ante evaluation and assessment of policy options for the EPBD - Final report”, Ecofys for DG-ENER, April 2016

5854
5855
5856
5857
5858
5859

A detailed comparison of the EPBA-IA scenario “*Option II: Enhanced implementation, including targeted amendments for strengthening of current provisions*” with the list of Agreed Amendments to the EPBD from above shows the following match:

5860 *Table 42: Comparison of EPBD Agreed Amendments with corresponding measures in the EPBD IA 2016*

EPBD Agreed Amendments	Corresponding measure in EPBD IA 2016
2: Clarification on Definitions	3A: Guidance for clarification of the current provisions on calculation methodologies
2A: NEW: Long-term renovation strategy (from EED)	8A: Long term renovation plans 6A: Guidance on EED Article 4
<ul style="list-style-type: none"> - Roadmap with policies and actions - Mobilization of investments - Public consultation 	
6: New Buildings	No direct impact
<ul style="list-style-type: none"> - List with high efficient alternative systems (to be considered) removed 	
7: Existing Buildings	Little direct impact, does refer to
<ul style="list-style-type: none"> - Minor additions (health and indoor climate) 	5B: Include the co-benefits that flow from improved energy performance in the cost-optimal framework methodology
8: Technical Building systems	4A: Improved EPC quality and data availability
<ul style="list-style-type: none"> - Minor additions (self-regulating devices) - EV charging points (at least one in five) for more than 10 parking spaces (if car park in the building or physically adjacent) for N-RES and ducting infrastructure only for RES buildings <ul style="list-style-type: none"> o Not mandatory for small/ medium enterprises o limiting factors (i.e. costs) - EPCs: Energy performance need to be assessed when technical building systems are installed/replaced 	2A: Initial commissioning of new/upgraded technical buildings systems 2B: Continuous commissioning of technical building systems in non-residential buildings 2C: Continuous commissioning of technical building systems in apartment buildings with central heating and/or air conditioning systems
SRI: Optimal EU-wide scheme for rating the smart readiness of buildings => NEW Annex Ia	<ul style="list-style-type: none"> - SRI to a large extend covered by TBS measues - Charging points not covered by EPBD IA
10: Financial Incentives	Does refer partly to
<ul style="list-style-type: none"> - More details on how financial incentives shall be linked to energy performance improvements - EPCs database shall gather data 	8B: Link between public financing and renovation depth
14: Inspection of Heating systems	2B: Continuous commissioning of technical building systems in non-residential buildings 2C: Continuous commissioning of technical building systems in apartment buildings with central heating and/or air conditioning systems
<ul style="list-style-type: none"> - Threshold for regular inspections moved from 20kW to 70 kW - Alternative measures with equivalent impact still allowed - N-RES: BACS mandatory from systems >290kW from 2025 onwards - RES: Voluntary introduction of electronic monitoring 	

15: Inspection of AirCon systems

- Threshold for regular inspections moved from 12kW to 70 kW
- Alternative measures with equivalent impact still allowed
- N-RES: BACS mandatory from systems >290kW from 2025 onwards
- RES: Voluntary introduction of electronic monitoring

19: Review

- District: Spatial context instead of single building introduced

Does partly refer to 7C: Beyond nearly zero-energy buildings

20: Information

- MS duty to inform owners and tenants rephrased

Does partly refer to 3A: Guidance for clarification of the current provisions on calculation methodologies

Annex I: Calculation of energy performance

- The “energy performance” indicator has been removed (addressing the efficiency of the building shell), on Primary Energy required

Does partly refer to 3B: Increase the transparency and comparability of energy performance calculation methodologies

Annex Ia: NEW: Smart Readiness of buildings

- The EC shall develop a methodology for the SRI that takes the following points into account:
 - o Maintain energy efficiency performance
 - o Adapt to the needs of the occupant
 - o Flexibility in relation to the grid

- Not covered

5861
5862
5863
5864
5865
5866

As a result of the comparison, the following policy options from the Option II (including Option I) for the EPBD IA are **NOT covered** by the Agreed Amendments of the EPBD:

5867

Table 43: Policy options of the EPBD IA that are not covered by the Agreed Amendments to the EPBD

- 5A Additional supporting guidance on implementation of cost-optimal levels of minimum performance requirements
- 6B Long term target set by Member states
- 8C Disclosure of actual energy consumptions

5868
5869
5870

→ Option 5A refers to 3a (66%) of original policies

Option 3a:	All	stock/	Earlier	Retrofit	
Accelerate	buildi	new	implem	Full thermal renovation	
the	ngs	bldgs.	entation	rate:	No effect
implementa			of CO	HVAC system exchange	
tion of cost			values	rate:	No effect

optimal levels	in comparison to S1	Quality building envelope: Apply CO levels for existing buildings from MS reports in 2017 instead of 2018, and 5% improvement in 2021 instead of 2023 and again	HVAC systems: New buildings 5% improvement in 2026 instead of 2028
		Quality building envelope: Small effect (included in system mix development)	HVAC systems: No effect for new buildings Small effect (included in system mix development)

5871

5872

5873 → 6B Long term targets set by MS (8A) → Effect assessed at 2/3 of effect attributed to option 8A

5874 (long term renovation plans) → Option 8A refers to 3b (100%) of original policies

Option 3b: Increase rate of renovation by promoting voluntary long-term renovation plan linked to financing schemes	All buildings	Stock	Higher renovation rate	Retrofit Full thermal renovation rate: 0.15% increase HVAC system exchange rate: 0.05% increase
				Quality building envelope: No effect HVAC systems: No effect New buildings
				Quality building envelope: No effect HVAC systems: No effect

5875

5876

5877

5878 → Option 8C refers to 4d (100%) of original policies

Option 4d: Voluntary Disclosure of Operational Energy Consumption in public buildings	Binding for public buildings,	stock	Increase of renovation rate. Higher quality of building envelope retrofit	Retrofit Full thermal renovation rate: 0.05% increase HVAC system exchange rate: 0.02% increase Quality building envelope: Small effect (10% of bldgs. perform 10% better than CO levels = 1% increase of ambition level) HVAC systems: No effect New buildings Quality building envelope: No effect HVAC systems: No effect
---	-------------------------------	-------	--	--

5879

5880
5881
5882
5883
5884

In **addition we have partly covered** the following policies from the Option III by the Agreed Amendments of the EPBD

5885

Table 44: Policy options of the EPBD IA that are additional to the Agreed Amendments to the EPBD

- 5B Include the co-benefits that flow from improved energy performance in the cost-optimal framework methodology
- 7C Beyond nearly zero-energy buildings

5886
5887
5888

→ Option 5B refers to 3C (100%) of original policies

	All stock/ buildings	new bldgs.	Retrofit	
Option 3c: Set ambitious requirements for new and existing buildings by 2030 and 2050 (beyond cost-optimal)			Full thermal renovation rate:	No effect
			HVAC system exchange rate:	No effect
			Quality building envelope:	10% improvement of Cost-optimal levels from 2021 for new bldgs. and renovations due to including co-benefits
			HVAC systems:	Use of higher performing systems
			New buildings	(effect included in system mix development)
			Quality building envelope:	No effect
			HVAC systems:	No effect

5889
5890
5891
5892
5893
5894
5895
5896

→ Option 7C: Effect assessed at 20% of effect attributed to option 5B (Include the co-benefits that flow from improved energy performance in the cost-optimal framework methodology) → Option refers to 3C (100%) of original policies.

5897
5898
5899

As a **summary** of the comparison from above the adaption of the parameter dataset of “*Option II: Enhanced implementation, including targeted amendments for strengthening of current provisions*” is as follows:

5900

Retrofit parameters:

5901
5902
5903
5904
5905
5906
5907
5908
5909
5910

- **Full thermal renovation rate:** $-2/3 * 0,15\% - 0,05\% \rightarrow -0,15\%$
- **HVAC system exchange rate:** $-2/3 * 0,05\% - 0,02\% \rightarrow -0,05\%$
- **Quality building envelope:** not included: cost optimal levels two years earlier (2021 instead of 2023 and 2026 instead of 2028), 1% increase of ambition level of CO₂; in addition: CO levels 10% better from 2021 onwards (120% of this effect), → **10% better CO levels**
- **HVAC systems:** not included: ; in addition: cost optimal levels two years earlier (2021 instead of 2023 and 2026 instead of 2028), Use of higher performing systems (effect included in system mix development) → **CO levels two years earlier**

5911

New building parameters:

5912 - No effects
5913
5914
5915
5916
5917

5918 I.3. BUILDING STOCK DISAGGREGATION

5919 I.3.1. REFERENCE ZONES AND CLIMATES

5920 The building stock is divided into five climate zones for Europe. The countries within the respective
5921 reference zones are shown in Figure 34.



5922

5923

Figure 34: Geographical regions for Europe


5924

5925 All countries are assigned to one of the reference zones concerning the criteria of (i) climate
5926 conditions, (ii) building stock characteristics and (iii) cost structures and level of investment
5927 costs/energy costs.

5928

5929 Figure 35 shows the reference climate conditions in terms of weighted average ambient
5930 temperatures of the reference zones.

5930



5931

5932 *Figure 35 Average ambient temperatures of the reference zones per month (Source: [Meteotest, 2012])*5933 **I.3.2. REFERENCE BUILDINGS**

5934 The model requires the definition of reference buildings as representative average building types for
 5935 all buildings in stock. Reference buildings are typical representatives with regard to the geometry of
 5936 a building.

5937

5938 **Residential**

5939 Reference buildings from [iNSPIRe, 2014] are used, which are:

- 5940 - Single Family House (SFH)
- 5941 - Small Multi Family House (SMFH)
- 5942 - Large Multi Family House (LMFH)

5943

5944 The parameters and geometries for the chosen reference buildings are shown in

5945 Table 45, Table 46 and Table 47.
5946
5947
5948
5949

5950

Table 45: Parameters for Single Family House (SFH) (Source: [iNSPIRe, 2014])

Parameter	Values	Unit
Total floor area	96	m ²
A/V ratio	0.90	1/m
Average room height	2.5	m
Exterior building volume	281	m ³
Exterior walls	128	m ²
Windows	26	m ²
Cellar ceiling	52	m ²
Roof / upper ceiling	52	m ²

5951

5952

Table 46: Parameters for Small Multi Family House (SMFH) (Source: [iNSPIRe, 2014])

Parameter	Values	Unit
Total floor area	500	m ²
A/V ratio	0.5	1/m
Average room height	2.5	m
Exterior building volume	1,672	m ³
Exterior walls	513	m ²
Windows	128	m ²
Cellar ceiling	124	m ²
Roof / upper ceiling	124	m ²

5953

5954

5955

Table 47: Parameters for Large Multi Family House (LMFH) (Source: [iNSPIRe, 2014])

Parameter	Values	Unit
Total floor area	2,340	m ²
A/V ratio	0.3	1/m
Average room height	2.5	m
Exterior building volume	7,484	m ³
Exterior walls	699	m ²
Windows	699	m ²
Cellar ceiling	462	m ²
Roof / upper ceiling	462	m ²

5956

5957 **Non-residential**5958 The reference buildings for non-residential buildings are defined along the Annex I.5 of the EPBD⁸¹.

5959 The geometries are based on data from European Copper Institute (ECI) for the study "Panorama of the European non-residential construction sector" (2011):

- 5960
- 5961 - Office Building (OFB)
 - 5962 - Trade and Retail Building (TRB)
 - 5963 - Education Building (EDB)
 - 5964 - Touristic Buildings (TOB)
 - 5965 - Health Buildings (HEB)
 - 5966 - Other non-residential buildings (ONB)
 - 5967 -

5968 The parameters and geometries for the chosen reference buildings are shown in Table 48, Table 49,
5969 Table 50, Table 51, Table 52 and Table 53.

5970

5971

⁸¹ Hospitals are listed under health buildings and hotels and restaurants under touristic buildings. Sport facilities are addressed with other non-res buildings.

5972

Table 48: Parameters for Office Buildings (OFB) (Source: [ECOFYS, 2011b])

Parameter	Values	Unit
Total floor area	1,801	m ²
A/V ratio	0.25	1/m
Average room height	2.6	m
Exterior building volume	4,683	m ³
Exterior walls	277	m ²
Windows	150	m ²
Cellar ceiling	360	m ²
Roof / upper ceiling	360	m ²

5973

5974

Table 49: Parameters for Trade and Retail Building (TRB) (Source: [ECOFYS, 2011b])

Parameter	Values	Unit
Total floor area	1,448	m ²
A/V ratio	0.36	1/m
Average room height	3.6	m
Exterior building volume	5,214	m ³
Exterior walls	302	m ²
Windows	130	m ²
Cellar ceiling	724	m ²
Roof / upper ceiling	724	m ²

5975

5976

5977

Table 50: Parameters for Education Building (EDB) (Source: [ECOFYS, 2011b])

Parameter	Values	Unit
Total floor area	2,552	m ²
A/V ratio	0.45	1/m
Average room height	2.6	m
Exterior building volume	6,556	m ³
Exterior walls	318	m ²
Windows	106	m ²
Cellar ceiling	1.216	m ²
Roof / upper ceiling	1.216	m ²

5978

5979

5980

Table 51: Parameters for Touristic Buildings (TOB) (Source: [ECOFYS, 2011b])

Parameter	Values	Unit
Total floor area	968	m ²
A/V ratio	0.40	1/m
Average room height	3.00	m
Exterior building volume	2,904	m ³
Exterior walls	385	m ²
Windows	127	m ²
Cellar ceiling	323	m ²
Roof / upper ceiling	323	m ²

5981

5982

5983

5984

Table 52: Parameters for Health Buildings (HEB) (Source: [ECOFYS, 2011b])

Parameter	Values	Unit
Total floor area	6,420	m ²
A/V ratio	0.27	1/m
Average room height	2.60	m
Exterior building volume	16,692	m ³
Exterior walls	997	m ²
Windows	330	m ²
Cellar ceiling	1,605	m ²
Roof / upper ceiling	1,605	m ²

5985

5986

Table 53: Parameters for Other non-residential buildings (ONB) (Source: [ECOFYS, 2011b])

Parameter	Values	Unit
Total floor area	2,434	m ²
A/V ratio	0.39	1/m
Average room height	3.00	m
Exterior building volume	9,500	m ³
Exterior walls	682	m ²
Windows	2,014	m ²
Cellar ceiling	507	m ²
Roof / upper ceiling	507	m ²

5987 **1.3.3. AGE GROUPS**

5988 The definition of age groups in stock is required to distinguish between different construction periods
 5989 of buildings. The chosen age groups are:

5990 - Pre 1945

- 5991 - 1945-1970
- 5992 - 1971-1990
- 5993 - 1991-2014
- 5994 - from 2015

5995 **I.3.4. RETROFIT LEVELS**

5996 The stock is further disaggregated into two sub-groups, considering the thermal characteristics:

- 5997 - "Renovated",
- 5998 - "Not-renovated".

5999

6000 This disaggregation enables the establishment of two levels of thermal characteristics for the
6001 considered segment.

6002 Already renovated buildings are not excluded from renovation by the model, but the not renovated
6003 buildings undergo renovation first.

6004


6005 In the scenario calculation for both, residential and non-residential buildings and for each reference
6006 zone, one retrofit level (major renovation) will be used. The fact that not every renovation is a major
6007 renovation will be considered in the full thermal retrofit rates assumed for each specific scenario.

6008 The thermal qualities assumed for residential and non-residential buildings of the "renovated" and
6009 "not renovated" cases are defined in section I.3.5.

6010

6011 **Residential**

6012 Figure 36 shows the share of already retrofitted residential buildings per reference zone.




6013

6014 *Figure 36: Considered share of already retrofitted residential buildings [%] (Source: own calculation based*
6015 *on [ECOFYS, 2012], based on [Euroconstruct, 2005] with further updates and assumptions for period 2005-*
6016 *2013.)*

6017 **Non-Residential**

6018 Figure 37 shows the share of already retrofitted non-residential buildings per reference zone.



6019

6020

6021

Figure 37: Considered share of already retrofitted non-residential buildings [%] (Source: own calculations for 2014 based on [Euroconstruct, 2005])

6022

1.3.5. BUILDING STOCK CHARACTERISTICS

6023

1.3.6. FLOOR AREAS

6024

The following figures give an overview on the floor area distribution along the reference zones of the study:

6025

6026

- Residential:

6027

- per reference buildings (Figure 38 and Figure 39),

6028

- per age group (Figure 40),

6029

- Non-residential:

6030

- per reference buildings (Figure 41 and Figure 42),

6031


- per age group (Figure 43).

6032

6033

6034

Residential




6035

6036

6037

6038

Figure 38: Floor area distribution in residential buildings, per zone and reference building [Mio. m²] (Source: own calculation based on [iNSPIRe, 2014], [IWU, 2015], [ENERDATA, 2013-2015], [BPIE, 2015] and [Schimschar, 2015])




6039

6040

6041

6042

Figure 39: Floor area distribution in residential buildings, per zone and reference building [%] (Source: own calculation based on [iNSPIRe, 2014], [IWU, 2015], [ENERDATA, 2013-2015], [BPIE, 2015] and [Schimschar, 2015])



6043

6044


Figure 40: Floor area distribution in residential buildings, per zone and age group [%] (Source: own calculation based on [iNSPIRe, 2014], [IWU, 2015], [ENERDATA, 2013-2015], [BPIE, 2015] and [Schimschar, 2015])

6045

6046

6047

Non-Residential



6048


6049

Figure 41: Floor area distribution in non-residential buildings, per zone and reference building [Mio. m²] (Source: own calculation based on [iNSPIRe, 2014], [IWU, 2015], [ENERDATA, 2013-2015], [BPIE, 2015] and [Schimschar, 2015])

6050

6051


6052



6053

6054 *Figure 42: Floor area distribution in non-residential buildings, per zone and reference building [%] (Source: own calculation based on [iNSPIRe, 2014], [IWU, 2015], [ENERDATA, 2013-2015], [BPIE, 2015] and*
 6055 *[Schimschar, 2015])*
 6056

6057



6058

6059 *Figure 43: Floor area distribution in residential buildings, per zone and age group, [%] (Source: own*
 6060 *calculation based on [iNSPIRe, 2014], [IWU, 2015], [ENERDATA, 2013-2015], [BPIE, 2015] and [Schimschar,*
 6061 *2015])*

6062

6063

6064 **I.4. DETAILED BUILDING SECTOR PATHWAYS**

6065 This section gives an overview of the first draft results for the building sector pathways.


6066 **I.4.1. AGREED AMENDMENTS PATHWAY**

6067

6068 **European Union**

6069

6070




6071

6072

6073

Figure 44 Floor area per reference building – EU




6074

6075

6076


Figure 45 EU total floor area development per buildings' age group



6077

6078

Figure 46 Floor area per heating system – EU




6079

6080

6081

Figure 47 Final Energy heating per reference buildings – EU




6082

6083

Figure 48 Primary Energy heating per reference building – EU

6084




6085

6086

Figure 49 CO2 emissions heating per heating system – EU

6087



6088

6089

Figure 50 Energy Costs heating per reference building – EU

6090


6091

6092

6093

EU-North

6094




6095

6096

Figure 51 Floor area per reference building – North

6097


6098



6099

6100

Figure 52 Floor area per age group – North




6101

6102

6103

6104

Figure 53 Floor area per heating system – North




6105

6106

Figure 54 Final Energy per reference buildings – North

6107

6108




6109

6110

Figure 55 Final Energy per Heating System – North

6111

6112



6113


6114

Figure 56 Primary Energy per reference building – North

6115

6116

6117




6118

6119

Figure 57 Primary Energy per heating system – North

6120

6121




6122

6123

Figure 58 CO₂ emissions per reference building – North

6124

6125




6126

6127

Figure 59 CO₂ emissions per heating system – North

6128

6129




6130

6131

Figure 60 Energy Costs per reference building – North

6132



6133

6134

Figure 61 Energy Costs per heating system – North


6135

6136

6137

EU-West

6138




6139

6140

6141

6142


Figure 62 Floor area per reference building – West



6143

6144

Figure 63 Floor area per age group – West




6145

6146

6147

6148

Figure 64 Floor area per heating system – West




6149

6150

Figure 65 Final Energy per reference buildings – West

6151

6152




6153

6154

Figure 66 Final Energy per Heating System – West

6155




6156

6157

Figure 67 Primary Energy per reference building – West

6158




6159

6160

Figure 68 Primary Energy per heating system – West

6161

6162




6163

6164

Figure 69 CO₂ emissions per reference building – West

6165

6166




6167

6168

Figure 70 CO₂ emissions per heating system – West

6169

6170




6171

6172

Figure 71 Energy Costs per reference building – West

6173



6174

6175

Figure 72 Energy Costs per heating system – West

6176

6177

6178

EU-North-East

6179





Figure 73 Floor area per reference building – North-East

6180

6181

6182


6183



6184

6185

Figure 74 Floor area per age group – North-East




6186

6187

6188

6189

Figure 75 Floor area per heating system – North-East




6190

6191

Figure 76 Final Energy per reference buildings – North-East

6192

6193




6194

6195

Figure 77 Final Energy per Heating System – North-East

6196




6197

6198

6199

Figure 78 Primary Energy per reference building – North-East



6200

6201

6202

6203

Figure 79 Primary Energy per heating system – North-East

6204
6205
6206
6207




Figure 80 CO₂ emissions per reference building – North-East

6208
6209
6210
6211





Figure 81 CO₂ emissions per heating system – North-East




6212

6213

Figure 82 Energy Costs per reference building – North-East

6214



6215

6216


Figure 83 Energy Costs per heating system – North-East

6217

6218

EU-South

6219




6220

6221

6222

6223


Figure 84 Floor area per reference building – South



6224

6225

Figure 85 Floor area per age group – South




6226

6227

6228

6229

Figure 86 Floor area per heating system – South




6230

Figure 87 Final Energy per reference buildings – South

6231

6232

6233




6234

Figure 88 Final Energy per Heating System – South

6235

6236




6237

6238

Figure 89 Primary Energy per reference building – South

6239




6240

6241

Figure 90 Primary Energy per heating system – South

6242

6243




6244

6245

Figure 91 CO₂ emissions per reference building – South

6246

6247




6248

6249

Figure 92 CO₂ emissions per heating system – South

6250

6251




6252

6253

Figure 93 Energy Costs per reference building – South

6254



6255

6256

Figure 94 Energy Costs per heating system – South

6257

6258

EU-South-East

6259





Figure 95 Floor area per reference building – South-East

6260

6261

6262


6263



6264

6265

Figure 96 Floor area per age group – South-East




6266

6267

Figure 97 Floor area per heating system – South-East

6268

6269




6270

6271

Figure 98 Final Energy per reference buildings – South-East

6272

6273




6274

6275

Figure 99 Final Energy per Heating System – South-East

6276




6277

6278

Figure 100 Primary Energy per reference building – South-East

6279




6280

6281

Figure 101 Primary Energy per heating system – South-East

6282

6283




6284

6285

6286

6287

Figure 102 CO₂ emissions per reference building – South-East




6288

6289

6290

6291

Figure 103 CO₂ emissions per heating system – South-East




6292

6293

Figure 104 Energy Costs per reference building – South-East

6294



6295

6296

Figure 105 Energy Costs per heating system – South-East

6297

6298

6299

6300

6301

6302

6303 **1.4.2. AGREED AMENDMENTS + AMBITIOUS IMPLEMENTATION PATHWAY**

6304 The scenario “Agreed Amendments + Ambitious Implementation” is not completed at the time this
 6305 report is issued.

6307

ANNEX J – SRT SCENARIOS – DETAILED ASSUMPTIONS (TO BE COMPLETED)

6308

ANNEX K – CURRENT AND ADDITIONAL ACCOMPANYING POLICIES

6309 Public policies, incentives and information campaigns influence and can promote adoption of
 6310 energy management and SRT. The effect of policies could be on the demand for SRT and
 6311 increase in the reliability of energy savings. There are already pieces of European legislation
 6312 today that can support the deployment of SRT. The effect of current related EU legislation is
 6313 considered under “business as usual (SRT-BAU)” scenario. Additionally, further measures and
 6314 policies can play a leveraging role for increased uptake of SRT. This second set of tools are
 6315 considered under “moderate” and “increased uptake” scenarios. The following sections give
 6316 an overview over existing policies that influence the implementation of SRT today and shows
 6317 possible future accompanying measures and policies considering both increase in demand and
 6318 increase in reliability of energy savings.
 6319

6320 **K.1. CURRENT POLICIES**

6321 This section analyses different levels of current policies in the area of regulatory law,
 6322 information measures from MS, incentives and others.
 6323

6324 **K.1.1. REGULATORY LAW**

6325 **EPBD**

6326 One of the most important regulations dealing with energy efficiency in EU is the EPBD. The core of
 6327 EPBD is to increase and ensure the energy efficiency of building stock by cost effective means. On 30
 6328 November 2016 the Commission proposed an update to the EPBD to help promote the use of smart
 6329 technology in buildings, to streamline existing rules and accelerate building renovation. Within its
 6330 specifications, technical building systems and controls have historically been mentioned, however
 6331 those gained increased importance in the latest proposal for amendment of the directive.

6332 In proposed revision of EPBD, **Article 2** is amended to include “Long term renovation strategy”. This
 6333 requires Member States to establish a long-term strategy to support the renovation of the national
 6334 stock of residential and non-residential buildings, both public and private, into a highly energy
 6335 efficient and decarbonised building stock by 2050. Among the requirements of the provision, it is
 6336 mentioned that an overview of national initiatives to promote smart technologies and well-
 6337 connected buildings and communities, as well as skills and education in the construction and energy
 6338 efficiency sectors is needed. If applied appropriately this provision would increase deployment of
 6339 SRT.

6340

6341 **Article 8** is amended to take into account the revised definition of technical building systems and
 6342 new paragraphs. Additional paragraphs are as follows;

6343 Article 8 new paragraph 5 “Member States shall ensure that, when a technical building system
 6344 is installed, replaced or upgraded, the overall energy performance of the complete altered
 6345 system is assessed, documented and passed on to the building owner, so that it remains available
 6346 for the verification of compliance with the minimum requirements set pursuant to paragraph 1

6347 and the issue of energy performance certificates. Without prejudice to Article 12, Member States
6348 shall decide whether to require the issue of a new energy performance certificate.”

6349 Article 8 new paragraph 6 “The Commission shall, by 31 December 2019, adopt a delegated act
6350 in accordance with Article 23, supplementing this Directive by establishing an optional common
6351 European Union scheme for rating the smart readiness of buildings. The rating shall be based on
6352 an assessment of the capabilities of a building or building unit to adapt its operation to the needs
6353 of the occupant and the grid and to improve its energy efficiency and overall performance.”

6354 The recitals strongly emphasize the emerging importance of digital solutions, and update of the
6355 proposed EPBD articles introduce implementation of potentially higher rate of Deployment of
6356 SRT.

6357

6358 The amendment of EPBD also includes the following provisions on inspection of heating and air-
6359 conditioning systems. **Article 14** is replaced with following paragraphs:

6360

6361 “Member States shall lay down the necessary measures to establish regular inspection of the
6362 accessible parts of systems with an effective rated output for space heating or for combined
6363 space heating and ventilation purposes of over 70 kW, such as the heat generator, control
6364 system and circulation pump(s) used for heating buildings. The inspection shall include an
6365 assessment of the heat generator efficiency and the heat generator sizing compared with the
6366 heating requirements of the building and considering, where relevant, the capabilities of the
6367 heating system to optimize its performance at typical or average operating conditions.

6368

6369 Where no changes have been made to the heating system or as regards the heating
6370 requirements of the building since an inspection pursuant to this paragraph was carried out,
6371 Member States may choose not to require the assessment of the heat generator sizing to be
6372 repeated.

6373

6374 1a. As an alternative to paragraph 1, Member States may opt to take measures to ensure
6375 the provision of advice to users concerning the replacement of heat generators, other
6376 modifications to the heating system and alternative solutions to assess the efficiency and
6377 appropriate size of the heating system or combined heating and ventilation system. The overall
6378 impact of such an approach shall be equivalent to that arising from the provisions set out in
6379 paragraph 1.

6380

6381 Before Member States apply the measures referred to in the first subparagraph, they shall, by
6382 submitting a report to the Commission, document the equivalence of the effect of those
6383 measures to the measures referred to in paragraph 1.

6384

6385

6386 Such report shall furthermore be included in the national climate and energy plans according
6387 to applicable reporting obligations [i.e. Governance Regulation].

6388

6389 2. Member States shall set the requirements to ensure that non-residential buildings with
6390 an effective rated heating or combined heating and ventilation system output of over 290kW,
6391 where technically and economically feasible, are equipped with building automation and
6392 control systems by 2025.

6393

6394 The building automation and control systems shall be capable of:

6395

- 6396 (a) continuously monitoring, logging, analysing and allowing for adjusting energy usage;
6397 (b) benchmarking the building's energy efficiency, detecting losses in efficiency of technical
6398 building systems, and informing the person responsible for the facilities or technical
6399 building management about opportunities for energy efficiency improvement; and
6400 (c) allowing communication with connected technical building systems and other
6401 appliances inside the building, and being interoperable with technical building systems
6402 across different types of proprietary technologies, devices and manufacturers.

6403

6404 3. Member States may set requirements to ensure that residential buildings are equipped
6405 with:

6406

- 6407 (a) the functionality of continuous electronic monitoring that measures systems' efficiency
6408 and inform building owners or managers when it has fallen significantly and when
6409 system servicing is necessary, and
6410 (b) effective control functionalities to ensure optimum generation, distribution, storage and
6411 use of energy.

6412

6413 3a. Buildings that comply with paragraphs 2 or 3 shall be exempt from the requirements
6414 laid down in paragraph 1.

6415

6416 3b. Technical building systems explicitly covered by an agreed energy performance criterion
6417 or a contractual arrangement specifying an agreed level of energy efficiency improvement,
6418 such as energy performance contracting as defined in point (27) of Article 2 of Directive
6419 2012/27/EU or that are operated by a utility or network operator and therefore subject to
6420 performance monitoring measures on the system side, shall be exempt from the requirements
6421 laid down in paragraph 1, provided that the overall impact of such an approach is equivalent
6422 to that arising from the provisions set out in paragraph 1.

6423

6424

6425 **Article 15** is replaced with following paragraphs

6426

6427 "1. Member States shall lay down the necessary measures to establish a regular inspection
6428 of the accessible parts of air-conditioning systems or of combined air-conditioning and
6429 ventilation systems, with an effective rated output of over 70 kW. The inspection shall include
6430 an assessment of the air-conditioning efficiency and the sizing compared to the cooling
6431 requirements of the building and considering, where relevant, the capabilities of the air-
6432 conditioning or of the combined air-conditioning and ventilation system to optimize its
6433 performance at typical or average operating conditions.

6434

6435 Where no changes have been made to the air-conditioning system or to the combined air-
6436 conditioning and ventilation system or to the requirements for cooling of the building since an
6437 inspection pursuant to this paragraph was carried out, Member States may choose not to
6438 require the assessment of the sizing to be repeated.

6439 Member States that maintain more stringent requirements pursuant to Article 1(3) shall be
6440 exempted from the obligation to notify them to the Commission.

6441

6442 1a. As an alternative to paragraph 1, Member States may opt to take measures to ensure
6443 the provision of advice to users concerning the replacement of air-conditioning systems or
6444 combined air-conditioning and ventilation systems, other modifications to the air-conditioning
6445 system or combined air-conditioning and ventilation system and alternative solutions to assess
6446 the efficiency and appropriate size of these systems. The overall impact of such an approach
6447 shall be equivalent to that arising from the provisions set out in paragraph 1.

6448

6449 Before Member States apply the measures referred to in the first subparagraph, they shall, by
6450 submitting a report to the Commission, document the equivalence of the effect of those
6451 measures to the measures referred to in paragraph 1.

6452

6453 Such report shall furthermore be included in the national climate and energy plans according
6454 to applicable reporting obligations [i.e. Governance Regulation].

6455

6456 2. Member States shall set the requirements to ensure that non-residential buildings with
6457 an effective rated output for systems for air-conditioning or systems for combined air-
6458 conditioning and ventilation of over 290kW, where technically and economically feasible, are
6459 equipped with building automation and control systems by 2025.

6460

6461 The building automation and control systems shall be capable of:

6462

6463 (a) continuously monitoring, logging, analysing and allowing for adjusting energy usage;
6464 (b) benchmarking the building's energy efficiency, detecting losses in efficiency of technical
6465 building systems, and informing the person responsible for the facilities or technical
6466 building management about opportunities for energy efficiency improvement; and

6467

6468 3. Member States may set requirements to ensure that residential buildings are equipped
6469 with:

6470

6471 (a) the functionality of continuous electronic monitoring that measures systems' efficiency
6472 and inform building owners or managers when it has fallen significantly and when system
6473 servicing is necessary, and

6474 (b) effective control functionalities to ensure optimum generation, distribution, storage
6475 and use of energy.

6476

6477 3a. Buildings that comply with paragraph 2 or 3 shall be exempt from the requirements laid
6478 down in paragraph 1.

6479

6480 3b. Technical building systems explicitly covered by an agreed energy performance criterion
6481 or a contractual arrangement specifying an agreed level of energy efficiency improvement,
6482 such as energy performance contracting as defined in point (27) of Article 2 of Directive
6483 2012/27/EU or that are operated by a utility or network operator and therefore subject to
6484 performance monitoring measures on the system side, shall be exempt from the requirements
6485 laid down in paragraph 1, provided that the overall impact of such an approach is equivalent
6486 to that arising from the provisions set out in paragraph 1. ”

6487

6488 Both Articles clearly emphasizes the use of building automation and control systems where
6489 technically and economically feasible. This creates a direct incentive for high SRT deployment
6490 rate.

6491

6492

6493 **EED**

6494 The Energy Efficiency Directive, (EED) (2012/27/EU) adopted on 25 October 2012, requires the
6495 Member States to set indicative national energy efficiency targets ensuring that the EU reaches
6496 its headline target of saving 20 % of primary and final energy consumption by 2020 compared to
6497 business-as-usual projections. In its Implementation report on the Energy Efficiency Directive,
6498 adopted on 23 June 2016, Parliament concluded that the existing directive, while offering a
6499 framework for reducing energy demand, was being implemented poorly. On
6500 30 November 2016, the European Commission presented the 'Clean Energy for All Europeans'
6501 package of proposals, including a revised Energy Efficiency Directive amending the current
6502 directive.

6503

6504 The revision of the directive only focused on some article. Below is a list of main provision of EED
6505 (considering their revision) which could be lever for deployment of SRT and controls in buildings
6506 if implemented accordingly.

6507

6508 • Central government buildings: The directive requires that central governments are to lead
6509 by example in the field of buildings as well, and to renovate 3 % of the total floor area of
6510 buildings occupied or owned by central government each year from 2014 onwards. The
6511 provision allows Member States to take alternative cost-efficient measures to achieve an
6512 equivalent improvement in the energy performance of the buildings within their central
6513 government estate. MS can consider the use SRT within the renovation plan, thus the
6514 provision can be an opportunity to promote deployment of SRT and controls in central
6515 government buildings and pioneer improvement within the sector.

6516

6517 • Energy efficiency obligation schemes; EU countries must set up an energy efficiency
6518 obligation scheme. This scheme requires energy companies to carry out measures which
6519 help final consumers improve energy efficiency to achieve yearly energy savings of 1.5%
6520 of annual sales of energy companies to final consumers. The utilities can consider various
6521 energy efficiency measures, including implementation of energy management services
6522 and deployment of SRT for this purpose.

6523

6524 • Metering and billing information; The directive sets requirements for the billing
6525 information available to customers with smart and regular meters. New provisions of EED
6526 refer mainly to district heating, cooling and domestic hot water. As of 1 January 2020, all
6527 newly installed district heating and cooling meters and domestic hot water meters, as well
6528 as cost allocators at individual radiators, have to be remotely readable. Old meters and
6529 allocators will have to add such capabilities or be replaced by 1 January 2027, unless a
6530 Member State shows this would not be cost-efficient. The requirements have potential to
6531 increase the opportunities for increased deployment of SRT and controls.

6532

6533 • Energy audits; Member States are required to develop programmes to stimulate energy
6534 audits among small and medium-sized enterprises (SMEs). Member states can consider
6535 the requirement developing systematic identification, quantification and reporting of
6536 energy-savings by use of SRT which in turn would increase their deployment rate.

6537

6538

6539 **K.1.2. INFORMATION MEASURES MEMBER STATES**

6540 **Guidelines (i.e. for the cost optimality reporting)**

6541 In order to help Member States implement the requirements of several regulations (such as EPBD
6542 and EED) the European commission has published accompanying documents referred as guidelines.
6543 While these guidelines are not legally binding, they provide relevant additional information to the
6544 Member States and reflect accepted principles for the cost calculations required in the context of
6545 the regulations. As such, the guidelines are intended for facilitating the application of the regulations
6546 thus are enabling tools for deployment of energy management and smart ready technologies.

6547 EPBD requires Member States to ensure that energy performance requirements are set with a view
6548 to achieving cost-optimal levels. EPBD is accompanied by Guidelines (2012/C 115/01) describing how
6549 to apply the methodology of calculating the cost-optimal performance level.

6550 The European Commission has also published guidelines to help implement the EED. The guidelines
6551 provide essential supplementary information on metering and billing, implementation of energy
6552 audits and management systems and also include cost-allocation rules for the smooth introduction
6553 of sub-metering in buildings where energy bills were previously calculated using different criteria.

6554 **Recommendations section of EPCs to improve energy performance**

6555 Recommendations for the cost-optimal or cost-effective improvement of the energy performance
6556 (“unless there is no reasonable potential for such improvement compared to the energy
6557 performance requirements in force.”) is one of the three main elements of Energy Performance
6558 Certificates according to EPBD. This section could include recommendations concerning TBS
6559 including BACS which further increase the probability that occupants’ needs are met, and
6560 potentials for cost-effective energy performance improvement options with SRT. Specific
6561 recommendations formulized uniquely for a building would improve the acceptability of SRT and
6562 increase their deployment rate.

6563 **K.1.3. INCENTIVES**

6564 **EPBD: Smart finance for smart buildings initiative**

6565 The commission has launched the Smart Finance for Smart Buildings (SFSB) initiative, as part of the
6566 'Clean Energy for All Europeans' package. This initiative includes practical solutions to mobilize more
6567 private financing for energy efficiency and renewable energy sources in buildings. It follows a
6568 threefold objective; using public funds more effectively: project development assistance; changing
6569 the risk perception of financiers and investors.

6570 These incentives have clear potential to help increase the number and effectiveness of energy saving
6571 measures in buildings by increasing the availability of financial resources and acceptance of available
6572 technology. In this context the initiative could create strategic opportunity to support deployment
6573 of SRT and controls for energy management, where technically and economically feasible.

6574 **Incentives in the framework of the renovation roadmaps**

6575 Roadmaps need to address all relevant aspects of the buildings and construction sectors, including
6576 technologies, construction materials. Inclusion of financial support and organisational support is one
6577 of the main pillars of successful renovation roadmaps. For example France has Finance law creating
6578 the 0% green loan with banks, Germany has subsidies and loans that are available for energy efficient
6579 renovations that meet certain ambition level

6580

6581 They can provide investment in consumer education and outreach so that they are made aware of
6582 need for renovations, possibilities and technologies in market. For example in the Netherlands the
6583 office responsible for the implementation of the renovation plan coordinates activities that brings
6584 together different stakeholders in events supporting the energy saving pilot projects and
6585 communication activities.

6586

6587 National roadmaps integrate plans that provide logistical support for homeowner for the required
6588 professional skills for decision making and planning. To make innovative solutions more accessible
6589 to homeowners.

6590 Mentioned features are examples of national renovation roadmaps and their opportunity to
6591 combine various support instruments for creating a greater momentum for use of SRT and energy
6592 management in renovation activities.

6593 **Art. 8 EPBD: If TBS is improved/ upgraded, an EPC should be updated (is not very often done in the**
6594 **field)**

6595 As mentioned earlier, Article 5 paragraph 5 of the proposed EPBD amendment introduces new
6596 arguments to ask for an update of EPC when a technical building system is installed, replaced or
6597 upgraded. Member States shall decide whether to require the issue of a new energy performance
6598 certificate as a result of TBS upgrade. In the case that TBS upgrade is linked to new EPC by MS this
6599 can demonstrate improved energy performance it could create incentives for implementation of TBS
6600 and SRT in energy management.

6601

6602 **K.2. ADDITIONAL ACCOMPANYING POLICY MEASURES**

6603 While current regulations provide a solid legislative environment that stimulate uptake of energy
 6604 savings controls, energy management systems and SRT, there are potential areas where further
 6605 policy measures are considered to facilitate higher deployment rate of such technologies and ensure
 6606 desired levels of energy savings are met.

6607 **K.2.1. MEASURES FOR INCREASING THE RELIABILITY OF EPC**

6608 In addition to the EPBD provisions that require use of SRT and controls that can stimulate the
 6609 high deployment rate of these technologies, there are potential areas where SRT can be seen
 6610 thus supported for the implementation of EPBD and help achieving the energy efficiency targets
 6611 of the EU legislation. Potentially one of the most important challenges for transforming the
 6612 building stock to an energy efficient one within the scope of EPBD is the so called “performance
 6613 gap”, defined as the difference between the design performance and actual performance of
 6614 building. A significant share in the performance gap is attributed to occupant behaviour. Several
 6615 studies have showed that there are notable differences between the predicted and actual energy
 6616 performance of a building once it is inhabited^{82, 83}. The studies conclude that human behaviour
 6617 and occupant preferences as an important contributor of the gap between the predicted and
 6618 actual building energy performance. SRT bring in the potential to reduce occupant based
 6619 performance gap via following, which in turn creates additional incentives to use SRT in the
 6620 actual implementation of the EPBD requirements;

- 6621 • *eliminating the poor operation practices of users*: SRT can replace users by utilizing
 6622 autonomous, and self-learning control systems, which empower occupants with control
 6623 over their own energy consumption. For example SRT override user behavior under pre-
 6624 defined conditions such as switching appliances off while not in active use or during non-
 6625 occupancy hours.
- 6626 • *guiding users for informed decision making*: SRT can provide energy savings by serving a
 6627 personalized service that allows occupants to make informed decisions on indoor
 6628 temperature or switching appliances in order to re-adjust their preference in favor of
 6629 energy saving options.

6630
 6631 Energy performance calculations are based on assumptions for technical building systems as well
 6632 as the occupant behavior. The assumptions about the building service needed by the occupant and
 6633 used in the EP calculation may not represent reality. For example building codes generally refer to
 6634 standard set point temperatures to be used in performance calculations. These potentially fail to
 6635 reflect the actual need of different occupants (for example, elderly, or young family). Ideally,
 6636 monitoring and control within SRT would allow collection of actual desired internal conditions and
 6637 provide a feedback for update of calculation input parameters.

6638 These benefits can be achieved by introducing additional policy measures to support use of the
 6639 actual energy consumption data by digitalised monitoring, SRT, into the energy performance
 6640 calculation and providing real time consumption information into an update of EPC.

82 Gram-Hanssen, K., Georg, S., Christiansen, E. T., & Heiselberg, P. K. (2017). How building regulations ignore the use of buildings, what that means for energy consumption and what to do about it. Summerstudy, ECEEE, European Council for an Energy Efficient Economy.

83 Majcen, D., Itard, L. C. M., & Visscher, H. (2013). Theoretical vs. actual energy consumption of labelled dwellings in the Netherlands: Discrepancies and policy implications. *Energy Policy*, 54, 125–136. doi: 10.1016/j.enpol.2012.11.008

6641

6642 **K.2.2. MEASURES FOR ELIMINATING FINANCIAL RISKS ATTRIBUTED TO ENERGY EFFICIENCY AND RENEWABLE**
 6643 **ENERGY INVESTMENTS**

6644 A building that is equipped with required energy monitoring and control devices, that enable to close
 6645 the performance gap and ensure actual energy consumption is reflected in the EPC (even with a
 6646 continuous update via digital monitoring) would provide confidence in reliability of energy
 6647 performance data. It would provide;

- 6648 • increased probability that building meets occupants needs while displaying the correct
 6649 energy performance,
- 6650 • better predictability of energy demand changes due to continuous monitoring.

6651 Additional policy measures addressing the requirement to increase confidence level that the
 6652 financial performance which has been assumed for renovation measures or a new building will
 6653 persist throughout its whole life-cycle would facilitate SRT uses in buildings.

6654 The interoperability of the building with the grid is increasingly important topic as the share of
 6655 renewables increase in the energy mix. Flexible and atomized building operation is the key to achieve
 6656 the interoperability in order to exploit potentials provided by building for load shifting and peak load
 6657 reduction. Future energy policy will need to address topics such as control of occupant to optimize
 6658 purchase of energy from the grid depending on time variable tariffs; automatically adaption of
 6659 building's operation when system parameters like energy prices change; and potentials for better
 6660 understand further flexibility potentials, like switching the heating system off for a certain period or
 6661 patterns for charging electric vehicles. These measures will have a direct effect on facilitating
 6662 increased use of SRT to achieve required new services.

6663 **K.2.3. INFORMATION AND EVALUATION**

6664
 6665 An important topic to address for the long term energy performance of the building stock is the
 6666 persistence of building's financial performance during its life-cycle. Currently for cost-optimality
 6667 calculations, typically the initial performance of the building is assumed to remain same for a period
 6668 of 20-30 years. The approach lacks an adequate discussion on how the assumed energy prices may
 6669 be affected in buildings that do not offer flexibility to the overall energy system during that period.
 6670 Aiming cost calculations that are closer to real conditions would consider use of advanced controls,
 6671 enhanced monitoring, thus would increase the uptake of SRT.

6672 EPCs are one of the most important tools of EPBD that support improved energy efficiency and
 6673 visibility of energy performance of building stock. However, current most of the EPC assessment
 6674 methods applied in the majority of MS lack adequate reliability and rate of update due to calculation
 6675 methods that are based on design specifications of buildings rather than monitoring the actual
 6676 energy performance after the building is completed and occupied. EPC databases run by MS have
 6677 proven to be an important source of information for different stakeholder groups including policy
 6678 makers as well as becoming crucial in quality control. Almost all MSs have established EPC databases
 6679 that register EPC data. In a further step more dynamic and informative EPC system possibly coupled
 6680 with or triggered by SRT update can be a gate opener for implementation of operational rating with
 6681 real time performance monitoring that trigger the financial incentives towards higher performance
 6682 investments.

6683

6684

ANNEX L MULTI CRITERIA DECISION MAKING METHODS

6685

MCDM methods

6686

6687

The following MCDM methods are available, many of which are implemented by specialised decision-making software:

6688

- Aggregated Indices Randomisation Method (AIRM)

6689

- Analytic hierarchy process (AHP)

6690

- Analytic network process (ANP)

6691

- Best worst method (BWM)

6692

- Characteristic Objects METHod (COMET)

6693

- Choosing By Advantages (CBA)

6694

- Data envelopment analysis

6695

- Decision EXpert (DEX)

6696

- Disaggregation – Aggregation Approaches (UTA, UTAlI, UTADIS)

6697

- Dominance-based rough set approach (DRSA)

6698

- ELECTRE (Outranking)

6699

- Evidential reasoning approach (ER)

6700

- Goal programming (GP)

6701

- Grey relational analysis (GRA)

6702

- Inner product of vectors (IPV)

6703

- Measuring Attractiveness by a categorical Based Evaluation Technique (MACBETH)

6704

- Multi-Attribute Global Inference of Quality (MAGIQ)

6705

- Multi-attribute utility theory (MAUT)

6706

- Multi-attribute value theory (MAVT)

6707

- New Approach to Appraisal (NATA)

6708

- Nonstructural Fuzzy Decision Support System (NSFDSS)

6709

- Potentially all pairwise rankings of all possible alternatives (PAPRIKA)

6710

- PROMETHEE (Outranking)

6711

- Stochastic Multicriteria Acceptability Analysis (SMAA)

6712

- Superiority and inferiority ranking method (SIR method)

6713

- Technique for the Order of Prioritisation by Similarity to Ideal Solution (TOPSIS)

6714

- Value analysis (VA)

6715

- Value engineering (VE)

6716

- VIKOR method

6717

- Fuzzy VIKOR method

6718

- Weighted product model (WPM)

6719

- Weighted sum model (WSM)

6720

- Rembrandt method.

6721

6722

6723

6724 **ANNEX M - CALCULATION PROCESS DETAILS FOR THE IN-FIELD SINGLE FAMILY**
6725 **HOME CASE STUDY**

6726 This annex reports the specific assessment and calculation applied in the in-field SFH case study
6727 reported in section 4.10. It begins with reporting the inputs to the assessment by domain and then
6728 discusses the calculations which produce the sub-scores and aggregate SRI score reported in Table
6729 31.

6730

6731 The following domains were absent and hence all scored zero:

- 6732 • Cooling
- 6733 • Controlled ventilation
- 6734 • Dynamic Building Envelope
- 6735 • Self generation
- 6736 • DSM
- 6737 • EV (only dumb charging)

6738

6739 In the case of Lighting while there was energy efficient lighting throughout the property there was
6740 only one small internal space (a toilet) which used smart lighting controls and hence it too scores
6741 zero (technically it could have been just above zero but the space was probably only ~1/90th of the
6742 total floor area of the property). The external security lighting used motion sensors but the
6743 streamlined methodology is currently focused on internal lighting.

6744 **Space heating**

6745 In the case of space heating the building scored the values indicated in Table Q1a below. The ordinal
6746 impact scores are produced by defining the functionality level for the service as set out in the services
6747 catalogue. Only the services retained in the streamlined methodology are eligible for consideration,
6748 however, depending on the heating solution adopted not all of these will be relevant for the building
6749 in question. In the case of this building the TABS and Thermal Energy Storage solutions are not part
6750 of the solutions applied and hence are zeroed-out and do not contribute to the overall scores.
6751 Nonetheless, this leaves 9 eligible smart heating services of the 11 potentially eligible services.

6752 In Table M1a the ordinal impact scores for the building are shown but in Table M1b the maximum
6753 possible ordinal impact scores for any building are also shown. The process of deriving the service
6754 level smart readiness scores for the building in question is to normalise its scores by dividing them
6755 by the maximum possible scores.

6756 **Hot Water**

6757 The equivalent data is reported for domestic hot water in Table M2a and Table M2b. Given that the
6758 hot water is gas-fired the only applicable service is DHW-3 concerning the reporting of information
6759 of the domestic hot water performance.

6760 **Lighting, DSM and Monitoring & Control**

6761 The equivalent data for lighting, DSM and Monitoring & Control is reported in Table M3a and Table
 6762 M3b. For lighting and DSM the building essentially has no smart service capability so it scores 0 on
 6763 these services. It does rather better on the Monitoring and Control MC3 and MC13 services.

6764 **Aggregation**

6765 The aggregated scores are shown in Table M4 (identical to Table 31). While the scores per domain
 6766 are the simple sum of the normalised service-level scores discussed above the aggregate overall
 6767 score is determined after the domain and impact parameter weighting factors shown in Table 21
 6768 have been applied. As mentioned in the discussion in section 4.10 these weightings are currently far
 6769 from imperfect – they are reasonably representative of an EU average building for energy
 6770 consumption but for other impact parameters they need more work to establish appropriate values.
 6771 Even for energy, more accurate approaches can be used even down to the specific energy balance
 6772 for the building in question if sub-metering data or EPC calculations are available. Thus, for the time
 6773 being these weightings are simply applied to illustrate the methodological principle and are not
 6774 intended to be reflective of an optimal or truly representative set of data.

6775 Aside from the weightings the other issue is which domains are applied to derive the overall
 6776 normalised score. This is discussed in section 4.10.

6777

6778 *Table M4 – SRI scores for the in-field single family home case study*

	Energy	Flexibility	Self generation	Comfort	Convenience	Well-being and health	Maintenance & fault prediction	Information to occupants	SRI
Overall	71%	0%	0%	77%	33%	17%	20%	19%	45%
Heating	75%	0%	0%	85%	64%	0%	25%	75%	
DHW	100%	0%	0%	0%	0%	0%	50%	67%	
Cooling	0%	0%	0%	0%	0%	0%	0%	0%	
Ventilation	0%	0%	0%	0%	0%	0%	0%	0%	
Lighting	0%	0%	0%	0%	0%	0%	0%	0%	
Dynamic envelope	0%	0%	0%	0%	0%	0%	0%	0%	
Self generation	0%	0%	0%	0%	0%	0%	0%	0%	
DSM	0%	0%	0%	0%	0%	0%	0%	0%	
Electric Vehicles	0%	0%	0%	0%	20%	0%	0%	0%	
Monitoring & control	60%	100%	0%	67%	38%	33%	17%	14%	

6779

6780

6781

6782

Table M1a. Heating service scores for the in-field SFH case study

SR fields						ORDINAL IMPACT SCORES							
Domain	Code	Service	Functionality level for this building	Max possible functionality level	Max functionality level in this building	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Heating	Heating-1a	Heat emission control	2	4	4	2	0	0	2	2	0	0	0
Heating	Heating-1b	Emission control for TABS (heating mode)	0	3	0	0	0	0	0	0	0	0	0
Heating	Heating-1c	Control of distribution network hot water temperature (supply or return) - Similar function can be applied to the control of direct electric heating networks	1	2	2	1	0	0	1	1	0	0	0
Heating	Heating-1d	Control of distribution pumps in networks	3	4	4	3	0	0	3	0	0	0	0
Heating	Heating-1e	Intermittent control of emission and/or distribution - One controller can control different rooms/zones having same occupancy patterns	2	3	3	2	0	0	2	2	0	0	0
Heating	Heating-1f	Thermal Energy Storage (TES) for building heating	0	2	0	0	0	0	0	0	0	0	0
Heating	Heating-1g	Building preheating control	2	2	2	2	0	0	2	2	0	0	1
Heating	Heating-2a	Heat generator control (for combustion and district heating)	1	2	2	1	0	0	1	0	0	0	0
Heating	Heating-2b	Heat generator control (for heat pumps)	0	3	0	0	0	0	0	0	0	0	0
Heating	Heating-2c	Sequencing of different heat generators	0	3	0	0	0	0	0	0	0	0	0
Heating	Heating-3	Report information regarding HEATING system performance	2	4	4	1	0	0	0	0	0	1	2

6783

6784

6785

Table M1b. Heating service scores for the in-field SFH case study

SR fields			ORDINAL IMPACT SCORES							MAXIMUM POSSIBLE ORDINAL IMPACT SCORES								
Domain	Code	Service	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Heating	Heating-1a	Heat emission control	2	0	0	2	2	0	0	0	3	0	0	2	3	0	1	0
Heating	Heating-1b	Emission control for TABS (heating mode)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Heating	Heating-1c	Control of distribution network hot water temperature (supply or return) - Similar function can be applied to the control of direct electric heating networks	1	0	0	1	1	0	0	0	2	0	0	1	2	0	1	0
Heating	Heating-1d	Control of distribution pumps in networks	3	0	0	3	0	0	0	0	3	0	0	3	0	0	0	0
Heating	Heating-1e	Intermittent control of emission and/or distribution - One controller can control different rooms/zones having same occupancy patterns	2	0	0	2	2	0	0	0	3	0	0	3	3	0	0	0
Heating	Heating-1f	Thermal Energy Storage (TES) for building heating	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Heating	Heating-1g	Building preheating control	2	0	0	2	2	0	0	1	2	0	0	2	2	0	0	1
Heating	Heating-2a	Heat generator control (for combustion and district heating)	1	0	0	1	0	0	0	0	2	0	0	2	0	0	0	0
Heating	Heating-2b	Heat generator control (for heat pumps)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Heating	Heating-2c	Sequencing of different heat generators	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Heating	Heating-3	Report information regarding HEATING system performance	1	0	0	0	0	0	1	2	1	0	0	0	1	0	2	3

6786

Draft Second Progress report

6787

6788

Table M2a. DHW service scores for the in-field SFH case study

SR fields						ORDINAL IMPACT SCORES							
Domain	Code	Service	Functionality level for this building	Max possible functionality level	Max functionality level in this building	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Domestic hot water	DHW-1a	Control of DHW storage charging (with direct electric heating or integrated electric heat pump)	0	3	0	0	0	0	0	0	0	0	0
Domestic hot water	DHW-1b	Control of DHW storage charging (using heat generation)	0	3	0	0	0	0	0	0	0	0	0
Domestic hot water	DHW-1d	Control of DHW storage charging (with solar collector and supplementary heat generation)	0	3	0	0	0	0	0	0	0	0	0
	DHW-3	Report information regarding domestic hot water performance	2	4	4	1	0	0	0	0	0	1	2

6789

6790

6791

Table M2b. DHW service scores for the in-field SFH case study

SR fields			ORDINAL IMPACT SCORES								MAXIMUM POSSIBLE ORDINAL IMPACT SCORES								
Domain	Code	Service	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants	
Domestic hot water	DHW-1a	Control of DHW storage charging (with direct electric heating or integrated electric heat pump)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Domestic hot water	DHW-1b	Control of DHW storage charging (using heat generation)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Domestic hot water	DHW-1d	Control of DHW storage charging (with solar collector and supplementary heat generation)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	DHW-3	Report information regarding domestic hot water performance	1	0	0	0	0	0	0	1	2	1	0	0	0	1	0	2	3

6792

6793

6794

6795

6796

Table M3a. Lighting, DSM and Monitoring & Control service scores for the in-field SFH case study

SR fields						ORDINAL IMPACT SCORES							
Domain	Code	Service	Functionality level for this building	Max possible functionality level	Max functionality level in this building	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Lighting	Lighting-1a	Occupancy control for indoor lighting	0	3	3	0	0	0	0	0	0	0	0
Lighting	Lighting-2	Control artificial lighting power based on daylight levels	0	4	4	0	0	0	0	0	0	0	0
Demand side management	DSM-18	Smart Grid Integration	0	1	1	0	0	0	0	0	0	0	0
Demand side management	DSM-19	DSM control of equipment	0	4	4	0	0	0	0	0	0	0	0
	DSM-21	Reporting information regarding DSM	0	2	2	0	0	0	0	0	0	0	0
	DSM-22	Override of DSM control	0	3	3	0	0	0	0	0	0	0	0
Monitoring and control	MC-3	Run time management of HVAC systems	2	3	3	2	1	0	2	2	1	0	0
Monitoring and control	MC-4	Detecting faults of technical building systems and providing support to the diagnosis of these faults	0	2	2	0	0	0	0	0	0	0	0
Monitoring and control	MC-9	Occupancy detection: connected services	0	2	2	0	0	0	0	0	0	0	0
	MC-13	Central reporting of TBS performance and energy use	1	3	3	1	0	0	0	1	0	1	1

6797
6798
6799

Draft Second Progress report

6800

Table M3b. Lighting, DSM and Monitoring & Control service scores for the in-field SFH case study

SR fields			ORDINAL IMPACT SCORES								MAXIMUM POSSIBLE ORDINAL IMPACT SCORES							
Domain	Code	Service	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants	Energy	Flexibility	Self-gen	Comfort	Convenience	Health	Maintenance & fault prediction	Information to occupants
Lighting	Lighting-1a	Occupancy control for indoor lighting	0	0	0	0	0	0	0	0	2	0	0	2	2	0	0	0
Lighting	Lighting-2	Control artificial lighting power based on daylight levels	0	0	0	0	0	0	0	0	3	0	0	3	3	3	0	0
Demand side management	DSM-18	Smart Grid Integration	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0
Demand side management	DSM-19	DSM control of equipment	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0	0
	DSM-21	Reporting information regarding DSM	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	3
	DSM-22	Override of DSM control	0	0	0	0	0	0	0	0	0	2	0	0	3	0	2	2
Monitoring and control	MC-3	Run time management of HVAC systems	2	1	0	2	2	1	0	0	3	1	0	2	3	1	0	1
Monitoring and control	MC-4	Detecting faults of technical building systems and providing support to the diagnosis of these faults	0	0	0	0	0	0	0	0	0	0	0	0	2	2	3	2
Monitoring and control	MC-9	Occupancy detection: connected services	0	0	0	0	0	0	0	0	1	0	0	1	1	0	2	1
	MC-13	Central reporting of TBS performance and energy use	1	0	0	0	1	0	1	1	1	0	0	0	2	0	1	3

6801

6802

6803

6804

ANNEX N - REFERENCE LIST

Amirhosein Ghaffarianhoseini, Umberto Berardi, Husam AlWaer, Seongju Chang, Edward Halawa, Ali Ghaffarianhoseini & Derek Clements-Croome (2016), What is an intelligent building? Analysis of recent interpretations from an international perspective, *Architectural Science Review*, 59:5, 338-357, DOI: 10.1080/00038628.2015.1079164

CEN, the European Committee for Standardization, M/490: Smart Grid Mandate Standardization Mandate to European Standardisation Organisations (ESOs) to support European Smart Grid deployment.

<https://www.cencenelec.eu/standards/Sectors/SustainableEnergy/SmartGrids/Pages/default.aspx>

CEN, the European Committee for Standardization (2017), EN 16947-1:2017 Building Management System - Module M10-12.

CEN, the European Committee for Standardization (2017), Standard EN 15232 - Energy performance of buildings – Impact of Building Automation, Controls and Building Management

CEN, the European Committee for Standardization (2017), EN 15193-1: 2017 Energy performance of buildings - Energy requirements for lighting - Part 1: Specifications, Module M9

CEN, the European Committee for Standardization (2016), prEN 16947 Building Management System - Module M10-12

CEN, the European Committee for Standardization (2017), EN-ISO 52000-1:2017 Energy performance of buildings — Overarching EPB assessment – Part 1: General framework and procedures

CEN, the European Committee for Standardization (2017), EN 12098 Energy Performance of Buildings. Controls for heating systems. Control equipment for hot water heating systems

CEN, the European Committee for Standardization (2017), EN 15193-1, Energy performance of buildings. Energy requirements for lighting. Specifications, Module M9

CEN, the European Committee for Standardization (2017), EN ISO 17772-1 Energy performance of buildings -- Indoor environmental quality -- Part 1: Indoor environmental input parameters for the design and assessment of energy performance of buildings

CEN, the European Committee for Standardization (2017), Overview EPB Standards. <http://epb.center/support/documents>

CEN/CENELEC, Smart House Roadmap 2010, <ftp://ftp.cencenelec.eu/CENELEC/SmartHouse/Roadmap.pdf>, 2010 (last accessed 12/2017)

DIN (2008), CEN/TS 15810 Graphical symbols for use on integrated building automation equipment

DIN (2016), prEN-50631-1 Household appliances network and grid connectivity - Part 1: General Requirements, Generic Data Modelling and Neutral Messages

DKE, German Standardization Roadmap AAL (Ambient Assisted Living), 2014, <https://www.dke.de/de/services/normungs-roadmaps> (last accessed 12/2017) ETIP SNET (2017), <http://www.etip-snet.eu/>

Ecofys & WSE (2017), Optimising the energy use of technical building systems: Unleashing the power of the EPBD's Article 8 – Ecofys and Waide Strategic Efficiency for Danfoss. <https://www.ecofys.com/en/publications/optimising-the-energy-use-of-technical-building-systems/>

Ecofys et al. (2017) , Optimising the energy use of technical building systems: Unleashing the power of the EPBD's Article 8. <https://www.ecofys.com/en/publications/optimising-the-energy-use-of-technical-building-systems/>

ENISA (2015), Security and Resilience of Smart Home Environments Study

EPBD CA (2016), Implementing the Energy Performance of Buildings Directive (EPBD) – Featuring Country Reports. <http://www.epbd-ca.eu/ca-outcomes/2011-2015>

ETSI (2017), <http://www.etsi.org/technologies-clusters/technologies/575-smart-grids>
RT2012 (2012), <http://www.rt-batiment.fr/batiments-neufs/reglementation-thermique-2012/textes-de-references.html>

European Commission (2016), Clean Energy for All Europeans, <http://ec.europa.eu/energy/en/content/energy-efficiency-directive-winter-package-2016>

European Commission (2016), Impact Assessment accompanying the proposal for amending the Energy Performance of Buildings Directive, SWD(2016) 414.

European Interoperability Framework EIF, https://ec.europa.eu/isa2/eif_en, 2017

Gartner, Hype Cycle for the Internet of Things, 2017, Report G00314298, 2017

Gartner, Hype Cycle for the Connected Home, 2017, Report G00314854, 2017

Gartner, Hype Cycle for Smart City Technologies and Solutions, Report G00314338, 2017

IEC, the International Electrotechnical Commission (2010), IEC Smart Grid Standardization Roadmap. http://www.iec.ch/smartgrid/downloads/sg3_roadmap.pdf

IEC, the International Electrotechnical Commission, IEC 60364-8-1 ED2 Low-voltage electrical installations - Part 8-1: Energy efficiency

IEC, the International Electrotechnical Commission, IEC 60364-8-2 ED2 Low-voltage electrical installations - Part 8-2: Prosumer Low-Voltage Electrical Installations

IEC, the International Electrotechnical Commission, IEC PT 60364-8-3 Low-voltage electrical installation - Part 8-3: Evolutions of Electrical Installations

IEC, the International Electrotechnical Commission, IEC TS 62950 ED1 “Household and similar electrical appliances - Specifying smart capabilities of appliances and devices - General aspects”

IEC, the International Electrotechnical Commission, IEC TS 62898-1:2017 on “Microgrids - Part 1: Guidelines for microgrid projects planning and specification”

IEC, the International Electrotechnical Commission, IEC 61727 Photovoltaic (PV) systems – Characteristics of the utility interface

IEC, the International Electrotechnical Commission, IEC 60364-7-712 Low-voltage electrical installations - Part 7-712: Requirements for special installations or locations - Solar photovoltaic (PV) power supply systems.

IEC, the International Electrotechnical Commission, IEC 61851-1:2017 on “Electric vehicle conductive charging system - Part 1: General requirements”

IEC, the International Electrotechnical Commission, IEC 60364-7-722:2015 on “Requirements for special installations or locations - Supplies for electric vehicles”

IEC, the International Electrotechnical Commission, IEC 62933-1 Electrical Energy Storage (EES) systems - Part 3-1: Planning and installation- General specifications

IEC, the International Electrotechnical Commission (2017), IEC 60364-8-2 ED2 Low-voltage electrical installations - Part 8-2: Prosuming Low-Voltage Electrical Installations

IEC, the International Electrotechnical Commission (2017), IEC TS 62898-1:2017 Microgrids - Part 1: Guidelines for microgrid projects planning and specification

ISO, International Organization for Standardization, ISO 27000 Information technology — Security techniques — Information security management systems — Overview and vocabulary

ISO, International Organization for Standardization (2017), EN ISO 16484 Building automation and control systems (BACS)

ISO, International Organization for Standardization (2017), ISO 17772-1:2017 Energy performance of buildings -- Indoor environmental quality -- Part 1: Indoor environmental input parameters for the design and assessment of energy performance of buildings.

ISO, International Organization for Standardization (2017), EN ISO 52016-1:2017 Energy performance of buildings -- Energy needs for heating and cooling, internal temperatures and sensible and latent heat loads -- Part 1: Calculation procedures.

ISO, International Organization for Standardization (2017), ISO/IEC 27032 - Information technology - Security techniques -- Guidelines for cybersecurity

Jaap Hogeling (2016), Chair of CEN TC 371, communication on ‘QUALICheck International Workshop on Summer Comfort Technologies in Buildings Athens, 9-10 March 2016’ on ‘Energy Performance Buildings Standards: status and flexibility of the CEN and ISO standards on EPBD’

Presson: Software Metrics and Interoperability, AIAA, 1983

PEB (2011), <http://www.environnement.brussels/thematiques/batiment/la-peb/construction-et-renovation/logiciel-peb/logiciel-peb-v10>

PPP, Photonics 21 Initiative, <http://www.photonics21.org/downloads/index.php> (last accessed 12/2017)

Presson: Software Metrics and Interoperability, AIAA, 1983

Rezaei et al: A review of interoperability assessment models, JZUS, 2013

STRATEGO (2014-2016), Quantifying the Heating and Cooling Demand in Europe Work Package 2 - Background Report 4. <http://stratego-project.eu/project-brief/>

VITO & WSE (2017), Technical assistance study for the assessment of the feasibility of using "points system" methods in the implementation of Ecodesign Directive (2009/125/EC) Specific contract no.: 478/PP/GRO/IMA/15/1164 – SI2.72259. VITO, Waide Strategic Efficiency et al for DG GROW. <https://points-system.eu/>